

BID DOCUMENTS

SR 38 AT CR 73 UTILITY RELOCATION
PI #0011730
FOR
CITY OF HINESVILLE

FEBRUARY 25, 2020



***SIMONTON ENGINEERING, LLC.
CONSULTING ENGINEERS***

**HINESVILLE, GEORGIA
(912) 977-1502**

**GREENSBORO, GEORGIA
(706) 454-0870**

SE NO. 2015-41

TABLE OF CONTENTS

ADVERTISEMENT FOR BID

INSTRUCTIONS TO BIDDER

PROPOSAL

STATEMENT OF BIDDER QUALIFICATIONS

LAWFUL PRESENCE AFFIDAVIT

CONTRACTOR AFFIDAVIT

SUBCONTRACTOR AFFIDAVIT

CITY OF HINESVILLE M/WBE POLICY DOCUMENTS

CONTRACT

PAYMENT AND PERFORMANCE BOND

GENERAL CONDITIONS

SUPPLEMENTAL CONDITIONS

TECHNICAL SPECIFICATIONS

SECTION 01001 GENERAL REQUIREMENTS

SECTION 01150 MEASUREMENT AND PAYMENT

SECTION 02210 SITE GRADING

SECTION 02221 TRENCH EXCAVATION, BACKFILL, AND COMPACTION

SECTION 02415 SITE DEMOLITION

SECTION 02540 EROSION CONTROL

SECTION 02556 WATER DISTRIBUTION SYSTEM

SECTION 02650 SANITARY SEWERS

Not for Bid

ADVERTISEMENT FOR BIDS

Sealed proposals will be received by the City of Hinesville located at City Hall, 115 East ML King Jr. Drive, Hinesville, Georgia 31313 on March 17, 2021 until 2:00 p.m. local time for SR 38 at CR 73 Utility Relocation.

The work to be performed consists of furnishing all labor and materials to complete the SR 38 at CR 73 Utility Relocation. More specifically, the project will consist of the removal of existing water mains and sewer force mains, installation of roughly 1200 LF PVC Watermain and 600 LF PVC Sewer Force Main, along with associated manhole installation to connect to the existing sewer system, and associated connections to the existing water system, as well as other construction activities typically related to utility relocation.

Plans, Specifications, and Contract documents are open to public inspection at the Hinesville City Hall, 115 East ML King Jr. Drive, Hinesville, Georgia, Dodge Data and Analytics, ConstructConnect, and Simonton Engineering, LLC., 1050 Parkside Commons, Suite 101, Greensboro, Georgia 30642. Copies of the Plans, Specifications, and Contract Documents may be obtained by contacting Simonton Engineering, LLC., 1050 Parkside Commons, Suite 101, Greensboro, Georgia 30642 (706) 454-0870 by depositing a non-refundable Fifty Dollar (\$50.00) for electronic (PDF) set of plans and One Hundred Dollar (\$100.00) for each set of printed plans requested.

Each Contractor must prequalify for bid by submitting a completed "Statement of Bidder Qualifications" form supplied by the Engineer. Bids will be accepted from prequalified bidders only.

Bids must be accompanied by a certified check or bid bond in an amount equal to at least five percent (5%) of total amount bid for the completed work.

No bids may be withdrawn for a period of sixty (60) days after the closing time schedule for receipt of bids.

The Owner reserves the right to accept or reject any or all bids and to waive informalities. Award of the contract, if it is awarded, will be to the lowest responsible bidder.

The M/WBE goal for this project is 7% MBE and 3% WBE, for a total M/WBE participation of 10%. All M/WBE documents must be submitted in a separate sealed envelope, otherwise bid may be rejected.

NOTE: Plans and Specifications must be obtained no later than five (5) working days before the bid date. No exceptions.

INSTRUCTIONS TO BIDDER

1. SUBMISSION OF PROPOSALS:

- A. Sealed proposals will be received by City of Hinesville at the Hinesville City Hall until 2:00 (p.m.) local time, on March 17, 2021 for all labor and materials required to fully complete the work identified in the plans and specifications for the construction of SR 38 at CR 73 Utility Relocation for the City of Hinesville.
- B. At the time and place noted above, the proposals will be publicly opened and read aloud.
- C. The proposal (including Statement of Bidder's Qualifications) shall be submitted **in duplicate** on an exact copy of the proposal form bound herein. Both copies of the Proposal Form must be signed. All blank spaces on the forms shall be filled in and all information called for shall be provided. The terms "NO BID" may be used to fill in a blank space on the Proposal Form. All signatures shall be in ink and in longhand, and the completed forms shall be without alterations or corrections; any interlineations must be initialed by the Bidder.
- D. Failure to submit a proposal in the form requested or the inclusion of any alternates, conditions, limitations or provisions not called for, will render the bid irregular and shall be considered sufficient cause for rejection of the bid.
- E. Proposal shall be in opaque, sealed envelope and marked "SR 38 at CR 73 Utility Relocation" and shall bear the name of the Bidder. All M/WBE Policy Documents shall be submitted **in duplicate** in a separate sealed envelope and marked appropriately. Proposal is to reach the above address no later than the hour and date named above, or authorized extension thereof. No proposal will be received after that time.
- F. Proposals, together with the full bid bond, may be withdrawn by Bidders prior to the time set for official opening. After time has been called, no proposal may be withdrawn for a period of sixty (60) days after the time and date of the opening.

2. INTERPRETATIONS:

- A. Neither Owner nor Engineer will be responsible for any oral instructions or interpretations of the Drawings and Specifications.
- B. Requests for interpretations of Drawings and Specifications must be made in writing to the Engineer no later than seven (7) days prior to date set for receipt of bids, and failure on the part of the successful bidder to do so shall not relieve him as Contractor of the obligation to execute such work in accordance with a later interpretation by the Engineer.

- C. All interpretations made to bidders will be issued in the form of an addendum to the Plans and Specifications will be sent to all bidders. The requirements of such an addendum are to be included in the bids, and in closing the contract, the addenda will become a part thereof.

3. BASIS OF CONTRACT AWARD:

- A. The competency and responsibility of a bidder will be considered in making the award. Owner does not obligate himself to accept the lowest bid or any other bid.
- B. The Owner reserves the right to reject any or all proposals and to waive any technicalities.

4. FORMS AND BONDS:

- A. The Bidder's attention is directed to the Proposal Form and the Performance and Labor and Materials Payment Bond section.
- B. The bond shall be accompanied with the agents and underwriters name, address and telephone number.

5. INSPECTING AND TESTING OF MATERIALS:

- A. Whenever, in these Contract Documents, inspecting, testing, or certification of material(s) is called for, the selection of bureaus, laboratories and/or agencies for such inspecting and testing shall be made by an Independent Testing Laboratory and the character of the test shall be stipulated by the Engineer. Documentary evidence satisfactory to the Engineer that the materials have passed the required inspection and test must be furnished in quadruplicate to the Engineer by the bureau, agency, or laboratory selected. Materials satisfactorily meeting the requirements of the inspection or tests shall be approved by the Engineer and the Contractor notified of the results. The cost of such inspecting and testing shall be paid for by the Contractor.

6. CONSTRUCTION SCHEDULE:

- A. The Contractor will be required to submit a construction schedule in writing identifying milestones and completion dates at the preconstruction conference. He shall also be required to submit a resume' of the proposed job superintendent for approval by the Engineer.

7. INSURANCE:

- A. The Contractor's attention is directed to Article 11 of the Supplemental General Conditions, "Insurance." He should review these requirements and be prepared to submit insurance certificates providing the coverage identified. On the insurance certificates, the "Certificate Holder" should be listed as **both** the Owner and P.C. Simonton Engineering, LLC.

8. CONSTRUCTION STAKING:

- A. The Owner will provide horizontal and vertical control. The Contractor will be responsible for construction staking.

9. UTILITY CONTRACTOR LICENSING LAW:

- A. Effective December 31, 1993, a new law took effect which has an indirect effect on engineers. As of that date all utility contractors must be licensed; a utility contractor is anyone who digs 5 feet or deeper on a public or private project and where the cost of work exceeds \$100,000.
- B. Effective July 1, 2004 the law was modified where the cost of work has no dollar amount therefore anyone who digs 5 feet or deeper on a public or private project must have a utility license.
- C. "It shall be unlawful for any person to contract with any other person for the performance of utility contracting work who is known by such person to not have a current, valid license as a utility contractor pursuant to this chapter." (O.C.G.A. 43-14-8.2(h)) Bids or proposals for utility contracting work will NOT be opened or considered unless the Utility Contractor License number is written on the face of the bid or proposal.

10. CONTRACTOR COORDINATION:

- A. The Contractor will be required to coordinate timing and scheduling, for the work to be done as part of this contract, with all other contractors working within the project site. The roadway contractor will complete the right of way clearing, stake the right of way and drainage structures, after which the Contractor can complete the work detailed in this contract. Detailed coordination with all other contractors to complete the work will be required.
- B. The Contractor will utilize erosion & sediment control quantities to supplement the E&S measures installed by the prime contractor, utilization of the erosion & sediment control measures will be directed by the engineer.

PROPOSAL

City of Hinesville
115 East ML King Jr. Drive
Hinesville, GA 31024

Submitted: _____, _____

The undersigned, as Bidder, hereby declares that the only person or persons interested in the Proposal as principal or principals is or are named herein and that no other person that herein mentioned has any interest in this Proposal or in the contract to be entered into; that this Proposal is made without connection with any other person, company or parties making a bid or Proposal; and that it is in full respect fair and in good faith without collusion or fraud.

The Bidder further declares that he has examined the site of the work and informed himself fully in regard to all conditions pertaining to the place where the work is to be done; that he has examined the Plans and Specifications for the work and Contractual Documents relative thereto, and has read all Special Provisions and General Conditions furnished prior to the opening of bids; that he has satisfied himself relative to the work to be performed.

The Bidder proposes and agrees, if the Proposal is accepted, to contract with The City of Hinesville in the form of contract specified, to furnish all necessary materials, equipment, machinery, tools, apparatus, means of transportation and labor necessary to complete the construction of the work, in full and in complete accordance with the shown, noted, described, and reasonably intended requirements of the Specifications and Contract Documents, to the full and entire satisfaction of City of Hinesville with a definite understanding that no money will be allowed for extra work except as set forth in the attached General Conditions and Contract Documents, for prices on the following pages.

Not for Bid

Bid Items - SR 38 at CR 73 Utility Relocation
for
City of Hinesville
SE Project No. 2015-41

Item No.	Estimated Quantity	Units	Description	Unit Price	Total Price
1. <u>DEMOLITION</u>					
A.	250	LF	6" Watermain Removal	\$	\$
B.	120	LF	10" Watermain Removal	\$	\$
C.	215	LF	6" Sewer Force Main Removal	\$	\$
DEMOLITION SUBTOTAL:					\$
2. <u>WATER</u>					
A.	1	EA	10" Tapping Sleeve & Valve Connection	\$	\$
B.	2	EA	10" Connection plus Plug & Block	\$	\$
C.	1	EA	6" Connection plus Plug & Block	\$	\$
D.	1	EA	Disconnect & Reconnect Ex. 2" Service to 10" Water Main	\$	\$
E.	565	LF	6" PVC Watermain	\$	\$
F.	545	LF	10" PVC Watermain	\$	\$
G.	140	LF	16" Steel Casing	\$	\$
H.	2	EA	6" GV	\$	\$
I.	2	EA	10" GV	\$	\$
J.	1.0	TN	Fittings	\$	\$
WATER SUBTOTAL:					\$
3. <u>SANITARY SEWER</u>					
A.	1	EA	Connect to Existing System	\$	\$
B.	580	LF	6" PVC Force Main	\$	\$
C.	1	EA	Doghouse Manhole w/ Boot for Force Main	\$	\$
D.	1.0	TN	Fittings	\$	\$
SANITARY SEWER SUBTOTAL:					\$
4. <u>EROSION & SEDIMENT CONTROL</u>					
A.	1,150	LF	Type "S" Silt Fence (Sensitive)	\$	\$
B.	1	LS	Temporary Grassing		\$
C.	1	LS	Permenant Grassing		\$
EROSION & SEDIMENT CONTROL SUBTOTAL:					\$
5. <u>MISCELLANEOUS</u>					
A.	1	LS	Mobilization		\$
MISCELLANEOUS SUBTOTAL:					\$
TOTAL:					\$

The Bidder further proposes and agrees hereby to commence work under his Contract, with adequate force and equipment, on a date to be specified in written order of the ENGINEER and shall fully complete all work hereunder within One hundred twenty (120) consecutive days from and including said date.

The Bidder declares that he understands that the quantities shown for unit price items, are approximate only, are valid only upon written authorization of the ENGINEER, and are subject to either increase or decrease and that should the quantities of any items of work be increased, the Bidder proposes to do the additional at the unit prices stated herein; and should the quantities be decreased, the Bidder also understands that payment will be made on the basis of actual quantities at the unit price bid and will make no claim for anticipated profits for any decrease in quantities, and that actual quantities will be determined upon completion of the work, at which time adjustment will be made to the Contract amount by direct increase or decrease.

The undersigned further agrees that, in case of failure on his part to execute the Construction Contract and the bond within ten (10) consecutive calendar days after written notice being given of the award of the Contract, the check or bond accompanying this bid, and the monies payable thereon, shall be paid into the funds of the City of Hinesville as liquidated damages for such failure, otherwise the check or bid bond accompanying this proposal shall be returned to the undersigned.

Attached hereto is a certified check on the _____ Bank of _____ or a Bid Bond by the _____ in the amount of _____ Dollars (\$ _____) made payable to the _____, in accordance with the conditions of the advertisement and provisions herein.

Submitted:

By:

Title:

Bidders Address: _____

City, State, Zip Code: _____

Telephone Number: _____

Bonding Agent: _____

Physical Address: _____

Telephone Number: _____

Underwriters Name: _____

Physical Address: _____

Telephone Number: _____

FAILURE TO COMPLETE THIS SECTION IS GROUNDS FOR REJECTION

BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM:

No. _____ Date _____ No. _____ Date _____

No. _____ Date _____ No. _____ Date _____

EXPERIENCE AND REFERENCES

The Bidder shall state what work he had done (minimum of three) of similar nature to that bid for, and give references that will afford the Owner opportunity to judge as to experience, skill, business standing and financial ability. Failure to complete this section is grounds for rejection.

STATEMENT OF BIDDER'S QUALIFICATIONS

To accompany proposals submitted for construction of _____

Full legal name of Bidder _____

Business Address _____

Business Phone Number _____

Bidder is a (check one) Corporation _____ Partnership _____ Individual Proprietorship _____ Other (Specify) _____

When Organized? _____ When Incorporated? _____

If Bidder is a partnership, list all names of all partners _____

How many years have you been engaged in the contracting business under the present firm name _____

Will you, if requested by the Owner, furnish to them your most recent Financial Statement within 48 hours after bid taking? _____ If yes, give date of statement _____

Credit available for this contract \$ _____

Contracts now in hand, Gross Amount \$ _____

Have you ever refused to sign a contract at your original bid? _____

Do you have a Georgia Utility Contractor's License? _____ If yes, number? _____

Have you ever defaulted on a contract? _____

Remarks _____

(The above statements must be subscribed and sworn to before a Notary Public)

Sworn to and subscribed before me,
this _____ day of _____, 20____.

Firm Name: _____

(Notary Public)

By: _____

(Title)

REFERENCES:

Provide references for work done, minimum of six, three within the last 12 months of similar size and nature and a listing of all jobs performed in the last 12 months. References will afford the owner opportunity to judge as to capabilities and performance of the contractor.

Provide name, brief description, address, phone number, and contact person for each project listed. Failure to complete this section in its entirety will be grounds for rejection.

Not for Bid

LAWFUL PRESENCE AFFIDAVIT

Pursuant to O.C.G.A. § 50-36-1, all persons who - either on behalf of themselves or on behalf of an individual, business, corporation, partnership, or other private entity - apply for certain public benefits must (1) be eighteen years of age or older and (2) submit an affidavit that they are lawfully present in the United States. Public benefits, as defined by O.C.G.A. § 50-36-1(a)(3)(A), include any grant, contract, loan, professional license, or commercial license provided by an agency of State or local government or by appropriated funds of a State or local government.

I, _____, swear or affirm under penalty of perjury under the laws of the State of Georgia that I am 18 years of age or older and (check one):

___ I am a United States citizen, or

___ I am a legal Permanent Resident of the United States, or

___ I am a qualified alien (other than as a permanent resident) or nonimmigrant in the United States pursuant to Federal law.

The secure and verifiable document provided with this affidavit can best be classified as:

I understand that this sworn statement is required by law because I have applied for a public benefit and/or a business license on my behalf as an individual or on behalf of a business, corporation, partnership, or other private entity. I understand that state law required me to provide proof that I am lawfully present in the United States prior to receipt of this public benefit as listed above. I further acknowledge that making a false, fictitious, or fraudulent statement or representation in this sworn affidavit is punishable under the criminal laws of Georgia under O.C.G.A. § 16-10-20 and it shall constitute a separate criminal offense each time a public benefit is fraudulently received.

Signature

Date

Title

*Alien Registration # for Non-citizens

Business Name

TIN or SSN

If this affidavit is not presented in person, applicant must submit a notarized copy of this affidavit.

Notarized this ___ Day of _____, in the State of _____,

County of _____

Notary

Commission Expires

*Note: O.C.G.A § 50-36-1(e) (2) requires that aliens under the Federal Immigration and Nationality Act., Title 8 U.S.C., as amended, provide their alien registration number. Because legal permanent residents are included in the federal definition of "alien", legal permanent residents must also provide their alien registration number. Qualified aliens that do not have an alien registration number may supply another identifying number below:

Another Identifying Number

Contractor Affidavit under O.C.G.A. § 13-10-91(b)(1)

By executing this affidavit, the undersigned contractor verifies its compliance with O.C.G.A. §13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services on behalf of _____ has registered with, is authorized to use and uses the federal work authorization program commonly known as E-verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned contractor will continue to use the federal work authorization program throughout the contract period and the undersigned contractor will contract for the physical performance of services in satisfaction of such contract only with subcontractors who present an affidavit to the contractor with the information required by O.C.G.A. § 13-10-91(b). Contractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

Federal Work Authorization User Identification Number/E-verify User Number

Date of Authorization/Date of contract between Contractor and Public Employer

Legal Name of Contractor (please print)

Legal Address of Contractor

City, State, & Zip Code

Name of Project

Name of Public Employer

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on _____ of _____, 20____ in _____ (city), _____ (state).

Signature of Authorized Officer or Agent

Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME ON THIS _____ DAY OF _____, 20____.

Notary Public

Commission Expires

Subcontractor Affidavit under O.C.G.A. § 13-10-91(b)(3)

By executing this affidavit, the undersigned subcontractor verifies its compliance with O.C.G.A. § 13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services under a contract with _____ (name of contractor) on behalf of _____ has registered with, is authorized to use and uses the federal work authorization program commonly known as E-Verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned subcontractor will continue to use the federal work authorization program throughout the contract period and the undersigned subcontractor will contract for the physical performance of services in satisfaction of such contract only with sub-subcontractors who present an affidavit to the subcontractor with the information required by O.C.G.A. § 13-10-91(b). Additionally, the undersigned subcontractor will forward notice of the receipt of an affidavit from a sub-subcontractor to the contractor within five business days of receipt. If the undersigned subcontractor receives notice of receipt of an affidavit from any sub-subcontractor that has contracted with a sub-subcontractor to forward, within five business days of receipt, a copy of such notice to the contractor. Subcontractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

Federal Work Authorization User Identification Number

Date of Authorization

Name of Subcontractor

Name of Project

Name of Public Employer

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on _____, ____, 201__ in _____ (city), _____ (state).

Signature of Authorized Officer or Agent

Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME ON THIS THE ____ DAY OF _____, 20__.

NOTARY PUBLIC

My Commission Expires:

CITY OF HINESVILLE
M/WBE POLICY DOCUMENTS
FOR
CONSTRUCTION CONTRACTS

ALL M/WBE POLICY DOCUMENTS TO BE
SUBMITTED IN SEPARATE SEALED ENVELOPE

Not for Bid

City of Hinesville Minority and Women Business Enterprise Program (M/WBE) Policy

I. M/WBE Implementation of the Policy

The city manager of the City of Hinesville (hereinafter referred to as "the City") or his designee shall implement and administer the City's M/WBE Policy through the City's M/WBE Program.

II. Policy Statement

It is the City's policy to provide minority and women owned and operated business enterprises (M/WBEs) with equal opportunity in the procurement initiative and processes for the purchase of goods and services required for the operation and administrative needs of the City. More specifically, it is also policy to:

- A. Ensure the M/WBE Program is narrowly tailored in accordance with applicable law;
- B. Ensure that only firms which fully meet the eligibility standards specified in 49 CFR Part 3 are permitted to participate as M/WBEs;
- C. Ensure there are no barriers to the participation of M/WBEs in opportunities for contracts with the City.

The M/WBE Program will be administered by the city manager or his designee with support of all other departments of the City that are engaged in the procurement of goods and services. Further, the provisions of the M/WBE Policy shall apply to all contracts and services awarded by the City, subject to the requirements of controlling federal, state, and local laws, except as specifically exempted herein. Special emphasis shall be placed on construction contracts to promote the inclusion of M/WBEs.

III. Purposes and Objectives of the M/WBE Program

The purposes of the City's M/WBE Program are to:

- A. Advocate and promote equal opportunity and access to contracting and procurement opportunities within in the City;
- B. Develop programs that will increase the participation of M/WBEs in City contract and procurement activities in order to assure equal opportunity;
- C. Monitor and assess the utilization of M/WBEs in all City construction contract and procurement activities;
- D. Monitor and assess the compliance by contractors with the M/WBE policy on all City construction contracts;
- E. Identify M/WBEs and promote their awareness of City contracting opportunities;
- F. Support programs that provide assistance and training to less experienced small businesses as well as established small businesses working to expand their present capacity; and
- G. Recommend revisions and changes to policies and procedures that are an impediment or barrier to equal opportunity of participation for M/WBEs in City contracting and procurement activities.

The objectives of the City's M/WBE Program are to:

- A. Continue a practice of nondiscrimination in the award and administration of City contracts;
- B. Remove barriers to the participation of M/WBEs in City contracts;
- C. Assist the development of M/WBEs and their capacities so that they can successfully compete in the market outside of the M/WBE program; and

- D. Increase the number of M/WBEs and the volume of their business with the City, so as to approximate their population and market share in a given construction trade business sector.

IV. Definitions

Bid – A written quotation, proposal or offer by a bidder or contractor to perform or provide labor, materials, equipment, supplies or services to the City for a certain price, submitted in response to competitive bidding solicitation by the City.

Bidder – Any person, firm, corporation, partnership or business enterprise that submits a bid or proposal to provide labor, goods or services to the City where funds are expended.

Business Enterprise – A legal entity existing for the purpose of engaging in business for profit, including, but not limited to, a corporation, partnership, individual, sole proprietorship, joint stock company, joint venture or any other private, legally recognized entity.

Certification – The process by which M/WBEs verify their status to the City in order to be considered an M/WBE. Certification is a requirement of all M/WBEs who register as such with the City and is a prerequisite to participation in the M/WBE program.

City and City Limits – The incorporated city limits of the City of Hinesville, Georgia and its annexed boundaries, as the same may be amended from time to time.

Classification – The designation which best describes the ownership (MBE or WBE) of a business enterprise.

Commercially Useful Function - Real and actual service in the discharge of any contractual endeavor, including the execution of a distinct element of work by actually performing, managing and/or supervising the work, in accordance with normal business practices, when the firm receives due compensation for the work performed. A supplier is considered to have performed a commercially useful function when it is a manufacturer or a regular dealer.

Compliance – The condition or status of a general contractor whose bid demonstrates that it complies with the M/WBE contract goals.

Construction – The process of building, altering, repairing, improving or demolishing any public infrastructure or building, or other public improvements of any kind to any public real property. Construction does not include the routine operation, routine repair or routine maintenance of existing structures, buildings or real property.

Contract – Any and all agreements, regardless of what they may be titled, for the procurement of supplies, services, or construction.

Contractor – Any business enterprise that has entered into a contract with the City or an agency thereof.

Control or Controlled – As used in this policy, this term refers to an individual's relationship with an M/WBE and shall mean to actually possess and exercise the legal authority and power to manage business assets and/or daily operations of the business and to actively and continuously exercise such managerial authority and power in determining the policies and directing the operations of the

business, as opposed to a nominal relationship existing only to create the appearance of minority or woman ownership.

Exclusive General Contractor/Subcontractor Relations – Agreements made between or among a general contractor and an M/WBE in which the M/WBE promises not to provide subcontracting quotations to other bidders or potential bidders in exchange for preferential treatment from the contractor. Such practice is prohibited by the City; contractors and M/WBEs engaging in such practice risk suspension or debarment from performing or bidding on future City contracts.

Goal – The percentage of M/WBE participation on a given project. Goals are established on a per-project basis based on trade type involved and the trade's history of discriminatory under-participation relative to its market share.

Joint Venture – An association between an M/WBE and one or more other firms to carry out a single, for profit business enterprise, for which the venture will be recognized as partially M/WBE, based on the proportion of M/WBE ownership and participation in the joint venture.

Minority – A citizen of the United States or a lawfully admitted resident alien who is a member of any of the following groups:

- A. *African American* – All persons having origins in any black racial groups of African descent as well as those identified as Jamaican, Trinidadian, and West Indian;
- B. *Asian or Pacific Islander* – All persons having origins in any of the original peoples of the Far East, Southeast Asia, the Indian Subcontinent, or the Pacific Islands. This area includes, for example, China, Japan, Korea, India, the Philippine Islands and Samoa;
- C. *Hispanic* – All persons of Mexican, Puerto Rican, Cuban, Central American, South American, Spanish or Portuguese culture or origin, regardless of race;
- D. *American Indian and Alaskan Native* – All persons having origins in any of the original peoples of North America and who maintain cultural identification through tribal affiliation or community. This includes Aleuts and Eskimo; and
- E. *Other* – All persons belonging to an ethnic or minority group identified by the State of Georgia or the U.S. Supreme Court as a “discrete and insular” minority afforded special protection under the Equal Protection Clause of the U.S. Constitution because of inherent cultural or personal characteristics.

Minority Business Enterprise or MBE – An entity or institution that is certified by an entity specified in subsection (IX)(J) as at least 51% owned and controlled by one or more minority individuals, or, in the case of a publically owned business, at least 51% of the stock is owned by one or more minority individuals. The ownership interest must be real and continuous, and not created solely to meet the minority-owned business or contractor provisions of this policy. This definition shall include educational and other non-profit entities, designated as such under section 501(c) of the U.S. Tax Code, that have a recognized historical association with a minority group.

M/WBE Compliance Plan – The document submitted by the general contractor during the prequalification process which demonstrates how the contractor will meet the M/WBE goals of the contract on which it is bidding.

Non-Compliance – The status of a bid or bidder who fails to comply with the M/WBE contract goals upon submission of a bid or proposal.

Non-Discrimination Statement – The statement made by a bidder relating to its conduct prior to submission of a bid, as well as after the award of a contract, in which the bidder agrees to:

- A. Follow the policies of the City of Hinesville relating to the participation of M/WBEs.
- B. Undertake measures to ensure the maximum practicable participation by M/WBE; and
- C. Not engage in discriminatory conduct against M/WBEs.

Non-Local Business Enterprise – Any business that does not meet the definition of a “Local Business Enterprise” recited above.

Non-Responsive Bidder – A bidder who has submitted a bid which does not conform in all material respects to the requirements set forth in the invitation for bids.

Prequalification – The process whereby potential bidders submit their qualifications to the City for evaluation to determine if they are capable of performing the work that is being solicited and therefore, eligible to bid on the project or submit a proposal. Prequalification is a prerequisite to submitting bids or proposals, but is not a guarantee of being awarded a contract.

Procurement – The process of buying, renting, leasing or otherwise obtaining or acquiring any real or personal property, supplies, materials, equipment or services.

Professional Services – Services which require licensure as a prerequisite to participation for a profit and which involve predominately mental or intellectual labor and skills, including, but not limited to, architects, engineers, surveyors, doctors, attorneys, and accountants.

Proposed Schedule of Minority Participation – A formal bid document which expresses how a contractor will meet the M/WBE goals of a contract by listing the proposed M/WBE subcontractors and/or suppliers it will use on the City project on which it is bidding.

Purchasing – The buying, renting, leasing or otherwise obtaining or acquiring of any real or personal property, supplies, materials, equipment or services.

Responsible Bidder– A bidder who has the capacity, in all respects, to fully perform the contract and all of its requirements and the demonstrated experience, reliability, facilities, equipment and credit to reasonably assure performance.

Responsive Bidder– A bidder who has submitted a bid which conforms in all material respects to the requirements set forth in the invitation for bids.

Small Business Enterprise Development Program –A program that assists and supports the development of local small and new businesses.

Subcontract – An agreement between the general contractor and another business entity (the subcontractor) for the performance of work that is part of the general contractor’s contract with the City.

Women’s Business Enterprise or WBE – An entity or institution that is certified by an entity specified in subsection (IX)(J) as at least 51% owned and controlled by one or more women, or, in the case of a publically owned business, at least 51% of the stock is owned by one or more women. The ownership interest must be real and continuous, and not created solely to meet the woman-owned business or contractor provisions of this policy.

V. Functions Undertaken by the City's M/WBE Program

The City will provide the following services to ensure the recognition and utilization of M/WBEs located in the City and Coastal Georgia:

- A. Review the M/WBE certifications of firms seeking to be approved by the City as M/WBEs.
- B. Maintain a current database of certified M/WBEs and the services they offer. The database of M/WBEs will be made available to the public via the City's website.
- C. Provide support and assistance identifying and contacting certified M/WBEs.
- D. Help plan and participate in outreach programs and provide assistance in informing M/WBEs of procurement opportunities with the City and other public sector and private sector entities.
- E. Review the City's bid/proposals, specifications, and plans to ensure they do not limit M/WBE participation. After review, advise the City Council of the availability of M/WBE contract opportunities and assist in setting goals on City projects, contracts, and procurements.
- F. Encourage M/WBEs to participate in training programs offered by the City and/or third-party education and training providers.
- G. Refer M/WBEs to third party technical assistance providers when appropriate for bonding, financial, and technical assistance.
- H. Disseminate, through scheduled meetings and other means, information regarding the City's contracting opportunities to M/WBE contractors, subcontractors, service providers, and suppliers.
- I. Conduct debriefing sessions for M/WBEs in coordination with City staff on the quality of M/WBE participation.
- J. Maintain listing of M/WBE, minority and women -focused media.
- K. Place notices of City projects with M/WBE, minority- and women-focused media.

VI. Implementation of the M/WBE Policy

The city manager or his designee shall implement and administer the City's M/WBE Policy through the City's M/WBE Program.

Several methods may be used to increase the opportunity for M/WBE participation in City contracts. These methods include but are not limited to:

- A. Conducting pre-bid conferences
- B. Creating and distributing pamphlets/literature on doing business with the City
- C. Attending community workshops and meetings
- D. Conducting workshops and/or seminars for vendors, general contractors and subcontractors
- E. Advertising bids in M/WBE-, minority- and women-focused media
- F. Allowing vendors to register on a vendor bid list
- G. Establish flexible M/WBE prequalification for vendors and contractors.
- H. Establishing participation (utilization) goals on a project by project basis
- I. Providing information on access to small business assistance programs
- J. Establishing separate goals for minority and gender participation (MBE% and WBE %) based on their availability.
- K. Categorizing M/WBE firms by business sector, sub-sector and specialty firms and assessing their relative participation levels to most efficiently achieve the goals of this program by the most narrowly tailored means
- L. Providing project management on a project by project basis

VII. Minority Participation Encouragement Policies

The M/WBE Participation Policy for the City includes, but is not limited, to the following areas:

A. Procurement of Construction Services

The following procedures and contract requirements will be used to ensure that M/WBEs are encouraged to participate on City construction contracts:

1. For all construction projects in excess of \$100,000 the project manager will identify M/WBEs which are qualified to submit bids. Based on information gathered, the project manager will send invitations to bid directly to these firms and, on behalf of the City, will make available plans and specifications to the M/WBEs.
2. The City will establish project-specific goals for M/WBE participation based on availability of minority/women subcontractors and minority/women general contractors.
3. The City shall provide trade-specific lists of certified M/WBEs to potential general contractors.
4. The City shall require bidders to submit with their bids the Bidder's Requirements as detailed in Subsection C, in a separate sealed envelope.

Submission of the above-mentioned documentation will require contractors to fulfill any M/WBE utilization commitments made. Failure to submit the above documentation shall result in the bid being considered non-responsive, and thereby disregarded.

B. Bidder's Requirements

1. For all City bids, bidders shall be required to submit with the bid a Non-Discrimination Statement that shall affirm the bidder's agreement to:
 - a. Adhere to City policies relating to the participation of M/WBEs;
 - b. Undertake certain measures as provided in this Policy to ensure maximum practicable participation of M/WBEs; and
 - c. Not engage in discriminatory conduct of any type against M/WBEs.
2. All construction bidders shall be required to submit, in a separate sealed envelope, a Proposed Schedule of M/WBE Participation, which shall include:
 - a. The names and addresses of known M/WBEs that have agreed to perform on the contract;
 - b. A description of the work that each M/WBE will perform;
 - c. The dollar amount of the participation of each M/WBE; and
 - d. A signed commitment to use the M/WBE subcontractor whose participation it submits to meet a contractual goal.

The obligation of the bidder is to make good faith efforts to meet or exceed the M/WBE participation goal for each City contract. If the bidder is unable to meet that goal, it must submit documentation of its good faith efforts to do so. Examples of good faith efforts may be found in 49 C.F.R. 26(c). The Project Manager is responsible for determining whether a bidder who has not met the designated contract goal has documented sufficient good faith efforts to be regarded as responsive. The Project Manager will review all good faith efforts documentation for relevance, legitimacy, and accuracy.

In the event a bid is declared non-responsive as a result of insufficient M/WBE participation and/or insufficient good faith efforts, notice of the bidder's non-responsive status will be delivered in writing. The bidder may then submit an Appeal for Reconsideration to the office of the city manager within ten (10) business days of receipt of the notification. The Appeal for Reconsideration may consist of additional written documentation or the bidder's argument for reconsideration. The office of the city manager shall review the Appeal and within ten (10) business days, render a written decision as to the responsiveness or non-responsiveness of the bid.

Submission of the above-mentioned documentation will require contractors to fulfill any M/WBE utilization commitments made. Failure to submit the above documentation shall result in the bid being considered to be non-responsive, and thereby disregarded.

C. Joint Ventures/Subcontracting Participation

Joint ventures and subcontracting may be utilized to create and increase opportunities for participation of M/WBE firms and to improve managerial and technical expertise.

Joint Ventures: Where bidders engage in a joint venture for the purpose of satisfying the M/WBE participation goal, the bidder shall demonstrate that the M/WBE joint venture's participation is real and legitimate. The City shall review and approve all contractual agreements and other supporting documentation to determine the percentage of M/WBE participation. The City shall determine the level of applicable participation resulting from the joint venture based on the above criteria.

Subcontracting: A general contractor may use subcontractors to satisfy the project's M/WBE participation goal provided the subcontractor performs a commercially useful function. In determining whether an M/WBE has performed a commercially useful function, the following will be considered:

1. The nature and amount of work subcontracted;
2. Whether the M/WBE has the skill and expertise to perform the work; and
3. Whether the M/WBE actually performs, manages and supervises the work.

D. Annual Compliance Report

City staff designated by the city manager shall submit an annual report to the city manager for distribution to the Mayor and City Council, detailing M/WBE participation in City contracts for the preceding fiscal year.

The reported information will include, but will not be limited to, the following data:

1. List of all construction services contracts during the reporting period;
2. Total contract costs;
3. MBE Goal: dollar amount and percentage of total contract costs;
4. MBE Actual: dollar amount and percentage of total contract costs;
5. WBE Goal: dollar amount and percentage of total contract costs;
6. WBE Actual: dollar amount and percentage of total contract costs;

E. Compliance

1. It will be the responsibility of the Project Manager to ensure that bids and/or proposals issued by the City adhere to the provisions set forth in this Policy.
2. The city manager or his designee will assume primary responsibility for evaluating compliance with the M/WBE Program on a continuing basis, including all aspects of the Program's operations, to ensure that the mission and objective are being appropriately addressed and realized.
3. Each City contract will contain a provision requiring compliance with this Policy, including maintenance of records and delivery of all information necessary to document compliance.
4. The Project Manager shall be responsible for the evaluation of good faith effort, required subcontractor information, and all related documentation as required.

5. The Project Manager shall require documentation of all M/WBE pay requests and payments made to M/WBEs.
6. City staff designated by the city manager will monitor and evaluate program performance and compliance. Failure to comply with the M/WBE requirements may result in a recommendation for suspension or debarment of the firms and/or individuals involved.

F. Competitive Bids

Nothing in this policy is to be construed to require the City to award a bid contract to any bidder other than the lowest responsible bidder, to require contractors to award to subcontractors, or to make significant material purchases from M/WBEs who do not submit the best overall pricing to the City.

Notwithstanding the foregoing, projects utilizing state or federal funds will be awarded in accordance with all state and federal rules and regulations.

VIII. Required Contract Clauses

A. Contract Assurance

The City shall require that the following clause be included in every City general contract and subcontract: **The general contractor or subcontractor shall not discriminate on the basis of race, color, national origin, or sex in the performance of this contract. The general contractor or subcontractor shall carry out applicable requirements in the award and administration of contracts. Failure by the general contractor or subcontractor to carry out these requirements is a material breach of this contract, which may result in the termination of this contract or such other remedy as the City deems appropriate.**

B. Prompt Payment

The City shall require that the following clause be included in every City general contract: **The general contractor agrees to pay each subcontractor under this general contract for satisfactory performance of its contract no later than 10 days from the receipt of each payment the general contractor receives from the City. Any delay or postponement of payment from the above-referenced time frame may occur only for good cause following written approval of the City. This clause applies to both M/WBE and non-M/WBE subcontractors.**

IX. Monitoring and Enforcement Mechanisms

The Project Managers will monitor and track M/WBE participation through the general contractor, including City and subcontractor reports of payments in accordance with the following:

A. Post-Contract Award

After the contract award, the City will review the award documents for the scope of work each M/WBE and first-tier subcontractor is scheduled to perform, and the dollar value of that work.

B. Preconstruction Conference

The Project Manager and the general contractor, or their representatives, will schedule a preconstruction conference to discuss the work each M/WBE subcontractor is scheduled to perform.

C. Construction Contract Monitoring

The general contractor will provide the Project Manager with the work each M/WBE is responsible for performing. The Project Manager will notify the city manager of suspected violations.

In the event that it is determined that an approved M/WBE firm is scheduled and contracted to perform a designated scope of work that has been subcontracted to an unapproved firm, the Project Manager will notify the general contractor of the apparent discrepancy and potential loss of payment. The Project Manager will investigate and deliver an opinion and recommendation to the general contractor, both subcontractors, and the city manager.

D. Substitution

In the event that a general contractor is compelled to request a substitution of a certified M/WBE with the approval of the M/WBE, a written request must be signed by both parties to the request and delivered to the Project Manager. The Project Manager shall review, investigate, and render a recommendation to the city manager for approval or denial.

In the event that a general contractor is compelled to request a substitution of a certified M/WBE without the approval of the M/WBE, the written request must be signed by the general contractor and delivered to the Project Manager and the M/WBE. The M/WBE shall submit a written statement concerning the request. The Project Manager shall review, investigate, and render a recommendation to both parties and the city manager for approval or denial.

Where substitution of a certified M/WBE is approved by the city manager, the general contractor shall be required, to the extent necessary to meet the contract's M/WBE goal, to identify another certified M/WBE as a replacement or document its good faith effort to do so within ten (10) business days. Should the general contractor fail to comply, the Project Manager shall issue an order stopping part or all of the general contractor's work and/or payment until a certified M/WBE is identified or a good faith effort is made. The general contractor's continued failure to do so will result in breach of contract.

E. Record Keeping and Final Utilization of M/WBEs

The general contractor shall be responsible for the creation and maintenance of the following:

1. The name and business address, regardless of tier, of every M/WBE subcontractor, professional service provider, and vendor of materials and supplies;
2. The date of payment and the total dollar figure paid to each of the firms; and
3. The date work was performed by the M/WBE firm's own employees along with the corresponding dollar value of the work claimed toward M/WBE goals.

F. Final Report - M/WBE Utilization

Upon the successful completion of the project, contract, or transaction, the general contractor shall submit for approval a summary of the utilization and participation of any and all relevant M/WBEs. This information shall be submitted on the "Project Closeout M/WBE Utilization Report" as provided by the City. This report must be submitted to the city manager and approved prior to the official "closeout" of the project, contract, or transaction. All discrepancies, exceptions, reconciliations, balances, etc. must be satisfied prior to the official closing of the project, contract, or transaction.

G. Overall Goals

Overall goals for M/WBE participation in City contracts have been established. The minimum participation goal for W/MBE firms with City contracts is 10% when there is subcontracting.

H. Contract Goals

Contract goals are established in a manner designed to meet or exceed the overall goal for the fiscal period. Contract goals will be expressed as a percentage of the total amount of a contract.

I. Counting M/WBE Participation

The City will count M/WBE participation in City contracts toward overall and contract goals as provided in the contract specifications for the general contractor, joint venture partner with the general or subcontractor, or vendor of material or supplies.

J. Certification

The City requires that by the date and time of the bid closing all M/WBEs identified for participation in City contracts be certified as such by one of the following agencies or organizations:

City Recognized M/WBE Certification Agencies

1. Chatham County
2. City of Atlanta
3. DeKalb County
4. Fulton County
5. Georgia Department of Transportation
6. Georgia Minority Supplier Development Council
7. Savannah-Hilton Head International Airport
8. U.S. Small Business Administration 89(a) Program

The City reserves the right to, from time to time, add or delete an agency or organization from the list. Additionally, an M/WBE may request that the City consider recognition from an agency or organization unfamiliar to the City.

K. Information Collection and Reporting


1. *Monitoring of Payments to M/WBEs*


General contractors are required to maintain records and documentation of payments to M/WBEs or certified M/WBE subcontractors for three years following the performance of a contract with the City. Any authorized representative of the City can request these records be made available for inspection during that time. In particular, payments to M/WBE subcontractors may be reviewed by the City to ensure that the actual amount paid to M/WBE subcontractors equals or exceeds the dollar amounts stated in the schedule of M/WBE participation.


2. *Confidentiality*


The City will safeguard from disclosure to third parties any information that may reasonably be regarded as confidential business information, except to the extent that disclosure is required by federal, state or local law.

Approved this 2nd day of August, 2012.


James Thomas, Jr., Mayor


David Anderson, Sr. Council Member


Charles Frasier, Mayor Pro Tem


Keith Jenkins, Council Member


Jason Floyd, Council Member

Kenneth Shaw, Council Member

ATTEST:


Sarah R. Lumpkin, City Clerk

Not for Bid

NON DISCRIMINATION STATEMENT

I, _____, hereby certify that
(Contractor Name)

_____ will adhere to the City of Hinesville M/WBE policy and
(Company Name)

undertake measures to ensure maximum practicable participation of M/WBE's and not engage in discriminatory conduct of any type against M/WBE's. I understand a copy of the Hinesville M/WBE policy documents may be obtained from Hinesville City Hall at 115 East M.L. King Jr. Drive and City of Hinesville website.

Signature:

By: _____

Title: _____

Seal

Notary Signature

Not for Bid

DBE COMPLIANCE FORM

Job Number: _____

Project Name: _____

Prime Contractor and Owners Certifications:

I certify that the information submitted on and with this form is true and accurate and that this firm has met and will continue to meet the conditions of this construction contract regarding M/WBE solicitation and utilization.

Prime Contractor Signature

Date

Printed Name

General Information:

Total Contract Amount: \$ _____

Proposed Total MBE: \$ _____

Proposed Total WBE: \$ _____

Percentage M/WBE: % _____

Goal: % _____

Not for Bid

**Disadvantaged Business Enterprise Program
DBE Subcontractor Utilization Form**

ALL M/WBE'S TO BE USED SHALL BE SHOWN ON THIS FORM:

JOB NUMBER	PROJECT NAME
NAME OF PRIME BIDDER/PROPOSER	E-MAIL ADDRESS
ADDRESS	
TELEPHONE NO.	FAX NO.

The following subcontractors will be used on this project:			
COMPANY NAME, ADDRESS, PHONE NUMBER, AND E-MAIL ADDRESS	TYPE OF WORK TO BE PERFORMED	ESTIMATE DOLLAR AMOUNT	CURRENTLY CERTIFIED AS AN MBE OF WBE?

I certify under penalty of perjury that the forgoing statements are true and correct. In the event of a replacement of a subcontractor, I will adhere to the replacement requirements set forth in 40 CFR Part 33 Section 33.302(c).

Signature of Prime Contractor

Date

Print Name

Title

NON COMPLIANCE FORM

In the event that the City’s M/WBE goals have not been met the Contractor must demonstrate a good faith effort to meet the goal or that subcontractors are not being used on the project:

_____, will not utilize any subcontractors on _____
 Company Name
 _____ and understand that in the event that subcontractors are needed the
 Project Name
 M/WBE policy will still apply.

_____, has made a good faith effort to meet the City’s M/WBE goals but
 Company Name
 have been unable to do so. Good faith efforts are defined in the Hinesville M/WBE policy as those that meet or exceed the good faith efforts described in 49 C.F.R 26(c). The chart below shall be filled out demonstrating a summary of good faith efforts.

	M/WBE Contractor Contacted	Date	Method of Communication	Responded to Solicitation?	Reason for non-use	If financial list percentage increase of total cost
1				Y/N		
2				Y/N		
3				Y/N		
4				Y/N		
5				Y/N		
6				Y/N		
7				Y/N		
8				Y/N		

 Signature

(Contractor to submit with each pay request)

PAGE NO. _____
 ESTIMATE NO. _____

M/WBE CONTRACTOR COMPLIANCE TRACKING FORM

PROJECT NAME: _____
 CONTRACTOR: _____
 FOR PERIOD ENDING: _____

PROJECT NO. _____
 DIVISION NO. _____
 M/WBE GOAL 10.00%

D. M/WBE CONTRACTOR TRACKING

Total Contract Amount to Date \$

ITEM #	CONTRACTOR	WORK COMPLETED	DOLLAR AMOUNT	PERCENT OF TOTAL CONTRACT
1			\$	
2			\$	
3			\$	
4				
5				

TOTAL M/WBE DOLLARS SPENT	
---------------------------	--

PERCENTAGE OF TOTAL CONTRACT	
------------------------------	--

HAS THE ESTIMATED M/WBE GOALS CHANGED FROM THE TIME OF BID?
 WILL THE M/WBE GOALS BE MET BY PROJECT COMPLETION?

YES NO
 YES NO

 Contractor certifies the statements above by signing

END OF PROJECT REPORT FORM

Please submit a “negative” report even if \$0 is the amount paid to MBE/WBE subcontractors during the reporting period.

PROJECT CLOSE-OUT FORM	
1. PRIME CONTRACTOR	2. Project Completion Date:
3. Submit to: P.C. SIMONTON & ASSOCIATES, INC. P.O. BOX 649 HINESVILLE, GA 31310 PHONE NUMBER: 912-368-5212 FAX: 912-368-6071	4. CONTRACTOR:
5. TOTAL CONSTRUCTION AMOUNT:	6. ACTUAL DOLLAR AMOUNT PAID TO MBE/WBE SUBCONTRACTORS THIS PROJECT \$MBE _____ \$WBE _____ NEGATIVE REPORT (\$0) _____
7. RECIPIENTS’S MBE/WBE GOALS M/WBE 10.0%	8. TOTAL DOLLARS SPENT THIS PROJECT MBE \$ _____ WBE \$ _____ NON MBE/WBE \$ _____ TOTAL \$ _____
9. SIGNATURE OF PRIME CONTRACTOR REPRESENTATIVE	10. DATE
TOTAL MBE/WBE PAYMENTS MADE DURING THIS PROJECT	
NAME & ADDRESS of DBE (SUB)CONTRACTOR (indicate if MBE or WBE firm)	TOTAL DOLLAR AMOUNT PAID & DATE PAID \$ _____ DATE _____

Not for Bid

CONTRACT

THIS AGREEMENT, made this _____ day of _____, 20__, by and between _____, herein called "OWNER" acting herein through _____ and _____, of _____, County of _____, and State of _____, herein called "CONTRACTOR".

WITNESSETH: that for and in consideration of the payments and agreement hereinafter mentioned, to be made and performed by the OWNER, and the CONTRACTOR hereby agrees with the OWNER to commence and complete the construction described as follows:

SR 38 AT CR 73 UTILITY RELOCATION
FOR
CITY OF HINESVILLE

hereinafter called the project, for the sum of _____ Dollars (\$ _____) and all extra work in connection therewith, under the terms as stated in the General and Special Conditions of the Contract; and at his (its or their) own proper cost and expense to furnish all the materials, supplies, machinery, equipment, tools, superintendence, labor, insurance, and other accessories and services necessary to complete the said project in accordance with the conditions and prices stated in the Proposal; the General Conditions, Supplemental General Conditions and Special Conditions of the Contract, the plans, which include all maps, plats, blue prints and other drawings and printed or written explanatory matter thereof, the specifications and Contract Documents therefore as prepared by P.C. Simonton Engineering, LLC., herein entitled the ENGINEER, and as enumerated in Paragraph 1 of the Supplementary General Conditions, all of which are made a part hereof and collectively evidence and constitute the Contract.

The Contractor hereby agrees to commence work under this Contract on or before a date to be specified in a written "Notice to Proceed" from the Owner and to fully complete the project within One hundred twenty (120) consecutive calendar days thereafter.

The Contractor further agrees to pay, as liquidated damages, the sum of \$300 for each consecutive calendar day thereafter as hereinafter provided in Section 01001, Paragraph 1.11.

The owner agrees to pay the contractor in current funds for the past performance of the contract subject to additions and deductions as provided in the General Conditions, Article 14 of the contract. Retainage on progress payments shall be ten (10) percent until the project is substantially complete (80% or more) at which point retainage may be reduced to 5% depending on the contractor's progress related to schedule and workmanship.

Not for Bid

IN WITNESS WHEREOF, the parties present have executed this contract in four (4) counterparts, each of which shall be deemed an original, in the year and day first above mentioned.

ATTEST

(Owner)

(Secretary) By _____

(Witness) (Title)

(Contractor)

(Secretary) By _____

(Witness) (Title)

(Address and Zip Code)

Not for Bid

PERFORMANCE BOND AND LABOR AND MATERIAL PAYMENT BOND

1. REFERENCE

By reference, "The Performance Bond and Payment Bond", E.J.C.D.C. Document C-610 and C-615, 2007 Edition, pages 1 through 2 of each inclusive, is a part of this Contract.

Not for Bid

This document has important legal consequences; consultation with an attorney is encouraged with respect to its use or modification. This document should be adapted to the particular circumstances of the contemplated Project and the controlling Laws and Regulations.

STANDARD GENERAL CONDITIONS OF THE CONSTRUCTION CONTRACT

Prepared by

ENGINEERS JOINT CONTRACT DOCUMENTS COMMITTEE

and

Issued and Published Jointly by

ACEC

AMERICAN COUNCIL OF ENGINEERING COMPANIES



ASCE *American Society
of Civil Engineers*

P/E *National Society of
Professional Engineers*
Professional Engineers in Private Practice

AMERICAN COUNCIL OF ENGINEERING COMPANIES

ASSOCIATED GENERAL CONTRACTORS OF AMERICA

AMERICAN SOCIETY OF CIVIL ENGINEERS

PROFESSIONAL ENGINEERS IN PRIVATE PRACTICE

A Practice Division of the

NATIONAL SOCIETY OF PROFESSIONAL ENGINEERS

Endorsed by



CONSTRUCTION SPECIFICATIONS INSTITUTE

These General Conditions have been prepared for use with the Suggested Forms of Agreement Between Owner and Contractor (EJCDC C-520 or C-525, 2007 Editions). Their provisions are interrelated and a change in one may necessitate a change in the other. Comments concerning their usage are contained in the Narrative Guide to the EJCDC Construction Documents (EJCDC C-001, 2007 Edition). For guidance in the preparation of Supplementary Conditions, see Guide to the Preparation of Supplementary Conditions (EJCDC C-800, 2007 Edition).

Copyright © 2007 National Society of Professional Engineers
1420 King Street, Alexandria, VA 22314-2794
(703) 684-2882
www.nspe.org

American Council of Engineering Companies
1015 15th Street N.W., Washington, DC 20005
(202) 347-7474
www.acec.org

American Society of Civil Engineers
1801 Alexander Bell Drive, Reston, VA 20191-4400
(800) 548-2723
www.asce.org

Associated General Contractors of America
2300 Wilson Boulevard, Suite 400, Arlington, VA 22201-3308
(703) 548-3118
www.agc.org

The copyright for this EJCDC document is owned jointly by the four EJCDC sponsoring organizations and held in trust for their benefit by NSPE.

STANDARD GENERAL CONDITIONS OF THE CONSTRUCTION CONTRACT

TABLE OF CONTENTS

	Page
Article 1 – Definitions and Terminology	1
1.01 Defined Terms.....	1
1.02 Terminology.....	5
Article 2 – Preliminary Matters	6
2.01 Delivery of Bonds and Evidence of Insurance	6
2.02 Copies of Documents.....	6
2.03 Commencement of Contract Times; Notice to Proceed.....	6
2.04 Starting the Work.....	7
2.05 Before Starting Construction	7
2.06 Preconstruction Conference; Designation of Authorized Representatives.....	7
2.07 Initial Acceptance of Schedules.....	7
Article 3 – Contract Documents: Intent, Amending, Reuse	8
3.01 Intent.....	8
3.02 Reference Standards.....	8
3.03 Reporting and Resolving Discrepancies.....	9
3.04 Amending and Supplementing Contract Documents.....	9
3.05 Reuse of Documents	10
3.06 Electronic Data.....	10
Article 4 – Availability of Lands; Subsurface and Physical Conditions; Hazardous Environmental Conditions; Reference Points.....	11
4.01 Availability of Lands.....	11
4.02 Subsurface and Physical Conditions.....	11
4.03 Differing Subsurface or Physical Conditions	12
4.04 Underground Facilities.....	13
4.05 Reference Points.....	14
4.06 Hazardous Environmental Condition at Site.....	14
Article 5 – Bonds and Insurance.....	16
5.01 Performance, Payment, and Other Bonds.....	16
5.02 Licensed Sureties and Insurers.....	16
5.03 Certificates of Insurance	17
5.04 Contractor’s Insurance	17
5.05 Owner’s Liability Insurance.....	19
5.06 Property Insurance.....	19
5.07 Waiver of Rights	20
5.08 Receipt and Application of Insurance Proceeds.....	21

5.09	Acceptance of Bonds and Insurance; Option to Replace	21
5.10	Partial Utilization, Acknowledgment of Property Insurer.....	22
Article 6 – Contractor’s Responsibilities		22
6.01	Supervision and Superintendence.....	22
6.02	Labor; Working Hours	22
6.03	Services, Materials, and Equipment	22
6.04	Progress Schedule	23
6.05	Substitutes and “Or-Equals”	23
6.06	Concerning Subcontractors, Suppliers, and Others.....	25
6.07	Patent Fees and Royalties	27
6.08	Permits.....	27
6.09	Laws and Regulations	28
6.10	Taxes	28
6.11	Use of Site and Other Areas.....	28
6.12	Record Documents.....	29
6.13	Safety and Protection	29
6.14	Safety Representative.....	30
6.15	Hazard Communication Programs.....	30
6.16	Emergencies	30
6.17	Shop Drawings and Samples	31
6.18	Continuing the Work.....	32
6.19	Contractor’s General Warranty and Guarantee	33
6.20	Indemnification	33
6.21	Delegation of Professional Design Services.....	34
Article 7 – Other Work at the Site.....		35
7.01	Related Work at Site	35
7.02	Coordination.....	35
7.03	Legal Relationships.....	36
Article 8 – Owner’s Responsibilities.....		36
8.01	Communications to Contractor.....	36
8.02	Replacement of Engineer.....	36
8.03	Furnish Data	36
8.04	Pay When Due.....	36
8.05	Lands and Easements; Reports and Tests.....	36
8.06	Insurance.....	36
8.07	Change Orders.....	37
8.08	Inspections, Tests, and Approvals	37
8.09	Limitations on Owner’s Responsibilities	37
8.10	Undisclosed Hazardous Environmental Condition	37
8.11	Evidence of Financial Arrangements.....	37
8.12	Compliance with Safety Program.....	37
Article 9 – Engineer’s Status During Construction.....		37
9.01	Owner’s Representative	37

9.02	Visits to Site	37
9.03	Project Representative.....	38
9.04	Authorized Variations in Work	38
9.05	Rejecting Defective Work.....	38
9.06	Shop Drawings, Change Orders and Payments.....	39
9.07	Determinations for Unit Price Work	39
9.08	Decisions on Requirements of Contract Documents and Acceptability of Work.....	39
9.09	Limitations on Engineer’s Authority and Responsibilities	39
9.10	Compliance with Safety Program	40
Article 10 – Changes in the Work; Claims		40
10.01	Authorized Changes in the Work	40
10.02	Unauthorized Changes in the Work.....	41
10.03	Execution of Change Orders.....	41
10.04	Notification to Surety.....	41
10.05	Claims.....	41
Article 11 – Cost of the Work; Allowances; Unit Price Work.....		42
11.01	Cost of the Work.....	42
11.02	Allowances	45
11.03	Unit Price Work	45
Article 12 – Change of Contract Price; Change of Contract Times		46
12.01	Change of Contract Price	46
12.02	Change of Contract Times	47
12.03	Delays.....	47
Article 13 – Tests and Inspections; Correction, Removal or Acceptance of Defective Work.....		48
13.01	Notice of Defects.....	48
13.02	Access to Work	48
13.03	Tests and Inspections	49
13.04	Uncovering Work.....	49
13.05	Owner May Stop the Work.....	50
13.06	Correction or Removal of Defective Work.....	50
13.07	Correction Period	50
13.08	Acceptance of Defective Work.....	51
13.09	Owner May Correct Defective Work	52
Article 14 – Payments to Contractor and Completion		52
14.01	Schedule of Values.....	52
14.02	Progress Payments	52
14.03	Contractor’s Warranty of Title.....	55
14.04	Substantial Completion.....	55
14.05	Partial Utilization	56
14.06	Final Inspection	57
14.07	Final Payment.....	57
14.08	Final Completion Delayed	58

14.09 Waiver of Claims	58
Article 15 – Suspension of Work and Termination	59
15.01 Owner May Suspend Work.....	59
15.02 Owner May Terminate for Cause	59
15.03 Owner May Terminate For Convenience	60
15.04 Contractor May Stop Work or Terminate.....	60
Article 16 – Dispute Resolution	61
16.01 Methods and Procedures	61
Article 17 – Miscellaneous	61
17.01 Giving Notice	61
17.02 Computation of Times	62
17.03 Cumulative Remedies	62
17.04 Survival of Obligations	62
17.05 Controlling Law	62
17.06 Headings.....	62

Not for Bid

ARTICLE 1 – DEFINITIONS AND TERMINOLOGY

1.01 *Defined Terms*

- A. Wherever used in the Bidding Requirements or Contract Documents and printed with initial capital letters, the terms listed below will have the meanings indicated which are applicable to both the singular and plural thereof. In addition to terms specifically defined, terms with initial capital letters in the Contract Documents include references to identified articles and paragraphs, and the titles of other documents or forms.
1. *Addenda*—Written or graphic instruments issued prior to the opening of Bids which clarify, correct, or change the Bidding Requirements or the proposed Contract Documents.
 2. *Agreement*—The written instrument which is evidence of the agreement between Owner and Contractor covering the Work.
 3. *Application for Payment*—The form acceptable to Engineer which is to be used by Contractor during the course of the Work in requesting progress or final payments and which is to be accompanied by such supporting documentation as is required by the Contract Documents.
 4. *Asbestos*—Any material that contains more than one percent asbestos and is friable or is releasing asbestos fibers into the air above current action levels established by the United States Occupational Safety and Health Administration.
 5. *Bid*—The offer or proposal of a Bidder submitted on the prescribed form setting forth the prices for the Work to be performed.
 6. *Bidder*—The individual or entity who submits a Bid directly to Owner.
 7. *Bidding Documents*—The Bidding Requirements and the proposed Contract Documents (including all Addenda).
 8. *Bidding Requirements*—The advertisement or invitation to bid, Instructions to Bidders, Bid security of acceptable form, if any, and the Bid Form with any supplements.
 9. *Change Order*—A document recommended by Engineer which is signed by Contractor and Owner and authorizes an addition, deletion, or revision in the Work or an adjustment in the Contract Price or the Contract Times, issued on or after the Effective Date of the Agreement.
 10. *Claim*—A demand or assertion by Owner or Contractor seeking an adjustment of Contract Price or Contract Times, or both, or other relief with respect to the terms of the Contract. A demand for money or services by a third party is not a Claim.
 11. *Contract*—The entire and integrated written agreement between the Owner and Contractor concerning the Work. The Contract supersedes prior negotiations, representations, or agreements, whether written or oral.

12. *Contract Documents*—Those items so designated in the Agreement. Only printed or hard copies of the items listed in the Agreement are Contract Documents. Approved Shop Drawings, other Contractor submittals, and the reports and drawings of subsurface and physical conditions are not Contract Documents.
13. *Contract Price*—The moneys payable by Owner to Contractor for completion of the Work in accordance with the Contract Documents as stated in the Agreement (subject to the provisions of Paragraph 11.03 in the case of Unit Price Work).
14. *Contract Times*—The number of days or the dates stated in the Agreement to: (i) achieve Milestones, if any; (ii) achieve Substantial Completion; and (iii) complete the Work so that it is ready for final payment as evidenced by Engineer's written recommendation of final payment.
15. *Contractor*—The individual or entity with whom Owner has entered into the Agreement.
16. *Cost of the Work*—See Paragraph 11.01 for definition.
17. *Drawings*—That part of the Contract Documents prepared or approved by Engineer which graphically shows the scope, extent, and character of the Work to be performed by Contractor. Shop Drawings and other Contractor submittals are not Drawings as so defined.
18. *Effective Date of the Agreement*—The date indicated in the Agreement on which it becomes effective, but if no such date is indicated, it means the date on which the Agreement is signed and delivered by the last of the two parties to sign and deliver.
19. *Engineer*—The individual or entity named as such in the Agreement.
20. *Field Order*—A written order issued by Engineer which requires minor changes in the Work but which does not involve a change in the Contract Price or the Contract Times.
21. *General Requirements*—Sections of Division 1 of the Specifications.
22. *Hazardous Environmental Condition*—The presence at the Site of Asbestos, PCBs, Petroleum, Hazardous Waste, or Radioactive Material in such quantities or circumstances that may present a substantial danger to persons or property exposed thereto.
23. *Hazardous Waste*—The term Hazardous Waste shall have the meaning provided in Section 1004 of the Solid Waste Disposal Act (42 USC Section 6903) as amended from time to time.
24. *Laws and Regulations; Laws or Regulations*—Any and all applicable laws, rules, regulations, ordinances, codes, and orders of any and all governmental bodies, agencies, authorities, and courts having jurisdiction.
25. *Liens*—Charges, security interests, or encumbrances upon Project funds, real property, or personal property.
26. *Milestone*—A principal event specified in the Contract Documents relating to an intermediate completion date or time prior to Substantial Completion of all the Work.

27. *Notice of Award*—The written notice by Owner to the Successful Bidder stating that upon timely compliance by the Successful Bidder with the conditions precedent listed therein, Owner will sign and deliver the Agreement.
28. *Notice to Proceed*—A written notice given by Owner to Contractor fixing the date on which the Contract Times will commence to run and on which Contractor shall start to perform the Work under the Contract Documents.
29. *Owner*—The individual or entity with whom Contractor has entered into the Agreement and for whom the Work is to be performed.
30. *PCBs*—Polychlorinated biphenyls.
31. *Petroleum*—Petroleum, including crude oil or any fraction thereof which is liquid at standard conditions of temperature and pressure (60 degrees Fahrenheit and 14.7 pounds per square inch absolute), such as oil, petroleum, fuel oil, oil sludge, oil refuse, gasoline, kerosene, and oil mixed with other non-Hazardous Waste and crude oils.
32. *Progress Schedule*—A schedule, prepared and maintained by Contractor, describing the sequence and duration of the activities comprising the Contractor's plan to accomplish the Work within the Contract Times.
33. *Project*—The total construction of which the Work to be performed under the Contract Documents may be the whole, or a part.
34. *Project Manual*—The bound documentary information prepared for bidding and constructing the Work. A listing of the contents of the Project Manual, which may be bound in one or more volumes, is contained in the table(s) of contents.
35. *Radioactive Material*—Source, special nuclear, or byproduct material as defined by the Atomic Energy Act of 1954 (42 USC Section 2011 et seq.) as amended from time to time.
36. *Resident Project Representative*—The authorized representative of Engineer who may be assigned to the Site or any part thereof.
37. *Samples*—Physical examples of materials, equipment, or workmanship that are representative of some portion of the Work and which establish the standards by which such portion of the Work will be judged.
38. *Schedule of Submittals*—A schedule, prepared and maintained by Contractor, of required submittals and the time requirements to support scheduled performance of related construction activities.
39. *Schedule of Values*—A schedule, prepared and maintained by Contractor, allocating portions of the Contract Price to various portions of the Work and used as the basis for reviewing Contractor's Applications for Payment.

40. *Shop Drawings*—All drawings, diagrams, illustrations, schedules, and other data or information which are specifically prepared or assembled by or for Contractor and submitted by Contractor to illustrate some portion of the Work.
41. *Site*—Lands or areas indicated in the Contract Documents as being furnished by Owner upon which the Work is to be performed, including rights-of-way and easements for access thereto, and such other lands furnished by Owner which are designated for the use of Contractor.
42. *Specifications*—That part of the Contract Documents consisting of written requirements for materials, equipment, systems, standards and workmanship as applied to the Work, and certain administrative requirements and procedural matters applicable thereto.
43. *Subcontractor*—An individual or entity having a direct contract with Contractor or with any other Subcontractor for the performance of a part of the Work at the Site.
44. *Substantial Completion*—The time at which the Work (or a specified part thereof) has progressed to the point where, in the opinion of Engineer, the Work (or a specified part thereof) is sufficiently complete, in accordance with the Contract Documents, so that the Work (or a specified part thereof) can be utilized for the purposes for which it is intended. The terms “substantially complete” and “substantially completed” as applied to all or part of the Work refer to Substantial Completion thereof.
45. *Successful Bidder*—The Bidder submitting a responsive Bid to whom Owner makes an award.
46. *Supplementary Conditions*—That part of the Contract Documents which amends or supplements these General Conditions.
47. *Supplier*—A manufacturer, fabricator, supplier, distributor, materialman, or vendor having a direct contract with Contractor or with any Subcontractor to furnish materials or equipment to be incorporated in the Work by Contractor or Subcontractor.
48. *Underground Facilities*—All underground pipelines, conduits, ducts, cables, wires, manholes, vaults, tanks, tunnels, or other such facilities or attachments, and any encasements containing such facilities, including those that convey electricity, gases, steam, liquid petroleum products, telephone or other communications, cable television, water, wastewater, storm water, other liquids or chemicals, or traffic or other control systems.
49. *Unit Price Work*—Work to be paid for on the basis of unit prices.
50. *Work*—The entire construction or the various separately identifiable parts thereof required to be provided under the Contract Documents. Work includes and is the result of performing or providing all labor, services, and documentation necessary to produce such construction, and furnishing, installing, and incorporating all materials and equipment into such construction, all as required by the Contract Documents.
51. *Work Change Directive*—A written statement to Contractor issued on or after the Effective Date of the Agreement and signed by Owner and recommended by Engineer ordering an

addition, deletion, or revision in the Work, or responding to differing or unforeseen subsurface or physical conditions under which the Work is to be performed or to emergencies. A Work Change Directive will not change the Contract Price or the Contract Times but is evidence that the parties expect that the change ordered or documented by a Work Change Directive will be incorporated in a subsequently issued Change Order following negotiations by the parties as to its effect, if any, on the Contract Price or Contract Times.

1.02 Terminology

A. The words and terms discussed in Paragraph 1.02.B through F are not defined but, when used in the Bidding Requirements or Contract Documents, have the indicated meaning.

B. *Intent of Certain Terms or Adjectives:*

1. The Contract Documents include the terms “as allowed,” “as approved,” “as ordered,” “as directed” or terms of like effect or import to authorize an exercise of professional judgment by Engineer. In addition, the adjectives “reasonable,” “suitable,” “acceptable,” “proper,” “satisfactory,” or adjectives of like effect or import are used to describe an action or determination of Engineer as to the Work. It is intended that such exercise of professional judgment, action, or determination will be solely to evaluate, in general, the Work for compliance with the information in the Contract Documents and with the design concept of the Project as a functioning whole as shown or indicated in the Contract Documents (unless there is a specific statement indicating otherwise). The use of any such term or adjective is not intended to and shall not be effective to assign to Engineer any duty or authority to supervise or direct the performance of the Work, or any duty or authority to undertake responsibility contrary to the provisions of Paragraph 9.09 or any other provision of the Contract Documents.

C. *Day:*

1. The word “day” means a calendar day of 24 hours measured from midnight to the next midnight.

D. *Defective:*

1. The word “defective,” when modifying the word “Work,” refers to Work that is unsatisfactory, faulty, or deficient in that it:
 - a. does not conform to the Contract Documents; or
 - b. does not meet the requirements of any applicable inspection, reference standard, test, or approval referred to in the Contract Documents; or
 - c. has been damaged prior to Engineer’s recommendation of final payment (unless responsibility for the protection thereof has been assumed by Owner at Substantial Completion in accordance with Paragraph 14.04 or 14.05).

E. *Furnish, Install, Perform, Provide:*

1. The word “furnish,” when used in connection with services, materials, or equipment, shall mean to supply and deliver said services, materials, or equipment to the Site (or some other specified location) ready for use or installation and in usable or operable condition.
2. The word “install,” when used in connection with services, materials, or equipment, shall mean to put into use or place in final position said services, materials, or equipment complete and ready for intended use.
3. The words “perform” or “provide,” when used in connection with services, materials, or equipment, shall mean to furnish and install said services, materials, or equipment complete and ready for intended use.
4. When “furnish,” “install,” “perform,” or “provide” is not used in connection with services, materials, or equipment in a context clearly requiring an obligation of Contractor, “provide” is implied.

F. Unless stated otherwise in the Contract Documents, words or phrases that have a well-known technical or construction industry or trade meaning are used in the Contract Documents in accordance with such recognized meaning.

ARTICLE 2 – PRELIMINARY MATTERS

2.01 *Delivery of Bonds and Evidence of Insurance*

- A. When Contractor delivers the executed counterparts of the Agreement to Owner, Contractor shall also deliver to Owner such bonds as Contractor may be required to furnish.
- B. *Evidence of Insurance:* Before any Work at the Site is started, Contractor and Owner shall each deliver to the other, with copies to each additional insured identified in the Supplementary Conditions, certificates of insurance (and other evidence of insurance which either of them or any additional insured may reasonably request) which Contractor and Owner respectively are required to purchase and maintain in accordance with Article 5.

2.02 *Copies of Documents*

- A. Owner shall furnish to Contractor up to ten printed or hard copies of the Drawings and Project Manual. Additional copies will be furnished upon request at the cost of reproduction.

2.03 *Commencement of Contract Times; Notice to Proceed*

- A. The Contract Times will commence to run on the thirtieth day after the Effective Date of the Agreement or, if a Notice to Proceed is given, on the day indicated in the Notice to Proceed. A Notice to Proceed may be given at any time within 30 days after the Effective Date of the Agreement. In no event will the Contract Times commence to run later than the sixtieth day after the day of Bid opening or the thirtieth day after the Effective Date of the Agreement, whichever date is earlier.

2.04 *Starting the Work*

- A. Contractor shall start to perform the Work on the date when the Contract Times commence to run. No Work shall be done at the Site prior to the date on which the Contract Times commence to run.

2.05 *Before Starting Construction*

- A. *Preliminary Schedules:* Within 10 days after the Effective Date of the Agreement (unless otherwise specified in the General Requirements), Contractor shall submit to Engineer for timely review:
 - 1. a preliminary Progress Schedule indicating the times (numbers of days or dates) for starting and completing the various stages of the Work, including any Milestones specified in the Contract Documents;
 - 2. a preliminary Schedule of Submittals; and
 - 3. a preliminary Schedule of Values for all of the Work which includes quantities and prices of items which when added together equal the Contract Price and subdivides the Work into component parts in sufficient detail to serve as the basis for progress payments during performance of the Work. Such prices will include an appropriate amount of overhead and profit applicable to each item of Work.

2.06 *Preconstruction Conference; Designation of Authorized Representatives*

- A. Before any Work at the Site is started, a conference attended by Owner, Contractor, Engineer, and others as appropriate will be held to establish a working understanding among the parties as to the Work and to discuss the schedules referred to in Paragraph 2.05.A, procedures for handling Shop Drawings and other submittals, processing Applications for Payment, and maintaining required records.
- B. At this conference Owner and Contractor each shall designate, in writing, a specific individual to act as its authorized representative with respect to the services and responsibilities under the Contract. Such individuals shall have the authority to transmit instructions, receive information, render decisions relative to the Contract, and otherwise act on behalf of each respective party.

2.07 *Initial Acceptance of Schedules*

- A. At least 10 days before submission of the first Application for Payment a conference attended by Contractor, Engineer, and others as appropriate will be held to review for acceptability to Engineer as provided below the schedules submitted in accordance with Paragraph 2.05.A. Contractor shall have an additional 10 days to make corrections and adjustments and to complete and resubmit the schedules. No progress payment shall be made to Contractor until acceptable schedules are submitted to Engineer.
 - 1. The Progress Schedule will be acceptable to Engineer if it provides an orderly progression of the Work to completion within the Contract Times. Such acceptance will not impose on

Engineer responsibility for the Progress Schedule, for sequencing, scheduling, or progress of the Work, nor interfere with or relieve Contractor from Contractor's full responsibility therefor.

2. Contractor's Schedule of Submittals will be acceptable to Engineer if it provides a workable arrangement for reviewing and processing the required submittals.
3. Contractor's Schedule of Values will be acceptable to Engineer as to form and substance if it provides a reasonable allocation of the Contract Price to component parts of the Work.

ARTICLE 3 – CONTRACT DOCUMENTS: INTENT, AMENDING, REUSE

3.01 *Intent*

- A. The Contract Documents are complementary; what is required by one is as binding as if required by all.
- B. It is the intent of the Contract Documents to describe a functionally complete project (or part thereof) to be constructed in accordance with the Contract Documents. Any labor, documentation, services, materials, or equipment that reasonably may be inferred from the Contract Documents or from prevailing custom or trade usage as being required to produce the indicated result will be provided whether or not specifically called for, at no additional cost to Owner.
- C. Clarifications and interpretations of the Contract Documents shall be issued by Engineer as provided in Article 9.

3.02 *Reference Standards*

- A. Standards, Specifications, Codes, Laws, and Regulations
 1. Reference to standards, specifications, manuals, or codes of any technical society, organization, or association, or to Laws or Regulations, whether such reference be specific or by implication, shall mean the standard, specification, manual, code, or Laws or Regulations in effect at the time of opening of Bids (or on the Effective Date of the Agreement if there were no Bids), except as may be otherwise specifically stated in the Contract Documents.
 2. No provision of any such standard, specification, manual, or code, or any instruction of a Supplier, shall be effective to change the duties or responsibilities of Owner, Contractor, or Engineer, or any of their subcontractors, consultants, agents, or employees, from those set forth in the Contract Documents. No such provision or instruction shall be effective to assign to Owner, Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors, any duty or authority to supervise or direct the performance of the Work or any duty or authority to undertake responsibility inconsistent with the provisions of the Contract Documents.

3.03 *Reporting and Resolving Discrepancies*

A. *Reporting Discrepancies:*

1. *Contractor's Review of Contract Documents Before Starting Work:* Before undertaking each part of the Work, Contractor shall carefully study and compare the Contract Documents and check and verify pertinent figures therein and all applicable field measurements. Contractor shall promptly report in writing to Engineer any conflict, error, ambiguity, or discrepancy which Contractor discovers, or has actual knowledge of, and shall obtain a written interpretation or clarification from Engineer before proceeding with any Work affected thereby.
2. *Contractor's Review of Contract Documents During Performance of Work:* If, during the performance of the Work, Contractor discovers any conflict, error, ambiguity, or discrepancy within the Contract Documents, or between the Contract Documents and (a) any applicable Law or Regulation, (b) any standard, specification, manual, or code, or (c) any instruction of any Supplier, then Contractor shall promptly report it to Engineer in writing. Contractor shall not proceed with the Work affected thereby (except in an emergency as required by Paragraph 6.16.A) until an amendment or supplement to the Contract Documents has been issued by one of the methods indicated in Paragraph 3.04.
3. Contractor shall not be liable to Owner or Engineer for failure to report any conflict, error, ambiguity, or discrepancy in the Contract Documents unless Contractor had actual knowledge thereof.

B. *Resolving Discrepancies:*

1. Except as may be otherwise specifically stated in the Contract Documents, the provisions of the Contract Documents shall take precedence in resolving any conflict, error, ambiguity, or discrepancy between the provisions of the Contract Documents and:
 - a. the provisions of any standard, specification, manual, or code, or the instruction of any Supplier (whether or not specifically incorporated by reference in the Contract Documents); or
 - b. the provisions of any Laws or Regulations applicable to the performance of the Work (unless such an interpretation of the provisions of the Contract Documents would result in violation of such Law or Regulation).

3.04 *Amending and Supplementing Contract Documents*

- A. The Contract Documents may be amended to provide for additions, deletions, and revisions in the Work or to modify the terms and conditions thereof by either a Change Order or a Work Change Directive.
- B. The requirements of the Contract Documents may be supplemented, and minor variations and deviations in the Work may be authorized, by one or more of the following ways:

1. A Field Order;
2. Engineer's approval of a Shop Drawing or Sample (subject to the provisions of Paragraph 6.17.D.3); or
3. Engineer's written interpretation or clarification.

3.05 *Reuse of Documents*

- A. Contractor and any Subcontractor or Supplier shall not:
1. have or acquire any title to or ownership rights in any of the Drawings, Specifications, or other documents (or copies of any thereof) prepared by or bearing the seal of Engineer or its consultants, including electronic media editions; or
 2. reuse any such Drawings, Specifications, other documents, or copies thereof on extensions of the Project or any other project without written consent of Owner and Engineer and specific written verification or adaptation by Engineer.
- B. The prohibitions of this Paragraph 3.05 will survive final payment, or termination of the Contract. Nothing herein shall preclude Contractor from retaining copies of the Contract Documents for record purposes.

3.06 *Electronic Data*

- A. Unless otherwise stated in the Supplementary Conditions, the data furnished by Owner or Engineer to Contractor, or by Contractor to Owner or Engineer, that may be relied upon are limited to the printed copies (also known as hard copies). Files in electronic media format of text, data, graphics, or other types are furnished only for the convenience of the receiving party. Any conclusion or information obtained or derived from such electronic files will be at the user's sole risk. If there is a discrepancy between the electronic files and the hard copies, the hard copies govern.
- B. Because data stored in electronic media format can deteriorate or be modified inadvertently or otherwise without authorization of the data's creator, the party receiving electronic files agrees that it will perform acceptance tests or procedures within 60 days, after which the receiving party shall be deemed to have accepted the data thus transferred. Any errors detected within the 60-day acceptance period will be corrected by the transferring party.
- C. When transferring documents in electronic media format, the transferring party makes no representations as to long term compatibility, usability, or readability of documents resulting from the use of software application packages, operating systems, or computer hardware differing from those used by the data's creator.

ARTICLE 4 – AVAILABILITY OF LANDS; SUBSURFACE AND PHYSICAL CONDITIONS; HAZARDOUS ENVIRONMENTAL CONDITIONS; REFERENCE POINTS

4.01 *Availability of Lands*

- A. Owner shall furnish the Site. Owner shall notify Contractor of any encumbrances or restrictions not of general application but specifically related to use of the Site with which Contractor must comply in performing the Work. Owner will obtain in a timely manner and pay for easements for permanent structures or permanent changes in existing facilities. If Contractor and Owner are unable to agree on entitlement to or on the amount or extent, if any, of any adjustment in the Contract Price or Contract Times, or both, as a result of any delay in Owner's furnishing the Site or a part thereof, Contractor may make a Claim therefor as provided in Paragraph 10.05.
- B. Upon reasonable written request, Owner shall furnish Contractor with a current statement of record legal title and legal description of the lands upon which the Work is to be performed and Owner's interest therein as necessary for giving notice of or filing a mechanic's or construction lien against such lands in accordance with applicable Laws and Regulations.
- C. Contractor shall provide for all additional lands and access thereto that may be required for temporary construction facilities or storage of materials and equipment.

4.02 *Subsurface and Physical Conditions*

- A. *Reports and Drawings:* The Supplementary Conditions identify:
 - 1. those reports known to Owner of explorations and tests of subsurface conditions at or contiguous to the Site; and
 - 2. those drawings known to Owner of physical conditions relating to existing surface or subsurface structures at the Site (except Underground Facilities).
- B. *Limited Reliance by Contractor on Technical Data Authorized:* Contractor may rely upon the accuracy of the "technical data" contained in such reports and drawings, but such reports and drawings are not Contract Documents. Such "technical data" is identified in the Supplementary Conditions. Except for such reliance on such "technical data," Contractor may not rely upon or make any claim against Owner or Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors with respect to:
 - 1. the completeness of such reports and drawings for Contractor's purposes, including, but not limited to, any aspects of the means, methods, techniques, sequences, and procedures of construction to be employed by Contractor, and safety precautions and programs incident thereto; or
 - 2. other data, interpretations, opinions, and information contained in such reports or shown or indicated in such drawings; or
 - 3. any Contractor interpretation of or conclusion drawn from any "technical data" or any such other data, interpretations, opinions, or information.

4.03 *Differing Subsurface or Physical Conditions*

- A. *Notice:* If Contractor believes that any subsurface or physical condition that is uncovered or revealed either:
1. is of such a nature as to establish that any “technical data” on which Contractor is entitled to rely as provided in Paragraph 4.02 is materially inaccurate; or
 2. is of such a nature as to require a change in the Contract Documents; or
 3. differs materially from that shown or indicated in the Contract Documents; or
 4. is of an unusual nature, and differs materially from conditions ordinarily encountered and generally recognized as inherent in work of the character provided for in the Contract Documents;

then Contractor shall, promptly after becoming aware thereof and before further disturbing the subsurface or physical conditions or performing any Work in connection therewith (except in an emergency as required by Paragraph 6.16.A), notify Owner and Engineer in writing about such condition. Contractor shall not further disturb such condition or perform any Work in connection therewith (except as aforesaid) until receipt of written order to do so.

- B. *Engineer’s Review:* After receipt of written notice as required by Paragraph 4.03.A, Engineer will promptly review the pertinent condition, determine the necessity of Owner’s obtaining additional exploration or tests with respect thereto, and advise Owner in writing (with a copy to Contractor) of Engineer’s findings and conclusions.

C. *Possible Price and Times Adjustments:*

1. The Contract Price or the Contract Times, or both, will be equitably adjusted to the extent that the existence of such differing subsurface or physical condition causes an increase or decrease in Contractor’s cost of, or time required for, performance of the Work; subject, however, to the following:
 - a. such condition must meet any one or more of the categories described in Paragraph 4.03.A; and
 - b. with respect to Work that is paid for on a unit price basis, any adjustment in Contract Price will be subject to the provisions of Paragraphs 9.07 and 11.03.
2. Contractor shall not be entitled to any adjustment in the Contract Price or Contract Times if:
 - a. Contractor knew of the existence of such conditions at the time Contractor made a final commitment to Owner with respect to Contract Price and Contract Times by the submission of a Bid or becoming bound under a negotiated contract; or
 - b. the existence of such condition could reasonably have been discovered or revealed as a result of any examination, investigation, exploration, test, or study of the Site and

contiguous areas required by the Bidding Requirements or Contract Documents to be conducted by or for Contractor prior to Contractor's making such final commitment; or

- c. Contractor failed to give the written notice as required by Paragraph 4.03.A.
3. If Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any adjustment in the Contract Price or Contract Times, or both, a Claim may be made therefor as provided in Paragraph 10.05. However, neither Owner or Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors shall be liable to Contractor for any claims, costs, losses, or damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) sustained by Contractor on or in connection with any other project or anticipated project.

4.04 *Underground Facilities*

A. *Shown or Indicated:* The information and data shown or indicated in the Contract Documents with respect to existing Underground Facilities at or contiguous to the Site is based on information and data furnished to Owner or Engineer by the owners of such Underground Facilities, including Owner, or by others. Unless it is otherwise expressly provided in the Supplementary Conditions:

1. Owner and Engineer shall not be responsible for the accuracy or completeness of any such information or data provided by others; and
2. the cost of all of the following will be included in the Contract Price, and Contractor shall have full responsibility for:
 - a. reviewing and checking all such information and data;
 - b. locating all Underground Facilities shown or indicated in the Contract Documents;
 - c. coordination of the Work with the owners of such Underground Facilities, including Owner, during construction; and
 - d. the safety and protection of all such Underground Facilities and repairing any damage thereto resulting from the Work.

B. *Not Shown or Indicated:*

1. If an Underground Facility is uncovered or revealed at or contiguous to the Site which was not shown or indicated, or not shown or indicated with reasonable accuracy in the Contract Documents, Contractor shall, promptly after becoming aware thereof and before further disturbing conditions affected thereby or performing any Work in connection therewith (except in an emergency as required by Paragraph 6.16.A), identify the owner of such Underground Facility and give written notice to that owner and to Owner and Engineer. Engineer will promptly review the Underground Facility and determine the extent, if any, to which a change is required in the Contract Documents to reflect and document the

consequences of the existence or location of the Underground Facility. During such time, Contractor shall be responsible for the safety and protection of such Underground Facility.

2. If Engineer concludes that a change in the Contract Documents is required, a Work Change Directive or a Change Order will be issued to reflect and document such consequences. An equitable adjustment shall be made in the Contract Price or Contract Times, or both, to the extent that they are attributable to the existence or location of any Underground Facility that was not shown or indicated or not shown or indicated with reasonable accuracy in the Contract Documents and that Contractor did not know of and could not reasonably have been expected to be aware of or to have anticipated. If Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any such adjustment in Contract Price or Contract Times, Owner or Contractor may make a Claim therefor as provided in Paragraph 10.05.

4.05 *Reference Points*

- A. Owner shall provide engineering surveys to establish reference points for construction which in Engineer's judgment are necessary to enable Contractor to proceed with the Work. Contractor shall be responsible for laying out the Work, shall protect and preserve the established reference points and property monuments, and shall make no changes or relocations without the prior written approval of Owner. Contractor shall report to Engineer whenever any reference point or property monument is lost or destroyed or requires relocation because of necessary changes in grades or locations, and shall be responsible for the accurate replacement or relocation of such reference points or property monuments by professionally qualified personnel.

4.06 *Hazardous Environmental Condition at Site*

- A. *Reports and Drawings:* The Supplementary Conditions identify those reports and drawings known to Owner relating to Hazardous Environmental Conditions that have been identified at the Site.
- B. *Limited Reliance by Contractor on Technical Data Authorized:* Contractor may rely upon the accuracy of the "technical data" contained in such reports and drawings, but such reports and drawings are not Contract Documents. Such "technical data" is identified in the Supplementary Conditions. Except for such reliance on such "technical data," Contractor may not rely upon or make any claim against Owner or Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors with respect to:
 1. the completeness of such reports and drawings for Contractor's purposes, including, but not limited to, any aspects of the means, methods, techniques, sequences and procedures of construction to be employed by Contractor and safety precautions and programs incident thereto; or
 2. other data, interpretations, opinions and information contained in such reports or shown or indicated in such drawings; or
 3. any Contractor interpretation of or conclusion drawn from any "technical data" or any such other data, interpretations, opinions or information.

- C. Contractor shall not be responsible for any Hazardous Environmental Condition uncovered or revealed at the Site which was not shown or indicated in Drawings or Specifications or identified in the Contract Documents to be within the scope of the Work. Contractor shall be responsible for a Hazardous Environmental Condition created with any materials brought to the Site by Contractor, Subcontractors, Suppliers, or anyone else for whom Contractor is responsible.
- D. If Contractor encounters a Hazardous Environmental Condition or if Contractor or anyone for whom Contractor is responsible creates a Hazardous Environmental Condition, Contractor shall immediately: (i) secure or otherwise isolate such condition; (ii) stop all Work in connection with such condition and in any area affected thereby (except in an emergency as required by Paragraph 6.16.A); and (iii) notify Owner and Engineer (and promptly thereafter confirm such notice in writing). Owner shall promptly consult with Engineer concerning the necessity for Owner to retain a qualified expert to evaluate such condition or take corrective action, if any. Promptly after consulting with Engineer, Owner shall take such actions as are necessary to permit Owner to timely obtain required permits and provide Contractor the written notice required by Paragraph 4.06.E.
- E. Contractor shall not be required to resume Work in connection with such condition or in any affected area until after Owner has obtained any required permits related thereto and delivered written notice to Contractor: (i) specifying that such condition and any affected area is or has been rendered safe for the resumption of Work; or (ii) specifying any special conditions under which such Work may be resumed safely. If Owner and Contractor cannot agree as to entitlement to or on the amount or extent, if any, of any adjustment in Contract Price or Contract Times, or both, as a result of such Work stoppage or such special conditions under which Work is agreed to be resumed by Contractor, either party may make a Claim therefor as provided in Paragraph 10.05.
- F. If after receipt of such written notice Contractor does not agree to resume such Work based on a reasonable belief it is unsafe, or does not agree to resume such Work under such special conditions, then Owner may order the portion of the Work that is in the area affected by such condition to be deleted from the Work. If Owner and Contractor cannot agree as to entitlement to or on the amount or extent, if any, of an adjustment in Contract Price or Contract Times as a result of deleting such portion of the Work, then either party may make a Claim therefor as provided in Paragraph 10.05. Owner may have such deleted portion of the Work performed by Owner's own forces or others in accordance with Article 7.
- G. To the fullest extent permitted by Laws and Regulations, Owner shall indemnify and hold harmless Contractor, Subcontractors, and Engineer, and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to a Hazardous Environmental Condition, provided that such Hazardous Environmental Condition: (i) was not shown or indicated in the Drawings or Specifications or identified in the Contract Documents to be included within the scope of the Work, and (ii) was not created by Contractor or by anyone for whom Contractor is responsible. Nothing in this Paragraph 4.06.G shall obligate Owner to indemnify any individual or entity from and against the consequences of that individual's or entity's own negligence.

- H. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to a Hazardous Environmental Condition created by Contractor or by anyone for whom Contractor is responsible. Nothing in this Paragraph 4.06.H shall obligate Contractor to indemnify any individual or entity from and against the consequences of that individual's or entity's own negligence.
- I. The provisions of Paragraphs 4.02, 4.03, and 4.04 do not apply to a Hazardous Environmental Condition uncovered or revealed at the Site.

ARTICLE 5 – BONDS AND INSURANCE

5.01 Performance, Payment, and Other Bonds

- A. Contractor shall furnish performance and payment bonds, each in an amount at least equal to the Contract Price as security for the faithful performance and payment of all of Contractor's obligations under the Contract Documents. These bonds shall remain in effect until one year after the date when final payment becomes due or until completion of the correction period specified in Paragraph 13.07, whichever is later, except as provided otherwise by Laws or Regulations or by the Contract Documents. Contractor shall also furnish such other bonds as are required by the Contract Documents.
- B. All bonds shall be in the form prescribed by the Contract Documents except as provided otherwise by Laws or Regulations, and shall be executed by such sureties as are named in the list of "Companies Holding Certificates of Authority as Acceptable Sureties on Federal Bonds and as Acceptable Reinsuring Companies" as published in Circular 570 (amended) by the Financial Management Service, Surety Bond Branch, U.S. Department of the Treasury. All bonds signed by an agent or attorney-in-fact must be accompanied by a certified copy of that individual's authority to bind the surety. The evidence of authority shall show that it is effective on the date the agent or attorney-in-fact signed each bond.
- C. If the surety on any bond furnished by Contractor is declared bankrupt or becomes insolvent or its right to do business is terminated in any state where any part of the Project is located or it ceases to meet the requirements of Paragraph 5.01.B, Contractor shall promptly notify Owner and Engineer and shall, within 20 days after the event giving rise to such notification, provide another bond and surety, both of which shall comply with the requirements of Paragraphs 5.01.B and 5.02.

5.02 Licensed Sureties and Insurers

- A. All bonds and insurance required by the Contract Documents to be purchased and maintained by Owner or Contractor shall be obtained from surety or insurance companies that are duly licensed or authorized in the jurisdiction in which the Project is located to issue bonds or insurance policies for the limits and coverages so required. Such surety and insurance companies shall also

meet such additional requirements and qualifications as may be provided in the Supplementary Conditions.

5.03 *Certificates of Insurance*

- A. Contractor shall deliver to Owner, with copies to each additional insured and loss payee identified in the Supplementary Conditions, certificates of insurance (and other evidence of insurance requested by Owner or any other additional insured) which Contractor is required to purchase and maintain.
- B. Owner shall deliver to Contractor, with copies to each additional insured and loss payee identified in the Supplementary Conditions, certificates of insurance (and other evidence of insurance requested by Contractor or any other additional insured) which Owner is required to purchase and maintain.
- C. Failure of Owner to demand such certificates or other evidence of Contractor's full compliance with these insurance requirements or failure of Owner to identify a deficiency in compliance from the evidence provided shall not be construed as a waiver of Contractor's obligation to maintain such insurance.
- D. Owner does not represent that insurance coverage and limits established in this Contract necessarily will be adequate to protect Contractor.
- E. The insurance and insurance limits required herein shall not be deemed as a limitation on Contractor's liability under the indemnities granted to Owner in the Contract Documents.

5.04 *Contractor's Insurance*

- A. Contractor shall purchase and maintain such insurance as is appropriate for the Work being performed and as will provide protection from claims set forth below which may arise out of or result from Contractor's performance of the Work and Contractor's other obligations under the Contract Documents, whether it is to be performed by Contractor, any Subcontractor or Supplier, or by anyone directly or indirectly employed by any of them to perform any of the Work, or by anyone for whose acts any of them may be liable:
 - 1. claims under workers' compensation, disability benefits, and other similar employee benefit acts;
 - 2. claims for damages because of bodily injury, occupational sickness or disease, or death of Contractor's employees;
 - 3. claims for damages because of bodily injury, sickness or disease, or death of any person other than Contractor's employees;
 - 4. claims for damages insured by reasonably available personal injury liability coverage which are sustained:

- a. by any person as a result of an offense directly or indirectly related to the employment of such person by Contractor, or
 - b. by any other person for any other reason;
5. claims for damages, other than to the Work itself, because of injury to or destruction of tangible property wherever located, including loss of use resulting therefrom; and
 6. claims for damages because of bodily injury or death of any person or property damage arising out of the ownership, maintenance or use of any motor vehicle.
- B. The policies of insurance required by this Paragraph 5.04 shall:
1. with respect to insurance required by Paragraphs 5.04.A.3 through 5.04.A.6 inclusive, be written on an occurrence basis, include as additional insureds (subject to any customary exclusion regarding professional liability) Owner and Engineer, and any other individuals or entities identified in the Supplementary Conditions, all of whom shall be listed as additional insureds, and include coverage for the respective officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of all such additional insureds, and the insurance afforded to these additional insureds shall provide primary coverage for all claims covered thereby;
 2. include at least the specific coverages and be written for not less than the limits of liability provided in the Supplementary Conditions or required by Laws or Regulations, whichever is greater;
 3. include contractual liability insurance covering Contractor's indemnity obligations under Paragraphs 6.11 and 6.20;
 4. contain a provision or endorsement that the coverage afforded will not be canceled, materially changed or renewal refused until at least 30 days prior written notice has been given to Owner and Contractor and to each other additional insured identified in the Supplementary Conditions to whom a certificate of insurance has been issued (and the certificates of insurance furnished by the Contractor pursuant to Paragraph 5.03 will so provide);
 5. remain in effect at least until final payment and at all times thereafter when Contractor may be correcting, removing, or replacing defective Work in accordance with Paragraph 13.07; and
 6. include completed operations coverage:
 - a. Such insurance shall remain in effect for two years after final payment.
 - b. Contractor shall furnish Owner and each other additional insured identified in the Supplementary Conditions, to whom a certificate of insurance has been issued, evidence satisfactory to Owner and any such additional insured of continuation of such insurance at final payment and one year thereafter.

5.05 *Owner's Liability Insurance*

- A. In addition to the insurance required to be provided by Contractor under Paragraph 5.04, Owner, at Owner's option, may purchase and maintain at Owner's expense Owner's own liability insurance as will protect Owner against claims which may arise from operations under the Contract Documents.

5.06 *Property Insurance*

- A. Unless otherwise provided in the Supplementary Conditions, Owner shall purchase and maintain property insurance upon the Work at the Site in the amount of the full replacement cost thereof (subject to such deductible amounts as may be provided in the Supplementary Conditions or required by Laws and Regulations). This insurance shall:
1. include the interests of Owner, Contractor, Subcontractors, and Engineer, and any other individuals or entities identified in the Supplementary Conditions, and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them, each of whom is deemed to have an insurable interest and shall be listed as a loss payee;
 2. be written on a Builder's Risk "all-risk" policy form that shall at least include insurance for physical loss or damage to the Work, temporary buildings, falsework, and materials and equipment in transit, and shall insure against at least the following perils or causes of loss: fire, lightning, extended coverage, theft, vandalism and malicious mischief, earthquake, collapse, debris removal, demolition occasioned by enforcement of Laws and Regulations, water damage (other than that caused by flood), and such other perils or causes of loss as may be specifically required by the Supplementary Conditions.
 3. include expenses incurred in the repair or replacement of any insured property (including but not limited to fees and charges of engineers and architects);
 4. cover materials and equipment stored at the Site or at another location that was agreed to in writing by Owner prior to being incorporated in the Work, provided that such materials and equipment have been included in an Application for Payment recommended by Engineer;
 5. allow for partial utilization of the Work by Owner;
 6. include testing and startup; and
 7. be maintained in effect until final payment is made unless otherwise agreed to in writing by Owner, Contractor, and Engineer with 30 days written notice to each other loss payee to whom a certificate of insurance has been issued.
- B. Owner shall purchase and maintain such equipment breakdown insurance or additional property insurance as may be required by the Supplementary Conditions or Laws and Regulations which will include the interests of Owner, Contractor, Subcontractors, and Engineer, and any other individuals or entities identified in the Supplementary Conditions, and the officers, directors,

members, partners, employees, agents, consultants and subcontractors of each and any of them, each of whom is deemed to have an insurable interest and shall be listed as a loss payee.

- C. All the policies of insurance (and the certificates or other evidence thereof) required to be purchased and maintained in accordance with this Paragraph 5.06 will contain a provision or endorsement that the coverage afforded will not be canceled or materially changed or renewal refused until at least 30 days prior written notice has been given to Owner and Contractor and to each other loss payee to whom a certificate of insurance has been issued and will contain waiver provisions in accordance with Paragraph 5.07.
- D. Owner shall not be responsible for purchasing and maintaining any property insurance specified in this Paragraph 5.06 to protect the interests of Contractor, Subcontractors, or others in the Work to the extent of any deductible amounts that are identified in the Supplementary Conditions. The risk of loss within such identified deductible amount will be borne by Contractor, Subcontractors, or others suffering any such loss, and if any of them wishes property insurance coverage within the limits of such amounts, each may purchase and maintain it at the purchaser's own expense.
- E. If Contractor requests in writing that other special insurance be included in the property insurance policies provided under this Paragraph 5.06, Owner shall, if possible, include such insurance, and the cost thereof will be charged to Contractor by appropriate Change Order. Prior to commencement of the Work at the Site, Owner shall in writing advise Contractor whether or not such other insurance has been procured by Owner.

5.07 *Waiver of Rights*

- A. Owner and Contractor intend that all policies purchased in accordance with Paragraph 5.06 will protect Owner, Contractor, Subcontractors, and Engineer, and all other individuals or entities identified in the Supplementary Conditions as loss payees (and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them) in such policies and will provide primary coverage for all losses and damages caused by the perils or causes of loss covered thereby. All such policies shall contain provisions to the effect that in the event of payment of any loss or damage the insurers will have no rights of recovery against any of the insureds or loss payees thereunder. Owner and Contractor waive all rights against each other and their respective officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them for all losses and damages caused by, arising out of or resulting from any of the perils or causes of loss covered by such policies and any other property insurance applicable to the Work; and, in addition, waive all such rights against Subcontractors and Engineer, and all other individuals or entities identified in the Supplementary Conditions as loss payees (and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them) under such policies for losses and damages so caused. None of the above waivers shall extend to the rights that any party making such waiver may have to the proceeds of insurance held by Owner as trustee or otherwise payable under any policy so issued.
- B. Owner waives all rights against Contractor, Subcontractors, and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them for:

1. loss due to business interruption, loss of use, or other consequential loss extending beyond direct physical loss or damage to Owner's property or the Work caused by, arising out of, or resulting from fire or other perils whether or not insured by Owner; and
 2. loss or damage to the completed Project or part thereof caused by, arising out of, or resulting from fire or other insured peril or cause of loss covered by any property insurance maintained on the completed Project or part thereof by Owner during partial utilization pursuant to Paragraph 14.05, after Substantial Completion pursuant to Paragraph 14.04, or after final payment pursuant to Paragraph 14.07.
- C. Any insurance policy maintained by Owner covering any loss, damage or consequential loss referred to in Paragraph 5.07.B shall contain provisions to the effect that in the event of payment of any such loss, damage, or consequential loss, the insurers will have no rights of recovery against Contractor, Subcontractors, or Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them.

5.08 *Receipt and Application of Insurance Proceeds*

- A. Any insured loss under the policies of insurance required by Paragraph 5.06 will be adjusted with Owner and made payable to Owner as fiduciary for the loss payees, as their interests may appear, subject to the requirements of any applicable mortgage clause and of Paragraph 5.08.B. Owner shall deposit in a separate account any money so received and shall distribute it in accordance with such agreement as the parties in interest may reach. If no other special agreement is reached, the damaged Work shall be repaired or replaced, the moneys so received applied on account thereof, and the Work and the cost thereof covered by an appropriate Change Order.
- B. Owner as fiduciary shall have power to adjust and settle any loss with the insurers unless one of the parties in interest shall object in writing within 15 days after the occurrence of loss to Owner's exercise of this power. If such objection be made, Owner as fiduciary shall make settlement with the insurers in accordance with such agreement as the parties in interest may reach. If no such agreement among the parties in interest is reached, Owner as fiduciary shall adjust and settle the loss with the insurers and, if required in writing by any party in interest, Owner as fiduciary shall give bond for the proper performance of such duties.

5.09 *Acceptance of Bonds and Insurance; Option to Replace*

- A. If either Owner or Contractor has any objection to the coverage afforded by or other provisions of the bonds or insurance required to be purchased and maintained by the other party in accordance with Article 5 on the basis of non-conformance with the Contract Documents, the objecting party shall so notify the other party in writing within 10 days after receipt of the certificates (or other evidence requested) required by Paragraph 2.01.B. Owner and Contractor shall each provide to the other such additional information in respect of insurance provided as the other may reasonably request. If either party does not purchase or maintain all of the bonds and insurance required of such party by the Contract Documents, such party shall notify the other party in writing of such failure to purchase prior to the start of the Work, or of such failure to maintain prior to any change in the required coverage. Without prejudice to any other right or remedy, the other party may elect to obtain equivalent bonds or insurance to protect such other party's

interests at the expense of the party who was required to provide such coverage, and a Change Order shall be issued to adjust the Contract Price accordingly.

5.10 *Partial Utilization, Acknowledgment of Property Insurer*

- A. If Owner finds it necessary to occupy or use a portion or portions of the Work prior to Substantial Completion of all the Work as provided in Paragraph 14.05, no such use or occupancy shall commence before the insurers providing the property insurance pursuant to Paragraph 5.06 have acknowledged notice thereof and in writing effected any changes in coverage necessitated thereby. The insurers providing the property insurance shall consent by endorsement on the policy or policies, but the property insurance shall not be canceled or permitted to lapse on account of any such partial use or occupancy.

ARTICLE 6 – CONTRACTOR’S RESPONSIBILITIES

6.01 *Supervision and Superintendence*

- A. Contractor shall supervise, inspect, and direct the Work competently and efficiently, devoting such attention thereto and applying such skills and expertise as may be necessary to perform the Work in accordance with the Contract Documents. Contractor shall be solely responsible for the means, methods, techniques, sequences, and procedures of construction. Contractor shall not be responsible for the negligence of Owner or Engineer in the design or specification of a specific means, method, technique, sequence, or procedure of construction which is shown or indicated in and expressly required by the Contract Documents.
- B. At all times during the progress of the Work, Contractor shall assign a competent resident superintendent who shall not be replaced without written notice to Owner and Engineer except under extraordinary circumstances.

6.02 *Labor; Working Hours*

- A. Contractor shall provide competent, suitably qualified personnel to survey and lay out the Work and perform construction as required by the Contract Documents. Contractor shall at all times maintain good discipline and order at the Site.
- B. Except as otherwise required for the safety or protection of persons or the Work or property at the Site or adjacent thereto, and except as otherwise stated in the Contract Documents, all Work at the Site shall be performed during regular working hours. Contractor will not permit the performance of Work on a Saturday, Sunday, or any legal holiday without Owner’s written consent (which will not be unreasonably withheld) given after prior written notice to Engineer.

6.03 *Services, Materials, and Equipment*

- A. Unless otherwise specified in the Contract Documents, Contractor shall provide and assume full responsibility for all services, materials, equipment, labor, transportation, construction equipment and machinery, tools, appliances, fuel, power, light, heat, telephone, water, sanitary facilities, temporary facilities, and all other facilities and incidentals necessary for the performance, testing, start-up, and completion of the Work.

- B. All materials and equipment incorporated into the Work shall be as specified or, if not specified, shall be of good quality and new, except as otherwise provided in the Contract Documents. All special warranties and guarantees required by the Specifications shall expressly run to the benefit of Owner. If required by Engineer, Contractor shall furnish satisfactory evidence (including reports of required tests) as to the source, kind, and quality of materials and equipment.
- C. All materials and equipment shall be stored, applied, installed, connected, erected, protected, used, cleaned, and conditioned in accordance with instructions of the applicable Supplier, except as otherwise may be provided in the Contract Documents.

6.04 *Progress Schedule*

- A. Contractor shall adhere to the Progress Schedule established in accordance with Paragraph 2.07 as it may be adjusted from time to time as provided below.
 - 1. Contractor shall submit to Engineer for acceptance (to the extent indicated in Paragraph 2.07) proposed adjustments in the Progress Schedule that will not result in changing the Contract Times. Such adjustments will comply with any provisions of the General Requirements applicable thereto.
 - 2. Proposed adjustments in the Progress Schedule that will change the Contract Times shall be submitted in accordance with the requirements of Article 12. Adjustments in Contract Times may only be made by a Change Order.

6.05 *Substitutes and "Or-Equals"*

- A. Whenever an item of material or equipment is specified or described in the Contract Documents by using the name of a proprietary item or the name of a particular Supplier, the specification or description is intended to establish the type, function, appearance, and quality required. Unless the specification or description contains or is followed by words reading that no like, equivalent, or "or-equal" item or no substitution is permitted, other items of material or equipment or material or equipment of other Suppliers may be submitted to Engineer for review under the circumstances described below.
 - 1. "*Or-Equal*" Items: If in Engineer's sole discretion an item of material or equipment proposed by Contractor is functionally equal to that named and sufficiently similar so that no change in related Work will be required, it may be considered by Engineer as an "or-equal" item, in which case review and approval of the proposed item may, in Engineer's sole discretion, be accomplished without compliance with some or all of the requirements for approval of proposed substitute items. For the purposes of this Paragraph 6.05.A.1, a proposed item of material or equipment will be considered functionally equal to an item so named if:
 - a. in the exercise of reasonable judgment Engineer determines that:
 - 1) it is at least equal in materials of construction, quality, durability, appearance, strength, and design characteristics;

- 2) it will reliably perform at least equally well the function and achieve the results imposed by the design concept of the completed Project as a functioning whole; and
 - 3) it has a proven record of performance and availability of responsive service.
- b. Contractor certifies that, if approved and incorporated into the Work:
- 1) there will be no increase in cost to the Owner or increase in Contract Times; and
 - 2) it will conform substantially to the detailed requirements of the item named in the Contract Documents.

2. *Substitute Items:*

- a. If in Engineer's sole discretion an item of material or equipment proposed by Contractor does not qualify as an "or-equal" item under Paragraph 6.05.A.1, it will be considered a proposed substitute item.
- b. Contractor shall submit sufficient information as provided below to allow Engineer to determine if the item of material or equipment proposed is essentially equivalent to that named and an acceptable substitute therefor. Requests for review of proposed substitute items of material or equipment will not be accepted by Engineer from anyone other than Contractor.
- c. The requirements for review by Engineer will be as set forth in Paragraph 6.05.A.2.d, as supplemented by the General Requirements, and as Engineer may decide is appropriate under the circumstances.
- d. Contractor shall make written application to Engineer for review of a proposed substitute item of material or equipment that Contractor seeks to furnish or use. The application:
 - 1) shall certify that the proposed substitute item will:
 - a) perform adequately the functions and achieve the results called for by the general design,
 - b) be similar in substance to that specified, and
 - c) be suited to the same use as that specified;
 - 2) will state:
 - a) the extent, if any, to which the use of the proposed substitute item will prejudice Contractor's achievement of Substantial Completion on time,
 - b) whether use of the proposed substitute item in the Work will require a change in any of the Contract Documents (or in the provisions of any other direct contract with Owner for other work on the Project) to adapt the design to the proposed substitute item, and

- c) whether incorporation or use of the proposed substitute item in connection with the Work is subject to payment of any license fee or royalty;
 - 3) will identify:
 - a) all variations of the proposed substitute item from that specified, and
 - b) available engineering, sales, maintenance, repair, and replacement services; and
 - 4) shall contain an itemized estimate of all costs or credits that will result directly or indirectly from use of such substitute item, including costs of redesign and claims of other contractors affected by any resulting change.
- B. *Substitute Construction Methods or Procedures:* If a specific means, method, technique, sequence, or procedure of construction is expressly required by the Contract Documents, Contractor may furnish or utilize a substitute means, method, technique, sequence, or procedure of construction approved by Engineer. Contractor shall submit sufficient information to allow Engineer, in Engineer's sole discretion, to determine that the substitute proposed is equivalent to that expressly called for by the Contract Documents. The requirements for review by Engineer will be similar to those provided in Paragraph 6.05.A.2.
- C. *Engineer's Evaluation:* Engineer will be allowed a reasonable time within which to evaluate each proposal or submittal made pursuant to Paragraphs 6.05.A and 6.05.B. Engineer may require Contractor to furnish additional data about the proposed substitute item. Engineer will be the sole judge of acceptability. No "or equal" or substitute will be ordered, installed or utilized until Engineer's review is complete, which will be evidenced by a Change Order in the case of a substitute and an approved Shop Drawing for an "or equal." Engineer will advise Contractor in writing of any negative determination.
- D. *Special Guarantee:* Owner may require Contractor to furnish at Contractor's expense a special performance guarantee or other surety with respect to any substitute.
- E. *Engineer's Cost Reimbursement:* Engineer will record Engineer's costs in evaluating a substitute proposed or submitted by Contractor pursuant to Paragraphs 6.05.A.2 and 6.05.B. Whether or not Engineer approves a substitute so proposed or submitted by Contractor, Contractor shall reimburse Owner for the reasonable charges of Engineer for evaluating each such proposed substitute. Contractor shall also reimburse Owner for the reasonable charges of Engineer for making changes in the Contract Documents (or in the provisions of any other direct contract with Owner) resulting from the acceptance of each proposed substitute.
- F. *Contractor's Expense:* Contractor shall provide all data in support of any proposed substitute or "or-equal" at Contractor's expense.

6.06 *Concerning Subcontractors, Suppliers, and Others*

- A. Contractor shall not employ any Subcontractor, Supplier, or other individual or entity (including those acceptable to Owner as indicated in Paragraph 6.06.B), whether initially or as a replacement, against whom Owner may have reasonable objection. Contractor shall not be

required to employ any Subcontractor, Supplier, or other individual or entity to furnish or perform any of the Work against whom Contractor has reasonable objection.

- B. If the Supplementary Conditions require the identity of certain Subcontractors, Suppliers, or other individuals or entities to be submitted to Owner in advance for acceptance by Owner by a specified date prior to the Effective Date of the Agreement, and if Contractor has submitted a list thereof in accordance with the Supplementary Conditions, Owner's acceptance (either in writing or by failing to make written objection thereto by the date indicated for acceptance or objection in the Bidding Documents or the Contract Documents) of any such Subcontractor, Supplier, or other individual or entity so identified may be revoked on the basis of reasonable objection after due investigation. Contractor shall submit an acceptable replacement for the rejected Subcontractor, Supplier, or other individual or entity, and the Contract Price will be adjusted by the difference in the cost occasioned by such replacement, and an appropriate Change Order will be issued. No acceptance by Owner of any such Subcontractor, Supplier, or other individual or entity, whether initially or as a replacement, shall constitute a waiver of any right of Owner or Engineer to reject defective Work.
- C. Contractor shall be fully responsible to Owner and Engineer for all acts and omissions of the Subcontractors, Suppliers, and other individuals or entities performing or furnishing any of the Work just as Contractor is responsible for Contractor's own acts and omissions. Nothing in the Contract Documents:
1. shall create for the benefit of any such Subcontractor, Supplier, or other individual or entity any contractual relationship between Owner or Engineer and any such Subcontractor, Supplier or other individual or entity; nor
 2. shall create any obligation on the part of Owner or Engineer to pay or to see to the payment of any moneys due any such Subcontractor, Supplier, or other individual or entity except as may otherwise be required by Laws and Regulations.
- D. Contractor shall be solely responsible for scheduling and coordinating the Work of Subcontractors, Suppliers, and other individuals or entities performing or furnishing any of the Work under a direct or indirect contract with Contractor.
- E. Contractor shall require all Subcontractors, Suppliers, and such other individuals or entities performing or furnishing any of the Work to communicate with Engineer through Contractor.
- F. The divisions and sections of the Specifications and the identifications of any Drawings shall not control Contractor in dividing the Work among Subcontractors or Suppliers or delineating the Work to be performed by any specific trade.
- G. All Work performed for Contractor by a Subcontractor or Supplier will be pursuant to an appropriate agreement between Contractor and the Subcontractor or Supplier which specifically binds the Subcontractor or Supplier to the applicable terms and conditions of the Contract Documents for the benefit of Owner and Engineer. Whenever any such agreement is with a Subcontractor or Supplier who is listed as a loss payee on the property insurance provided in Paragraph 5.06, the agreement between the Contractor and the Subcontractor or Supplier will contain provisions whereby the Subcontractor or Supplier waives all rights against Owner,

Contractor, Engineer, and all other individuals or entities identified in the Supplementary Conditions to be listed as insureds or loss payees (and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them) for all losses and damages caused by, arising out of, relating to, or resulting from any of the perils or causes of loss covered by such policies and any other property insurance applicable to the Work. If the insurers on any such policies require separate waiver forms to be signed by any Subcontractor or Supplier, Contractor will obtain the same.

6.07 *Patent Fees and Royalties*

- A. Contractor shall pay all license fees and royalties and assume all costs incident to the use in the performance of the Work or the incorporation in the Work of any invention, design, process, product, or device which is the subject of patent rights or copyrights held by others. If a particular invention, design, process, product, or device is specified in the Contract Documents for use in the performance of the Work and if, to the actual knowledge of Owner or Engineer, its use is subject to patent rights or copyrights calling for the payment of any license fee or royalty to others, the existence of such rights shall be disclosed by Owner in the Contract Documents.
- B. To the fullest extent permitted by Laws and Regulations, Owner shall indemnify and hold harmless Contractor, and its officers, directors, members, partners, employees, agents, consultants, and subcontractors from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals, and all court or arbitration or other dispute resolution costs) arising out of or relating to any infringement of patent rights or copyrights incident to the use in the performance of the Work or resulting from the incorporation in the Work of any invention, design, process, product, or device specified in the Contract Documents, but not identified as being subject to payment of any license fee or royalty to others required by patent rights or copyrights.
- C. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to any infringement of patent rights or copyrights incident to the use in the performance of the Work or resulting from the incorporation in the Work of any invention, design, process, product, or device not specified in the Contract Documents.

6.08 *Permits*

- A. Unless otherwise provided in the Supplementary Conditions, Contractor shall obtain and pay for all construction permits and licenses. Owner shall assist Contractor, when necessary, in obtaining such permits and licenses. Contractor shall pay all governmental charges and inspection fees necessary for the prosecution of the Work which are applicable at the time of opening of Bids, or, if there are no Bids, on the Effective Date of the Agreement. Owner shall pay all charges of utility owners for connections for providing permanent service to the Work.

6.09 *Laws and Regulations*

- A. Contractor shall give all notices required by and shall comply with all Laws and Regulations applicable to the performance of the Work. Except where otherwise expressly required by applicable Laws and Regulations, neither Owner nor Engineer shall be responsible for monitoring Contractor's compliance with any Laws or Regulations.
- B. If Contractor performs any Work knowing or having reason to know that it is contrary to Laws or Regulations, Contractor shall bear all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such Work. However, it shall not be Contractor's responsibility to make certain that the Specifications and Drawings are in accordance with Laws and Regulations, but this shall not relieve Contractor of Contractor's obligations under Paragraph 3.03.
- C. Changes in Laws or Regulations not known at the time of opening of Bids (or, on the Effective Date of the Agreement if there were no Bids) having an effect on the cost or time of performance of the Work shall be the subject of an adjustment in Contract Price or Contract Times. If Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any such adjustment, a Claim may be made therefor as provided in Paragraph 10.05.

6.10 *Taxes*

- A. Contractor shall pay all sales, consumer, use, and other similar taxes required to be paid by Contractor in accordance with the Laws and Regulations of the place of the Project which are applicable during the performance of the Work.

6.11 *Use of Site and Other Areas*

A. *Limitation on Use of Site and Other Areas:*

1. Contractor shall confine construction equipment, the storage of materials and equipment, and the operations of workers to the Site and other areas permitted by Laws and Regulations, and shall not unreasonably encumber the Site and other areas with construction equipment or other materials or equipment. Contractor shall assume full responsibility for any damage to any such land or area, or to the owner or occupant thereof, or of any adjacent land or areas resulting from the performance of the Work.
2. Should any claim be made by any such owner or occupant because of the performance of the Work, Contractor shall promptly settle with such other party by negotiation or otherwise resolve the claim by arbitration or other dispute resolution proceeding or at law.
3. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to any claim or action, legal or equitable, brought

by any such owner or occupant against Owner, Engineer, or any other party indemnified hereunder to the extent caused by or based upon Contractor's performance of the Work.

- B. *Removal of Debris During Performance of the Work:* During the progress of the Work Contractor shall keep the Site and other areas free from accumulations of waste materials, rubbish, and other debris. Removal and disposal of such waste materials, rubbish, and other debris shall conform to applicable Laws and Regulations.
- C. *Cleaning:* Prior to Substantial Completion of the Work Contractor shall clean the Site and the Work and make it ready for utilization by Owner. At the completion of the Work Contractor shall remove from the Site all tools, appliances, construction equipment and machinery, and surplus materials and shall restore to original condition all property not designated for alteration by the Contract Documents.
- D. *Loading Structures:* Contractor shall not load nor permit any part of any structure to be loaded in any manner that will endanger the structure, nor shall Contractor subject any part of the Work or adjacent property to stresses or pressures that will endanger it.

6.12 *Record Documents*

- A. Contractor shall maintain in a safe place at the Site one record copy of all Drawings, Specifications, Addenda, Change Orders, Work Change Directives, Field Orders, and written interpretations and clarifications in good order and annotated to show changes made during construction. These record documents together with all approved Samples and a counterpart of all approved Shop Drawings will be available to Engineer for reference. Upon completion of the Work, these record documents, Samples, and Shop Drawings will be delivered to Engineer for Owner.

6.13 *Safety and Protection*

- A. Contractor shall be solely responsible for initiating, maintaining and supervising all safety precautions and programs in connection with the Work. Such responsibility does not relieve Subcontractors of their responsibility for the safety of persons or property in the performance of their work, nor for compliance with applicable safety Laws and Regulations. Contractor shall take all necessary precautions for the safety of, and shall provide the necessary protection to prevent damage, injury or loss to:
 - 1. all persons on the Site or who may be affected by the Work;
 - 2. all the Work and materials and equipment to be incorporated therein, whether in storage on or off the Site; and
 - 3. other property at the Site or adjacent thereto, including trees, shrubs, lawns, walks, pavements, roadways, structures, utilities, and Underground Facilities not designated for removal, relocation, or replacement in the course of construction.
- B. Contractor shall comply with all applicable Laws and Regulations relating to the safety of persons or property, or to the protection of persons or property from damage, injury, or loss; and

shall erect and maintain all necessary safeguards for such safety and protection. Contractor shall notify owners of adjacent property and of Underground Facilities and other utility owners when prosecution of the Work may affect them, and shall cooperate with them in the protection, removal, relocation, and replacement of their property.

- C. Contractor shall comply with the applicable requirements of Owner's safety programs, if any. The Supplementary Conditions identify any Owner's safety programs that are applicable to the Work.
- D. Contractor shall inform Owner and Engineer of the specific requirements of Contractor's safety program with which Owner's and Engineer's employees and representatives must comply while at the Site.
- E. All damage, injury, or loss to any property referred to in Paragraph 6.13.A.2 or 6.13.A.3 caused, directly or indirectly, in whole or in part, by Contractor, any Subcontractor, Supplier, or any other individual or entity directly or indirectly employed by any of them to perform any of the Work, or anyone for whose acts any of them may be liable, shall be remedied by Contractor (except damage or loss attributable to the fault of Drawings or Specifications or to the acts or omissions of Owner or Engineer or anyone employed by any of them, or anyone for whose acts any of them may be liable, and not attributable, directly or indirectly, in whole or in part, to the fault or negligence of Contractor or any Subcontractor, Supplier, or other individual or entity directly or indirectly employed by any of them).
- F. Contractor's duties and responsibilities for safety and for protection of the Work shall continue until such time as all the Work is completed and Engineer has issued a notice to Owner and Contractor in accordance with Paragraph 14.07.B that the Work is acceptable (except as otherwise expressly provided in connection with Substantial Completion).

6.14 *Safety Representative*

- A. Contractor shall designate a qualified and experienced safety representative at the Site whose duties and responsibilities shall be the prevention of accidents and the maintaining and supervising of safety precautions and programs.

6.15 *Hazard Communication Programs*

- A. Contractor shall be responsible for coordinating any exchange of material safety data sheets or other hazard communication information required to be made available to or exchanged between or among employers at the Site in accordance with Laws or Regulations.

6.16 *Emergencies*

- A. In emergencies affecting the safety or protection of persons or the Work or property at the Site or adjacent thereto, Contractor is obligated to act to prevent threatened damage, injury, or loss. Contractor shall give Engineer prompt written notice if Contractor believes that any significant changes in the Work or variations from the Contract Documents have been caused thereby or are required as a result thereof. If Engineer determines that a change in the Contract Documents is

required because of the action taken by Contractor in response to such an emergency, a Work Change Directive or Change Order will be issued.

6.17 *Shop Drawings and Samples*

A. Contractor shall submit Shop Drawings and Samples to Engineer for review and approval in accordance with the accepted Schedule of Submittals (as required by Paragraph 2.07). Each submittal will be identified as Engineer may require.

1. *Shop Drawings:*

- a. Submit number of copies specified in the General Requirements.
- b. Data shown on the Shop Drawings will be complete with respect to quantities, dimensions, specified performance and design criteria, materials, and similar data to show Engineer the services, materials, and equipment Contractor proposes to provide and to enable Engineer to review the information for the limited purposes required by Paragraph 6.17.D.

2. *Samples:*

- a. Submit number of Samples specified in the Specifications.
- b. Clearly identify each Sample as to material, Supplier, pertinent data such as catalog numbers, the use for which intended and other data as Engineer may require to enable Engineer to review the submittal for the limited purposes required by Paragraph 6.17.D.

B. Where a Shop Drawing or Sample is required by the Contract Documents or the Schedule of Submittals, any related Work performed prior to Engineer's review and approval of the pertinent submittal will be at the sole expense and responsibility of Contractor.

C. *Submittal Procedures:*

1. Before submitting each Shop Drawing or Sample, Contractor shall have:

- a. reviewed and coordinated each Shop Drawing or Sample with other Shop Drawings and Samples and with the requirements of the Work and the Contract Documents;
- b. determined and verified all field measurements, quantities, dimensions, specified performance and design criteria, installation requirements, materials, catalog numbers, and similar information with respect thereto;
- c. determined and verified the suitability of all materials offered with respect to the indicated application, fabrication, shipping, handling, storage, assembly, and installation pertaining to the performance of the Work; and
- d. determined and verified all information relative to Contractor's responsibilities for means, methods, techniques, sequences, and procedures of construction, and safety precautions and programs incident thereto.

2. Each submittal shall bear a stamp or specific written certification that Contractor has satisfied Contractor's obligations under the Contract Documents with respect to Contractor's review and approval of that submittal.
3. With each submittal, Contractor shall give Engineer specific written notice of any variations that the Shop Drawing or Sample may have from the requirements of the Contract Documents. This notice shall be both a written communication separate from the Shop Drawings or Sample submittal; and, in addition, by a specific notation made on each Shop Drawing or Sample submitted to Engineer for review and approval of each such variation.

D. *Engineer's Review:*

1. Engineer will provide timely review of Shop Drawings and Samples in accordance with the Schedule of Submittals acceptable to Engineer. Engineer's review and approval will be only to determine if the items covered by the submittals will, after installation or incorporation in the Work, conform to the information given in the Contract Documents and be compatible with the design concept of the completed Project as a functioning whole as indicated by the Contract Documents.
2. Engineer's review and approval will not extend to means, methods, techniques, sequences, or procedures of construction (except where a particular means, method, technique, sequence, or procedure of construction is specifically and expressly called for by the Contract Documents) or to safety precautions or programs incident thereto. The review and approval of a separate item as such will not indicate approval of the assembly in which the item functions.
3. Engineer's review and approval shall not relieve Contractor from responsibility for any variation from the requirements of the Contract Documents unless Contractor has complied with the requirements of Paragraph 6.17.C.3 and Engineer has given written approval of each such variation by specific written notation thereof incorporated in or accompanying the Shop Drawing or Sample. Engineer's review and approval shall not relieve Contractor from responsibility for complying with the requirements of Paragraph 6.17.C.1.

E. *Resubmittal Procedures:*

1. Contractor shall make corrections required by Engineer and shall return the required number of corrected copies of Shop Drawings and submit, as required, new Samples for review and approval. Contractor shall direct specific attention in writing to revisions other than the corrections called for by Engineer on previous submittals.

6.18 *Continuing the Work*

- A. Contractor shall carry on the Work and adhere to the Progress Schedule during all disputes or disagreements with Owner. No Work shall be delayed or postponed pending resolution of any disputes or disagreements, except as permitted by Paragraph 15.04 or as Owner and Contractor may otherwise agree in writing.

6.19 *Contractor's General Warranty and Guarantee*

- A. Contractor warrants and guarantees to Owner that all Work will be in accordance with the Contract Documents and will not be defective. Engineer and its officers, directors, members, partners, employees, agents, consultants, and subcontractors shall be entitled to rely on representation of Contractor's warranty and guarantee.
- B. Contractor's warranty and guarantee hereunder excludes defects or damage caused by:
 - 1. abuse, modification, or improper maintenance or operation by persons other than Contractor, Subcontractors, Suppliers, or any other individual or entity for whom Contractor is responsible; or
 - 2. normal wear and tear under normal usage.
- C. Contractor's obligation to perform and complete the Work in accordance with the Contract Documents shall be absolute. None of the following will constitute an acceptance of Work that is not in accordance with the Contract Documents or a release of Contractor's obligation to perform the Work in accordance with the Contract Documents:
 - 1. observations by Engineer;
 - 2. recommendation by Engineer or payment by Owner of any progress or final payment;
 - 3. the issuance of a certificate of Substantial Completion by Engineer or any payment related thereto by Owner;
 - 4. use or occupancy of the Work or any part thereof by Owner;
 - 5. any review and approval of a Shop Drawing or Sample submittal or the issuance of a notice of acceptability by Engineer;
 - 6. any inspection, test, or approval by others; or
 - 7. any correction of defective Work by Owner.

6.20 *Indemnification*

- A. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to the performance of the Work, provided that any such claim, cost, loss, or damage is attributable to bodily injury, sickness, disease, or death, or to injury to or destruction of tangible property (other than the Work itself), including the loss of use resulting therefrom but only to the extent caused by any negligent act or omission of Contractor, any Subcontractor, any Supplier, or any individual or entity directly or indirectly employed by any of them to perform any of the Work or anyone for whose acts any of them may be liable .

- B. In any and all claims against Owner or Engineer or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors by any employee (or the survivor or personal representative of such employee) of Contractor, any Subcontractor, any Supplier, or any individual or entity directly or indirectly employed by any of them to perform any of the Work, or anyone for whose acts any of them may be liable, the indemnification obligation under Paragraph 6.20.A shall not be limited in any way by any limitation on the amount or type of damages, compensation, or benefits payable by or for Contractor or any such Subcontractor, Supplier, or other individual or entity under workers' compensation acts, disability benefit acts, or other employee benefit acts.
- C. The indemnification obligations of Contractor under Paragraph 6.20.A shall not extend to the liability of Engineer and Engineer's officers, directors, members, partners, employees, agents, consultants and subcontractors arising out of:
 - 1. the preparation or approval of, or the failure to prepare or approve maps, Drawings, opinions, reports, surveys, Change Orders, designs, or Specifications; or
 - 2. giving directions or instructions, or failing to give them, if that is the primary cause of the injury or damage.

6.21 *Delegation of Professional Design Services*

- A. Contractor will not be required to provide professional design services unless such services are specifically required by the Contract Documents for a portion of the Work or unless such services are required to carry out Contractor's responsibilities for construction means, methods, techniques, sequences and procedures. Contractor shall not be required to provide professional services in violation of applicable law.
- B. If professional design services or certifications by a design professional related to systems, materials or equipment are specifically required of Contractor by the Contract Documents, Owner and Engineer will specify all performance and design criteria that such services must satisfy. Contractor shall cause such services or certifications to be provided by a properly licensed professional, whose signature and seal shall appear on all drawings, calculations, specifications, certifications, Shop Drawings and other submittals prepared by such professional. Shop Drawings and other submittals related to the Work designed or certified by such professional, if prepared by others, shall bear such professional's written approval when submitted to Engineer.
- C. Owner and Engineer shall be entitled to rely upon the adequacy, accuracy and completeness of the services, certifications or approvals performed by such design professionals, provided Owner and Engineer have specified to Contractor all performance and design criteria that such services must satisfy.
- D. Pursuant to this Paragraph 6.21, Engineer's review and approval of design calculations and design drawings will be only for the limited purpose of checking for conformance with performance and design criteria given and the design concept expressed in the Contract Documents. Engineer's review and approval of Shop Drawings and other submittals (except design calculations and design drawings) will be only for the purpose stated in Paragraph 6.17.D.1.

- E. Contractor shall not be responsible for the adequacy of the performance or design criteria required by the Contract Documents.

ARTICLE 7 – OTHER WORK AT THE SITE

7.01 Related Work at Site

- A. Owner may perform other work related to the Project at the Site with Owner's employees, or through other direct contracts therefor, or have other work performed by utility owners. If such other work is not noted in the Contract Documents, then:
 - 1. written notice thereof will be given to Contractor prior to starting any such other work; and
 - 2. if Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any adjustment in the Contract Price or Contract Times that should be allowed as a result of such other work, a Claim may be made therefor as provided in Paragraph 10.05.
- B. Contractor shall afford each other contractor who is a party to such a direct contract, each utility owner, and Owner, if Owner is performing other work with Owner's employees, proper and safe access to the Site, provide a reasonable opportunity for the introduction and storage of materials and equipment and the execution of such other work, and properly coordinate the Work with theirs. Contractor shall do all cutting, fitting, and patching of the Work that may be required to properly connect or otherwise make its several parts come together and properly integrate with such other work. Contractor shall not endanger any work of others by cutting, excavating, or otherwise altering such work; provided, however, that Contractor may cut or alter others' work with the written consent of Engineer and the others whose work will be affected. The duties and responsibilities of Contractor under this Paragraph are for the benefit of such utility owners and other contractors to the extent that there are comparable provisions for the benefit of Contractor in said direct contracts between Owner and such utility owners and other contractors.
- C. If the proper execution or results of any part of Contractor's Work depends upon work performed by others under this Article 7, Contractor shall inspect such other work and promptly report to Engineer in writing any delays, defects, or deficiencies in such other work that render it unavailable or unsuitable for the proper execution and results of Contractor's Work. Contractor's failure to so report will constitute an acceptance of such other work as fit and proper for integration with Contractor's Work except for latent defects and deficiencies in such other work.

7.02 Coordination

- A. If Owner intends to contract with others for the performance of other work on the Project at the Site, the following will be set forth in Supplementary Conditions:
 - 1. the individual or entity who will have authority and responsibility for coordination of the activities among the various contractors will be identified;
 - 2. the specific matters to be covered by such authority and responsibility will be itemized; and
 - 3. the extent of such authority and responsibilities will be provided.

- B. Unless otherwise provided in the Supplementary Conditions, Owner shall have sole authority and responsibility for such coordination.

7.03 *Legal Relationships*

- A. Paragraphs 7.01.A and 7.02 are not applicable for utilities not under the control of Owner.
- B. Each other direct contract of Owner under Paragraph 7.01.A shall provide that the other contractor is liable to Owner and Contractor for the reasonable direct delay and disruption costs incurred by Contractor as a result of the other contractor's wrongful actions or inactions.
- C. Contractor shall be liable to Owner and any other contractor under direct contract to Owner for the reasonable direct delay and disruption costs incurred by such other contractor as a result of Contractor's wrongful action or inactions.

ARTICLE 8 – OWNER'S RESPONSIBILITIES

8.01 *Communications to Contractor*

- A. Except as otherwise provided in these General Conditions, Owner shall issue all communications to Contractor through Engineer.

8.02 *Replacement of Engineer*

- A. In case of termination of the employment of Engineer, Owner shall appoint an engineer to whom Contractor makes no reasonable objection, whose status under the Contract Documents shall be that of the former Engineer.

8.03 *Furnish Data*

- A. Owner shall promptly furnish the data required of Owner under the Contract Documents.

8.04 *Pay When Due*

- A. Owner shall make payments to Contractor when they are due as provided in Paragraphs 14.02.C and 14.07.C.

8.05 *Lands and Easements; Reports and Tests*

- A. Owner's duties with respect to providing lands and easements and providing engineering surveys to establish reference points are set forth in Paragraphs 4.01 and 4.05. Paragraph 4.02 refers to Owner's identifying and making available to Contractor copies of reports of explorations and tests of subsurface conditions and drawings of physical conditions relating to existing surface or subsurface structures at the Site.

8.06 *Insurance*

- A. Owner's responsibilities, if any, with respect to purchasing and maintaining liability and property insurance are set forth in Article 5.

8.07 *Change Orders*

A. Owner is obligated to execute Change Orders as indicated in Paragraph 10.03.

8.08 *Inspections, Tests, and Approvals*

A. Owner's responsibility with respect to certain inspections, tests, and approvals is set forth in Paragraph 13.03.B.

8.09 *Limitations on Owner's Responsibilities*

A. The Owner shall not supervise, direct, or have control or authority over, nor be responsible for, Contractor's means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or for any failure of Contractor to comply with Laws and Regulations applicable to the performance of the Work. Owner will not be responsible for Contractor's failure to perform the Work in accordance with the Contract Documents.

8.10 *Undisclosed Hazardous Environmental Condition*

A. Owner's responsibility in respect to an undisclosed Hazardous Environmental Condition is set forth in Paragraph 4.06.

8.11 *Evidence of Financial Arrangements*

A. Upon request of Contractor, Owner shall furnish Contractor reasonable evidence that financial arrangements have been made to satisfy Owner's obligations under the Contract Documents.

8.12 *Compliance with Safety Program*

A. While at the Site, Owner's employees and representatives shall comply with the specific applicable requirements of Contractor's safety programs of which Owner has been informed pursuant to Paragraph 6.13.D.

ARTICLE 9 – ENGINEER'S STATUS DURING CONSTRUCTION

9.01 *Owner's Representative*

A. Engineer will be Owner's representative during the construction period. The duties and responsibilities and the limitations of authority of Engineer as Owner's representative during construction are set forth in the Contract Documents.

9.02 *Visits to Site*

A. Engineer will make visits to the Site at intervals appropriate to the various stages of construction as Engineer deems necessary in order to observe as an experienced and qualified design professional the progress that has been made and the quality of the various aspects of Contractor's executed Work. Based on information obtained during such visits and observations, Engineer, for the benefit of Owner, will determine, in general, if the Work is proceeding in accordance with the Contract Documents. Engineer will not be required to make exhaustive or

continuous inspections on the Site to check the quality or quantity of the Work. Engineer's efforts will be directed toward providing for Owner a greater degree of confidence that the completed Work will conform generally to the Contract Documents. On the basis of such visits and observations, Engineer will keep Owner informed of the progress of the Work and will endeavor to guard Owner against defective Work.

- B. Engineer's visits and observations are subject to all the limitations on Engineer's authority and responsibility set forth in Paragraph 9.09. Particularly, but without limitation, during or as a result of Engineer's visits or observations of Contractor's Work, Engineer will not supervise, direct, control, or have authority over or be responsible for Contractor's means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or for any failure of Contractor to comply with Laws and Regulations applicable to the performance of the Work.

9.03 *Project Representative*

- A. If Owner and Engineer agree, Engineer will furnish a Resident Project Representative to assist Engineer in providing more extensive observation of the Work. The authority and responsibilities of any such Resident Project Representative and assistants will be as provided in the Supplementary Conditions, and limitations on the responsibilities thereof will be as provided in Paragraph 9.09. If Owner designates another representative or agent to represent Owner at the Site who is not Engineer's consultant, agent or employee, the responsibilities and authority and limitations thereon of such other individual or entity will be as provided in the Supplementary Conditions.

9.04 *Authorized Variations in Work*

- A. Engineer may authorize minor variations in the Work from the requirements of the Contract Documents which do not involve an adjustment in the Contract Price or the Contract Times and are compatible with the design concept of the completed Project as a functioning whole as indicated by the Contract Documents. These may be accomplished by a Field Order and will be binding on Owner and also on Contractor, who shall perform the Work involved promptly. If Owner or Contractor believes that a Field Order justifies an adjustment in the Contract Price or Contract Times, or both, and the parties are unable to agree on entitlement to or on the amount or extent, if any, of any such adjustment, a Claim may be made therefor as provided in Paragraph 10.05.

9.05 *Rejecting Defective Work*

- A. Engineer will have authority to reject Work which Engineer believes to be defective, or that Engineer believes will not produce a completed Project that conforms to the Contract Documents or that will prejudice the integrity of the design concept of the completed Project as a functioning whole as indicated by the Contract Documents. Engineer will also have authority to require special inspection or testing of the Work as provided in Paragraph 13.04, whether or not the Work is fabricated, installed, or completed.

9.06 *Shop Drawings, Change Orders and Payments*

- A. In connection with Engineer's authority, and limitations thereof, as to Shop Drawings and Samples, see Paragraph 6.17.
- B. In connection with Engineer's authority, and limitations thereof, as to design calculations and design drawings submitted in response to a delegation of professional design services, if any, see Paragraph 6.21.
- C. In connection with Engineer's authority as to Change Orders, see Articles 10, 11, and 12.
- D. In connection with Engineer's authority as to Applications for Payment, see Article 14.

9.07 *Determinations for Unit Price Work*

- A. Engineer will determine the actual quantities and classifications of Unit Price Work performed by Contractor. Engineer will review with Contractor the Engineer's preliminary determinations on such matters before rendering a written decision thereon (by recommendation of an Application for Payment or otherwise). Engineer's written decision thereon will be final and binding (except as modified by Engineer to reflect changed factual conditions or more accurate data) upon Owner and Contractor, subject to the provisions of Paragraph 10.05.

9.08 *Decisions on Requirements of Contract Documents and Acceptability of Work*

- A. Engineer will be the initial interpreter of the requirements of the Contract Documents and judge of the acceptability of the Work thereunder. All matters in question and other matters between Owner and Contractor arising prior to the date final payment is due relating to the acceptability of the Work, and the interpretation of the requirements of the Contract Documents pertaining to the performance of the Work, will be referred initially to Engineer in writing within 30 days of the event giving rise to the question.
- B. Engineer will, with reasonable promptness, render a written decision on the issue referred. If Owner or Contractor believes that any such decision entitles them to an adjustment in the Contract Price or Contract Times or both, a Claim may be made under Paragraph 10.05. The date of Engineer's decision shall be the date of the event giving rise to the issues referenced for the purposes of Paragraph 10.05.B.
- C. Engineer's written decision on the issue referred will be final and binding on Owner and Contractor, subject to the provisions of Paragraph 10.05.
- D. When functioning as interpreter and judge under this Paragraph 9.08, Engineer will not show partiality to Owner or Contractor and will not be liable in connection with any interpretation or decision rendered in good faith in such capacity.

9.09 *Limitations on Engineer's Authority and Responsibilities*

- A. Neither Engineer's authority or responsibility under this Article 9 or under any other provision of the Contract Documents nor any decision made by Engineer in good faith either to exercise or not

exercise such authority or responsibility or the undertaking, exercise, or performance of any authority or responsibility by Engineer shall create, impose, or give rise to any duty in contract, tort, or otherwise owed by Engineer to Contractor, any Subcontractor, any Supplier, any other individual or entity, or to any surety for or employee or agent of any of them.

- B. Engineer will not supervise, direct, control, or have authority over or be responsible for Contractor's means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or for any failure of Contractor to comply with Laws and Regulations applicable to the performance of the Work. Engineer will not be responsible for Contractor's failure to perform the Work in accordance with the Contract Documents.
- C. Engineer will not be responsible for the acts or omissions of Contractor or of any Subcontractor, any Supplier, or of any other individual or entity performing any of the Work.
- D. Engineer's review of the final Application for Payment and accompanying documentation and all maintenance and operating instructions, schedules, guarantees, bonds, certificates of inspection, tests and approvals, and other documentation required to be delivered by Paragraph 14.07.A will only be to determine generally that their content complies with the requirements of, and in the case of certificates of inspections, tests, and approvals that the results certified indicate compliance with, the Contract Documents.
- E. The limitations upon authority and responsibility set forth in this Paragraph 9.09 shall also apply to the Resident Project Representative, if any, and assistants, if any.

9.10 *Compliance with Safety Program*

- A. While at the Site, Engineer's employees and representatives shall comply with the specific applicable requirements of Contractor's safety programs of which Engineer has been informed pursuant to Paragraph 6.13.D.

ARTICLE 10 – CHANGES IN THE WORK; CLAIMS

10.01 *Authorized Changes in the Work*

- A. Without invalidating the Contract and without notice to any surety, Owner may, at any time or from time to time, order additions, deletions, or revisions in the Work by a Change Order, or a Work Change Directive. Upon receipt of any such document, Contractor shall promptly proceed with the Work involved which will be performed under the applicable conditions of the Contract Documents (except as otherwise specifically provided).
- B. If Owner and Contractor are unable to agree on entitlement to, or on the amount or extent, if any, of an adjustment in the Contract Price or Contract Times, or both, that should be allowed as a result of a Work Change Directive, a Claim may be made therefor as provided in Paragraph 10.05.

10.02 *Unauthorized Changes in the Work*

- A. Contractor shall not be entitled to an increase in the Contract Price or an extension of the Contract Times with respect to any work performed that is not required by the Contract Documents as amended, modified, or supplemented as provided in Paragraph 3.04, except in the case of an emergency as provided in Paragraph 6.16 or in the case of uncovering Work as provided in Paragraph 13.04.D.

10.03 *Execution of Change Orders*

- A. Owner and Contractor shall execute appropriate Change Orders recommended by Engineer covering:
 - 1. changes in the Work which are: (i) ordered by Owner pursuant to Paragraph 10.01.A, (ii) required because of acceptance of defective Work under Paragraph 13.08.A or Owner's correction of defective Work under Paragraph 13.09, or (iii) agreed to by the parties;
 - 2. changes in the Contract Price or Contract Times which are agreed to by the parties, including any undisputed sum or amount of time for Work actually performed in accordance with a Work Change Directive; and
 - 3. changes in the Contract Price or Contract Times which embody the substance of any written decision rendered by Engineer pursuant to Paragraph 10.05; provided that, in lieu of executing any such Change Order, an appeal may be taken from any such decision in accordance with the provisions of the Contract Documents and applicable Laws and Regulations, but during any such appeal, Contractor shall carry on the Work and adhere to the Progress Schedule as provided in Paragraph 6.18.A.

10.04 *Notification to Surety*

- A. If the provisions of any bond require notice to be given to a surety of any change affecting the general scope of the Work or the provisions of the Contract Documents (including, but not limited to, Contract Price or Contract Times), the giving of any such notice will be Contractor's responsibility. The amount of each applicable bond will be adjusted to reflect the effect of any such change.

10.05 *Claims*

- A. *Engineer's Decision Required:* All Claims, except those waived pursuant to Paragraph 14.09, shall be referred to the Engineer for decision. A decision by Engineer shall be required as a condition precedent to any exercise by Owner or Contractor of any rights or remedies either may otherwise have under the Contract Documents or by Laws and Regulations in respect of such Claims.
- B. *Notice:* Written notice stating the general nature of each Claim shall be delivered by the claimant to Engineer and the other party to the Contract promptly (but in no event later than 30 days) after the start of the event giving rise thereto. The responsibility to substantiate a Claim shall rest with the party making the Claim. Notice of the amount or extent of the Claim, with supporting data

shall be delivered to the Engineer and the other party to the Contract within 60 days after the start of such event (unless Engineer allows additional time for claimant to submit additional or more accurate data in support of such Claim). A Claim for an adjustment in Contract Price shall be prepared in accordance with the provisions of Paragraph 12.01.B. A Claim for an adjustment in Contract Times shall be prepared in accordance with the provisions of Paragraph 12.02.B. Each Claim shall be accompanied by claimant's written statement that the adjustment claimed is the entire adjustment to which the claimant believes it is entitled as a result of said event. The opposing party shall submit any response to Engineer and the claimant within 30 days after receipt of the claimant's last submittal (unless Engineer allows additional time).

- C. *Engineer's Action:* Engineer will review each Claim and, within 30 days after receipt of the last submittal of the claimant or the last submittal of the opposing party, if any, take one of the following actions in writing:
1. deny the Claim in whole or in part;
 2. approve the Claim; or
 3. notify the parties that the Engineer is unable to resolve the Claim if, in the Engineer's sole discretion, it would be inappropriate for the Engineer to do so. For purposes of further resolution of the Claim, such notice shall be deemed a denial.
- D. In the event that Engineer does not take action on a Claim within said 30 days, the Claim shall be deemed denied.
- E. Engineer's written action under Paragraph 10.05.C or denial pursuant to Paragraphs 10.05.C.3 or 10.05.D will be final and binding upon Owner and Contractor, unless Owner or Contractor invoke the dispute resolution procedure set forth in Article 16 within 30 days of such action or denial.
- F. No Claim for an adjustment in Contract Price or Contract Times will be valid if not submitted in accordance with this Paragraph 10.05.

ARTICLE 11 – COST OF THE WORK; ALLOWANCES; UNIT PRICE WORK

11.01 *Cost of the Work*

- A. *Costs Included:* The term Cost of the Work means the sum of all costs, except those excluded in Paragraph 11.01.B, necessarily incurred and paid by Contractor in the proper performance of the Work. When the value of any Work covered by a Change Order or when a Claim for an adjustment in Contract Price is determined on the basis of Cost of the Work, the costs to be reimbursed to Contractor will be only those additional or incremental costs required because of the change in the Work or because of the event giving rise to the Claim. Except as otherwise may be agreed to in writing by Owner, such costs shall be in amounts no higher than those prevailing in the locality of the Project, shall not include any of the costs itemized in Paragraph 11.01.B, and shall include only the following items:

1. Payroll costs for employees in the direct employ of Contractor in the performance of the Work under schedules of job classifications agreed upon by Owner and Contractor. Such employees shall include, without limitation, superintendents, foremen, and other personnel employed full time on the Work. Payroll costs for employees not employed full time on the Work shall be apportioned on the basis of their time spent on the Work. Payroll costs shall include, but not be limited to, salaries and wages plus the cost of fringe benefits, which shall include social security contributions, unemployment, excise, and payroll taxes, workers' compensation, health and retirement benefits, bonuses, sick leave, vacation and holiday pay applicable thereto. The expenses of performing Work outside of regular working hours, on Saturday, Sunday, or legal holidays, shall be included in the above to the extent authorized by Owner.
2. Cost of all materials and equipment furnished and incorporated in the Work, including costs of transportation and storage thereof, and Suppliers' field services required in connection therewith. All cash discounts shall accrue to Contractor unless Owner deposits funds with Contractor with which to make payments, in which case the cash discounts shall accrue to Owner. All trade discounts, rebates and refunds and returns from sale of surplus materials and equipment shall accrue to Owner, and Contractor shall make provisions so that they may be obtained.
3. Payments made by Contractor to Subcontractors for Work performed by Subcontractors. If required by Owner, Contractor shall obtain competitive bids from subcontractors acceptable to Owner and Contractor and shall deliver such bids to Owner, who will then determine, with the advice of Engineer, which bids, if any, will be acceptable. If any subcontract provides that the Subcontractor is to be paid on the basis of Cost of the Work plus a fee, the Subcontractor's Cost of the Work and fee shall be determined in the same manner as Contractor's Cost of the Work and fee as provided in this Paragraph 11.01.
4. Costs of special consultants (including but not limited to engineers, architects, testing laboratories, surveyors, attorneys, and accountants) employed for services specifically related to the Work.
5. Supplemental costs including the following:
 - a. The proportion of necessary transportation, travel, and subsistence expenses of Contractor's employees incurred in discharge of duties connected with the Work.
 - b. Cost, including transportation and maintenance, of all materials, supplies, equipment, machinery, appliances, office, and temporary facilities at the Site, and hand tools not owned by the workers, which are consumed in the performance of the Work, and cost, less market value, of such items used but not consumed which remain the property of Contractor.
 - c. Rentals of all construction equipment and machinery, and the parts thereof whether rented from Contractor or others in accordance with rental agreements approved by Owner with the advice of Engineer, and the costs of transportation, loading, unloading, assembly, dismantling, and removal thereof. All such costs shall be in accordance with the terms of

said rental agreements. The rental of any such equipment, machinery, or parts shall cease when the use thereof is no longer necessary for the Work.

- d. Sales, consumer, use, and other similar taxes related to the Work, and for which Contractor is liable, as imposed by Laws and Regulations.
- e. Deposits lost for causes other than negligence of Contractor, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable, and royalty payments and fees for permits and licenses.
- f. Losses and damages (and related expenses) caused by damage to the Work, not compensated by insurance or otherwise, sustained by Contractor in connection with the performance of the Work (except losses and damages within the deductible amounts of property insurance established in accordance with Paragraph 5.06.D), provided such losses and damages have resulted from causes other than the negligence of Contractor, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable. Such losses shall include settlements made with the written consent and approval of Owner. No such losses, damages, and expenses shall be included in the Cost of the Work for the purpose of determining Contractor's fee.
- g. The cost of utilities, fuel, and sanitary facilities at the Site.
- h. Minor expenses such as telegrams, long distance telephone calls, telephone service at the Site, express and courier services, and similar petty cash items in connection with the Work.
- i. The costs of premiums for all bonds and insurance Contractor is required by the Contract Documents to purchase and maintain.

B. *Costs Excluded:* The term Cost of the Work shall not include any of the following items:

1. Payroll costs and other compensation of Contractor's officers, executives, principals (of partnerships and sole proprietorships), general managers, safety managers, engineers, architects, estimators, attorneys, auditors, accountants, purchasing and contracting agents, expeditors, timekeepers, clerks, and other personnel employed by Contractor, whether at the Site or in Contractor's principal or branch office for general administration of the Work and not specifically included in the agreed upon schedule of job classifications referred to in Paragraph 11.01.A.1 or specifically covered by Paragraph 11.01.A.4, all of which are to be considered administrative costs covered by the Contractor's fee.
2. Expenses of Contractor's principal and branch offices other than Contractor's office at the Site.
3. Any part of Contractor's capital expenses, including interest on Contractor's capital employed for the Work and charges against Contractor for delinquent payments.
4. Costs due to the negligence of Contractor, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable, including but not

limited to, the correction of defective Work, disposal of materials or equipment wrongly supplied, and making good any damage to property.

5. Other overhead or general expense costs of any kind and the costs of any item not specifically and expressly included in Paragraphs 11.01.A.
- C. *Contractor's Fee:* When all the Work is performed on the basis of cost-plus, Contractor's fee shall be determined as set forth in the Agreement. When the value of any Work covered by a Change Order or when a Claim for an adjustment in Contract Price is determined on the basis of Cost of the Work, Contractor's fee shall be determined as set forth in Paragraph 12.01.C.
- D. *Documentation:* Whenever the Cost of the Work for any purpose is to be determined pursuant to Paragraphs 11.01.A and 11.01.B, Contractor will establish and maintain records thereof in accordance with generally accepted accounting practices and submit in a form acceptable to Engineer an itemized cost breakdown together with supporting data.

11.02 Allowances

- A. It is understood that Contractor has included in the Contract Price all allowances so named in the Contract Documents and shall cause the Work so covered to be performed for such sums and by such persons or entities as may be acceptable to Owner and Engineer.
- B. *Cash Allowances:*
 1. Contractor agrees that:
 - a. the cash allowances include the cost to Contractor (less any applicable trade discounts) of materials and equipment required by the allowances to be delivered at the Site, and all applicable taxes; and
 - b. Contractor's costs for unloading and handling on the Site, labor, installation, overhead, profit, and other expenses contemplated for the cash allowances have been included in the Contract Price and not in the allowances, and no demand for additional payment on account of any of the foregoing will be valid.
- C. *Contingency Allowance:*
 1. Contractor agrees that a contingency allowance, if any, is for the sole use of Owner to cover unanticipated costs.
- D. Prior to final payment, an appropriate Change Order will be issued as recommended by Engineer to reflect actual amounts due Contractor on account of Work covered by allowances, and the Contract Price shall be correspondingly adjusted.

11.03 Unit Price Work

- A. Where the Contract Documents provide that all or part of the Work is to be Unit Price Work, initially the Contract Price will be deemed to include for all Unit Price Work an amount equal to

the sum of the unit price for each separately identified item of Unit Price Work times the estimated quantity of each item as indicated in the Agreement.

- B. The estimated quantities of items of Unit Price Work are not guaranteed and are solely for the purpose of comparison of Bids and determining an initial Contract Price. Determinations of the actual quantities and classifications of Unit Price Work performed by Contractor will be made by Engineer subject to the provisions of Paragraph 9.07.
- C. Each unit price will be deemed to include an amount considered by Contractor to be adequate to cover Contractor's overhead and profit for each separately identified item.
- D. Owner or Contractor may make a Claim for an adjustment in the Contract Price in accordance with Paragraph 10.05 if:
 - 1. the quantity of any item of Unit Price Work performed by Contractor differs materially and significantly from the estimated quantity of such item indicated in the Agreement; and
 - 2. there is no corresponding adjustment with respect to any other item of Work; and
 - 3. Contractor believes that Contractor is entitled to an increase in Contract Price as a result of having incurred additional expense or Owner believes that Owner is entitled to a decrease in Contract Price and the parties are unable to agree as to the amount of any such increase or decrease.

ARTICLE 12 – CHANGE OF CONTRACT PRICE; CHANGE OF CONTRACT TIMES

12.01 Change of Contract Price

- A. The Contract Price may only be changed by a Change Order. Any Claim for an adjustment in the Contract Price shall be based on written notice submitted by the party making the Claim to the Engineer and the other party to the Contract in accordance with the provisions of Paragraph 10.05.
- B. The value of any Work covered by a Change Order or of any Claim for an adjustment in the Contract Price will be determined as follows:
 - 1. where the Work involved is covered by unit prices contained in the Contract Documents, by application of such unit prices to the quantities of the items involved (subject to the provisions of Paragraph 11.03); or
 - 2. where the Work involved is not covered by unit prices contained in the Contract Documents, by a mutually agreed lump sum (which may include an allowance for overhead and profit not necessarily in accordance with Paragraph 12.01.C.2); or
 - 3. where the Work involved is not covered by unit prices contained in the Contract Documents and agreement to a lump sum is not reached under Paragraph 12.01.B.2, on the basis of the Cost of the Work (determined as provided in Paragraph 11.01) plus a Contractor's fee for overhead and profit (determined as provided in Paragraph 12.01.C).

C. *Contractor's Fee*: The Contractor's fee for overhead and profit shall be determined as follows:

1. a mutually acceptable fixed fee; or
2. if a fixed fee is not agreed upon, then a fee based on the following percentages of the various portions of the Cost of the Work:
 - a. for costs incurred under Paragraphs 11.01.A.1 and 11.01.A.2, the Contractor's fee shall be 15 percent;
 - b. for costs incurred under Paragraph 11.01.A.3, the Contractor's fee shall be five percent;
 - c. where one or more tiers of subcontracts are on the basis of Cost of the Work plus a fee and no fixed fee is agreed upon, the intent of Paragraphs 12.01.C.2.a and 12.01.C.2.b is that the Subcontractor who actually performs the Work, at whatever tier, will be paid a fee of 15 percent of the costs incurred by such Subcontractor under Paragraphs 11.01.A.1 and 11.01.A.2 and that any higher tier Subcontractor and Contractor will each be paid a fee of five percent of the amount paid to the next lower tier Subcontractor;
 - d. no fee shall be payable on the basis of costs itemized under Paragraphs 11.01.A.4, 11.01.A.5, and 11.01.B;
 - e. the amount of credit to be allowed by Contractor to Owner for any change which results in a net decrease in cost will be the amount of the actual net decrease in cost plus a deduction in Contractor's fee by an amount equal to five percent of such net decrease; and
 - f. when both additions and credits are involved in any one change, the adjustment in Contractor's fee shall be computed on the basis of the net change in accordance with Paragraphs 12.01.C.2.a through 12.01.C.2.e, inclusive.

12.02 *Change of Contract Times*

- A. The Contract Times may only be changed by a Change Order. Any Claim for an adjustment in the Contract Times shall be based on written notice submitted by the party making the Claim to the Engineer and the other party to the Contract in accordance with the provisions of Paragraph 10.05.
- B. Any adjustment of the Contract Times covered by a Change Order or any Claim for an adjustment in the Contract Times will be determined in accordance with the provisions of this Article 12.

12.03 *Delays*

- A. Where Contractor is prevented from completing any part of the Work within the Contract Times due to delay beyond the control of Contractor, the Contract Times will be extended in an amount equal to the time lost due to such delay if a Claim is made therefor as provided in Paragraph 12.02.A. Delays beyond the control of Contractor shall include, but not be limited to, acts or

neglect by Owner, acts or neglect of utility owners or other contractors performing other work as contemplated by Article 7, fires, floods, epidemics, abnormal weather conditions, or acts of God.

- B. If Owner, Engineer, or other contractors or utility owners performing other work for Owner as contemplated by Article 7, or anyone for whom Owner is responsible, delays, disrupts, or interferes with the performance or progress of the Work, then Contractor shall be entitled to an equitable adjustment in the Contract Price or the Contract Times, or both. Contractor's entitlement to an adjustment of the Contract Times is conditioned on such adjustment being essential to Contractor's ability to complete the Work within the Contract Times.
- C. If Contractor is delayed in the performance or progress of the Work by fire, flood, epidemic, abnormal weather conditions, acts of God, acts or failures to act of utility owners not under the control of Owner, or other causes not the fault of and beyond control of Owner and Contractor, then Contractor shall be entitled to an equitable adjustment in Contract Times, if such adjustment is essential to Contractor's ability to complete the Work within the Contract Times. Such an adjustment shall be Contractor's sole and exclusive remedy for the delays described in this Paragraph 12.03.C.
- D. Owner, Engineer, and their officers, directors, members, partners, employees, agents, consultants, or subcontractors shall not be liable to Contractor for any claims, costs, losses, or damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) sustained by Contractor on or in connection with any other project or anticipated project.
- E. Contractor shall not be entitled to an adjustment in Contract Price or Contract Times for delays within the control of Contractor. Delays attributable to and within the control of a Subcontractor or Supplier shall be deemed to be delays within the control of Contractor.

ARTICLE 13 – TESTS AND INSPECTIONS; CORRECTION, REMOVAL OR ACCEPTANCE OF DEFECTIVE WORK

13.01 Notice of Defects

- A. Prompt notice of all defective Work of which Owner or Engineer has actual knowledge will be given to Contractor. Defective Work may be rejected, corrected, or accepted as provided in this Article 13.

13.02 Access to Work

- A. Owner, Engineer, their consultants and other representatives and personnel of Owner, independent testing laboratories, and governmental agencies with jurisdictional interests will have access to the Site and the Work at reasonable times for their observation, inspection, and testing. Contractor shall provide them proper and safe conditions for such access and advise them of Contractor's safety procedures and programs so that they may comply therewith as applicable.

13.03 *Tests and Inspections*

- A. Contractor shall give Engineer timely notice of readiness of the Work for all required inspections, tests, or approvals and shall cooperate with inspection and testing personnel to facilitate required inspections or tests.
- B. Owner shall employ and pay for the services of an independent testing laboratory to perform all inspections, tests, or approvals required by the Contract Documents except:
 - 1. for inspections, tests, or approvals covered by Paragraphs 13.03.C and 13.03.D below;
 - 2. that costs incurred in connection with tests or inspections conducted pursuant to Paragraph 13.04.B shall be paid as provided in Paragraph 13.04.C; and
 - 3. as otherwise specifically provided in the Contract Documents.
- C. If Laws or Regulations of any public body having jurisdiction require any Work (or part thereof) specifically to be inspected, tested, or approved by an employee or other representative of such public body, Contractor shall assume full responsibility for arranging and obtaining such inspections, tests, or approvals, pay all costs in connection therewith, and furnish Engineer the required certificates of inspection or approval.
- D. Contractor shall be responsible for arranging and obtaining and shall pay all costs in connection with any inspections, tests, or approvals required for Owner's and Engineer's acceptance of materials or equipment to be incorporated in the Work; or acceptance of materials, mix designs, or equipment submitted for approval prior to Contractor's purchase thereof for incorporation in the Work. Such inspections, tests, or approvals shall be performed by organizations acceptable to Owner and Engineer.
- E. If any Work (or the work of others) that is to be inspected, tested, or approved is covered by Contractor without written concurrence of Engineer, Contractor shall, if requested by Engineer, uncover such Work for observation.
- F. Uncovering Work as provided in Paragraph 13.03.E shall be at Contractor's expense unless Contractor has given Engineer timely notice of Contractor's intention to cover the same and Engineer has not acted with reasonable promptness in response to such notice.

13.04 *Uncovering Work*

- A. If any Work is covered contrary to the written request of Engineer, it must, if requested by Engineer, be uncovered for Engineer's observation and replaced at Contractor's expense.
- B. If Engineer considers it necessary or advisable that covered Work be observed by Engineer or inspected or tested by others, Contractor, at Engineer's request, shall uncover, expose, or otherwise make available for observation, inspection, or testing as Engineer may require, that portion of the Work in question, furnishing all necessary labor, material, and equipment.

- C. If it is found that the uncovered Work is defective, Contractor shall pay all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such uncovering, exposure, observation, inspection, and testing, and of satisfactory replacement or reconstruction (including but not limited to all costs of repair or replacement of work of others); and Owner shall be entitled to an appropriate decrease in the Contract Price. If the parties are unable to agree as to the amount thereof, Owner may make a Claim therefor as provided in Paragraph 10.05.
- D. If the uncovered Work is not found to be defective, Contractor shall be allowed an increase in the Contract Price or an extension of the Contract Times, or both, directly attributable to such uncovering, exposure, observation, inspection, testing, replacement, and reconstruction. If the parties are unable to agree as to the amount or extent thereof, Contractor may make a Claim therefor as provided in Paragraph 10.05.

13.05 *Owner May Stop the Work*

- A. If the Work is defective, or Contractor fails to supply sufficient skilled workers or suitable materials or equipment, or fails to perform the Work in such a way that the completed Work will conform to the Contract Documents, Owner may order Contractor to stop the Work, or any portion thereof, until the cause for such order has been eliminated; however, this right of Owner to stop the Work shall not give rise to any duty on the part of Owner to exercise this right for the benefit of Contractor, any Subcontractor, any Supplier, any other individual or entity, or any surety for, or employee or agent of any of them.

13.06 *Correction or Removal of Defective Work*

- A. Promptly after receipt of written notice, Contractor shall correct all defective Work, whether or not fabricated, installed, or completed, or, if the Work has been rejected by Engineer, remove it from the Project and replace it with Work that is not defective. Contractor shall pay all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such correction or removal (including but not limited to all costs of repair or replacement of work of others).
- B. When correcting defective Work under the terms of this Paragraph 13.06 or Paragraph 13.07, Contractor shall take no action that would void or otherwise impair Owner's special warranty and guarantee, if any, on said Work.

13.07 *Correction Period*

- A. If within one year after the date of Substantial Completion (or such longer period of time as may be prescribed by the terms of any applicable special guarantee required by the Contract Documents) or by any specific provision of the Contract Documents, any Work is found to be defective, or if the repair of any damages to the land or areas made available for Contractor's use by Owner or permitted by Laws and Regulations as contemplated in Paragraph 6.11.A is found to be defective, Contractor shall promptly, without cost to Owner and in accordance with Owner's written instructions:

1. repair such defective land or areas; or
 2. correct such defective Work; or
 3. if the defective Work has been rejected by Owner, remove it from the Project and replace it with Work that is not defective, and
 4. satisfactorily correct or repair or remove and replace any damage to other Work, to the work of others or other land or areas resulting therefrom.
- B. If Contractor does not promptly comply with the terms of Owner's written instructions, or in an emergency where delay would cause serious risk of loss or damage, Owner may have the defective Work corrected or repaired or may have the rejected Work removed and replaced. All claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such correction or repair or such removal and replacement (including but not limited to all costs of repair or replacement of work of others) will be paid by Contractor.
- C. In special circumstances where a particular item of equipment is placed in continuous service before Substantial Completion of all the Work, the correction period for that item may start to run from an earlier date if so provided in the Specifications.
- D. Where defective Work (and damage to other Work resulting therefrom) has been corrected or removed and replaced under this Paragraph 13.07, the correction period hereunder with respect to such Work will be extended for an additional period of one year after such correction or removal and replacement has been satisfactorily completed.
- E. Contractor's obligations under this Paragraph 13.07 are in addition to any other obligation or warranty. The provisions of this Paragraph 13.07 shall not be construed as a substitute for, or a waiver of, the provisions of any applicable statute of limitation or repose.

13.08 *Acceptance of Defective Work*

- A. If, instead of requiring correction or removal and replacement of defective Work, Owner (and, prior to Engineer's recommendation of final payment, Engineer) prefers to accept it, Owner may do so. Contractor shall pay all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) attributable to Owner's evaluation of and determination to accept such defective Work (such costs to be approved by Engineer as to reasonableness) and for the diminished value of the Work to the extent not otherwise paid by Contractor pursuant to this sentence. If any such acceptance occurs prior to Engineer's recommendation of final payment, a Change Order will be issued incorporating the necessary revisions in the Contract Documents with respect to the Work, and Owner shall be entitled to an appropriate decrease in the Contract Price, reflecting the diminished value of Work so accepted. If the parties are unable to agree as to the amount thereof, Owner may make a Claim therefor as provided in Paragraph 10.05. If the acceptance occurs after such recommendation, an appropriate amount will be paid by Contractor to Owner.

13.09 *Owner May Correct Defective Work*

- A. If Contractor fails within a reasonable time after written notice from Engineer to correct defective Work, or to remove and replace rejected Work as required by Engineer in accordance with Paragraph 13.06.A, or if Contractor fails to perform the Work in accordance with the Contract Documents, or if Contractor fails to comply with any other provision of the Contract Documents, Owner may, after seven days written notice to Contractor, correct, or remedy any such deficiency.
- B. In exercising the rights and remedies under this Paragraph 13.09, Owner shall proceed expeditiously. In connection with such corrective or remedial action, Owner may exclude Contractor from all or part of the Site, take possession of all or part of the Work and suspend Contractor's services related thereto, take possession of Contractor's tools, appliances, construction equipment and machinery at the Site, and incorporate in the Work all materials and equipment stored at the Site or for which Owner has paid Contractor but which are stored elsewhere. Contractor shall allow Owner, Owner's representatives, agents and employees, Owner's other contractors, and Engineer and Engineer's consultants access to the Site to enable Owner to exercise the rights and remedies under this Paragraph.
- C. All claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) incurred or sustained by Owner in exercising the rights and remedies under this Paragraph 13.09 will be charged against Contractor, and a Change Order will be issued incorporating the necessary revisions in the Contract Documents with respect to the Work; and Owner shall be entitled to an appropriate decrease in the Contract Price. If the parties are unable to agree as to the amount of the adjustment, Owner may make a Claim therefor as provided in Paragraph 10.05. Such claims, costs, losses and damages will include but not be limited to all costs of repair, or replacement of work of others destroyed or damaged by correction, removal, or replacement of Contractor's defective Work.
- D. Contractor shall not be allowed an extension of the Contract Times because of any delay in the performance of the Work attributable to the exercise by Owner of Owner's rights and remedies under this Paragraph 13.09.

ARTICLE 14 – PAYMENTS TO CONTRACTOR AND COMPLETION

14.01 *Schedule of Values*

- A. The Schedule of Values established as provided in Paragraph 2.07.A will serve as the basis for progress payments and will be incorporated into a form of Application for Payment acceptable to Engineer. Progress payments on account of Unit Price Work will be based on the number of units completed.

14.02 *Progress Payments*

A. *Applications for Payments:*

1. At least 20 days before the date established in the Agreement for each progress payment (but not more often than once a month), Contractor shall submit to Engineer for review an

Application for Payment filled out and signed by Contractor covering the Work completed as of the date of the Application and accompanied by such supporting documentation as is required by the Contract Documents. If payment is requested on the basis of materials and equipment not incorporated in the Work but delivered and suitably stored at the Site or at another location agreed to in writing, the Application for Payment shall also be accompanied by a bill of sale, invoice, or other documentation warranting that Owner has received the materials and equipment free and clear of all Liens and evidence that the materials and equipment are covered by appropriate property insurance or other arrangements to protect Owner's interest therein, all of which must be satisfactory to Owner.

2. Beginning with the second Application for Payment, each Application shall include an affidavit of Contractor stating that all previous progress payments received on account of the Work have been applied on account to discharge Contractor's legitimate obligations associated with prior Applications for Payment.
3. The amount of retainage with respect to progress payments will be as stipulated in the Agreement.

B. Review of Applications:

1. Engineer will, within 10 days after receipt of each Application for Payment, either indicate in writing a recommendation of payment and present the Application to Owner or return the Application to Contractor indicating in writing Engineer's reasons for refusing to recommend payment. In the latter case, Contractor may make the necessary corrections and resubmit the Application.
2. Engineer's recommendation of any payment requested in an Application for Payment will constitute a representation by Engineer to Owner, based on Engineer's observations of the executed Work as an experienced and qualified design professional, and on Engineer's review of the Application for Payment and the accompanying data and schedules, that to the best of Engineer's knowledge, information and belief:
 - a. the Work has progressed to the point indicated;
 - b. the quality of the Work is generally in accordance with the Contract Documents (subject to an evaluation of the Work as a functioning whole prior to or upon Substantial Completion, the results of any subsequent tests called for in the Contract Documents, a final determination of quantities and classifications for Unit Price Work under Paragraph 9.07, and any other qualifications stated in the recommendation); and
 - c. the conditions precedent to Contractor's being entitled to such payment appear to have been fulfilled in so far as it is Engineer's responsibility to observe the Work.
3. By recommending any such payment Engineer will not thereby be deemed to have represented that:
 - a. inspections made to check the quality or the quantity of the Work as it has been performed have been exhaustive, extended to every aspect of the Work in progress, or

- involved detailed inspections of the Work beyond the responsibilities specifically assigned to Engineer in the Contract Documents; or
- b. there may not be other matters or issues between the parties that might entitle Contractor to be paid additionally by Owner or entitle Owner to withhold payment to Contractor.
4. Neither Engineer's review of Contractor's Work for the purposes of recommending payments nor Engineer's recommendation of any payment, including final payment, will impose responsibility on Engineer:
 - a. to supervise, direct, or control the Work, or
 - b. for the means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or
 - c. for Contractor's failure to comply with Laws and Regulations applicable to Contractor's performance of the Work, or
 - d. to make any examination to ascertain how or for what purposes Contractor has used the moneys paid on account of the Contract Price, or
 - e. to determine that title to any of the Work, materials, or equipment has passed to Owner free and clear of any Liens.
 5. Engineer may refuse to recommend the whole or any part of any payment if, in Engineer's opinion, it would be incorrect to make the representations to Owner stated in Paragraph 14.02.B.2. Engineer may also refuse to recommend any such payment or, because of subsequently discovered evidence or the results of subsequent inspections or tests, revise or revoke any such payment recommendation previously made, to such extent as may be necessary in Engineer's opinion to protect Owner from loss because:
 - a. the Work is defective, or completed Work has been damaged, requiring correction or replacement;
 - b. the Contract Price has been reduced by Change Orders;
 - c. Owner has been required to correct defective Work or complete Work in accordance with Paragraph 13.09; or
 - d. Engineer has actual knowledge of the occurrence of any of the events enumerated in Paragraph 15.02.A.

C. Payment Becomes Due:

1. Ten days after presentation of the Application for Payment to Owner with Engineer's recommendation, the amount recommended will (subject to the provisions of Paragraph 14.02.D) become due, and when due will be paid by Owner to Contractor.

D. *Reduction in Payment:*

1. Owner may refuse to make payment of the full amount recommended by Engineer because:
 - a. claims have been made against Owner on account of Contractor's performance or furnishing of the Work;
 - b. Liens have been filed in connection with the Work, except where Contractor has delivered a specific bond satisfactory to Owner to secure the satisfaction and discharge of such Liens;
 - c. there are other items entitling Owner to a set-off against the amount recommended; or
 - d. Owner has actual knowledge of the occurrence of any of the events enumerated in Paragraphs 14.02.B.5.a through 14.02.B.5.c or Paragraph 15.02.A.
2. If Owner refuses to make payment of the full amount recommended by Engineer, Owner will give Contractor immediate written notice (with a copy to Engineer) stating the reasons for such action and promptly pay Contractor any amount remaining after deduction of the amount so withheld. Owner shall promptly pay Contractor the amount so withheld, or any adjustment thereto agreed to by Owner and Contractor, when Contractor remedies the reasons for such action.
3. Upon a subsequent determination that Owner's refusal of payment was not justified, the amount wrongfully withheld shall be treated as an amount due as determined by Paragraph 14.02.C.1 and subject to interest as provided in the Agreement.

14.03 *Contractor's Warranty of Title*

- A. Contractor warrants and guarantees that title to all Work, materials, and equipment covered by any Application for Payment, whether incorporated in the Project or not, will pass to Owner no later than the time of payment free and clear of all Liens.

14.04 *Substantial Completion*

- A. When Contractor considers the entire Work ready for its intended use Contractor shall notify Owner and Engineer in writing that the entire Work is substantially complete (except for items specifically listed by Contractor as incomplete) and request that Engineer issue a certificate of Substantial Completion.
- B. Promptly after Contractor's notification, Owner, Contractor, and Engineer shall make an inspection of the Work to determine the status of completion. If Engineer does not consider the Work substantially complete, Engineer will notify Contractor in writing giving the reasons therefor.
- C. If Engineer considers the Work substantially complete, Engineer will deliver to Owner a tentative certificate of Substantial Completion which shall fix the date of Substantial Completion. There shall be attached to the certificate a tentative list of items to be completed or corrected before

final payment. Owner shall have seven days after receipt of the tentative certificate during which to make written objection to Engineer as to any provisions of the certificate or attached list. If, after considering such objections, Engineer concludes that the Work is not substantially complete, Engineer will, within 14 days after submission of the tentative certificate to Owner, notify Contractor in writing, stating the reasons therefor. If, after consideration of Owner's objections, Engineer considers the Work substantially complete, Engineer will, within said 14 days, execute and deliver to Owner and Contractor a definitive certificate of Substantial Completion (with a revised tentative list of items to be completed or corrected) reflecting such changes from the tentative certificate as Engineer believes justified after consideration of any objections from Owner.

- D. At the time of delivery of the tentative certificate of Substantial Completion, Engineer will deliver to Owner and Contractor a written recommendation as to division of responsibilities pending final payment between Owner and Contractor with respect to security, operation, safety, and protection of the Work, maintenance, heat, utilities, insurance, and warranties and guarantees. Unless Owner and Contractor agree otherwise in writing and so inform Engineer in writing prior to Engineer's issuing the definitive certificate of Substantial Completion, Engineer's aforesaid recommendation will be binding on Owner and Contractor until final payment.
- E. Owner shall have the right to exclude Contractor from the Site after the date of Substantial Completion subject to allowing Contractor reasonable access to remove its property and complete or correct items on the tentative list.

14.05 *Partial Utilization*

- A. Prior to Substantial Completion of all the Work, Owner may use or occupy any substantially completed part of the Work which has specifically been identified in the Contract Documents, or which Owner, Engineer, and Contractor agree constitutes a separately functioning and usable part of the Work that can be used by Owner for its intended purpose without significant interference with Contractor's performance of the remainder of the Work, subject to the following conditions:
 - 1. Owner at any time may request Contractor in writing to permit Owner to use or occupy any such part of the Work which Owner believes to be ready for its intended use and substantially complete. If and when Contractor agrees that such part of the Work is substantially complete, Contractor, Owner, and Engineer will follow the procedures of Paragraph 14.04.A through D for that part of the Work.
 - 2. Contractor at any time may notify Owner and Engineer in writing that Contractor considers any such part of the Work ready for its intended use and substantially complete and request Engineer to issue a certificate of Substantial Completion for that part of the Work.
 - 3. Within a reasonable time after either such request, Owner, Contractor, and Engineer shall make an inspection of that part of the Work to determine its status of completion. If Engineer does not consider that part of the Work to be substantially complete, Engineer will notify Owner and Contractor in writing giving the reasons therefor. If Engineer considers that part of the Work to be substantially complete, the provisions of Paragraph 14.04 will apply with respect to certification of Substantial Completion of that part of the Work and the division of responsibility in respect thereof and access thereto.

4. No use or occupancy or separate operation of part of the Work may occur prior to compliance with the requirements of Paragraph 5.10 regarding property insurance.

14.06 *Final Inspection*

- A. Upon written notice from Contractor that the entire Work or an agreed portion thereof is complete, Engineer will promptly make a final inspection with Owner and Contractor and will notify Contractor in writing of all particulars in which this inspection reveals that the Work is incomplete or defective. Contractor shall immediately take such measures as are necessary to complete such Work or remedy such deficiencies.

14.07 *Final Payment*

A. *Application for Payment:*

1. After Contractor has, in the opinion of Engineer, satisfactorily completed all corrections identified during the final inspection and has delivered, in accordance with the Contract Documents, all maintenance and operating instructions, schedules, guarantees, bonds, certificates or other evidence of insurance, certificates of inspection, marked-up record documents (as provided in Paragraph 6.12), and other documents, Contractor may make application for final payment following the procedure for progress payments.
2. The final Application for Payment shall be accompanied (except as previously delivered) by:
 - a. all documentation called for in the Contract Documents, including but not limited to the evidence of insurance required by Paragraph 5.04.B.6;
 - b. consent of the surety, if any, to final payment;
 - c. a list of all Claims against Owner that Contractor believes are unsettled; and
 - d. complete and legally effective releases or waivers (satisfactory to Owner) of all Lien rights arising out of or Liens filed in connection with the Work.
3. In lieu of the releases or waivers of Liens specified in Paragraph 14.07.A.2 and as approved by Owner, Contractor may furnish receipts or releases in full and an affidavit of Contractor that: (i) the releases and receipts include all labor, services, material, and equipment for which a Lien could be filed; and (ii) all payrolls, material and equipment bills, and other indebtedness connected with the Work for which Owner might in any way be responsible, or which might in any way result in liens or other burdens on Owner's property, have been paid or otherwise satisfied. If any Subcontractor or Supplier fails to furnish such a release or receipt in full, Contractor may furnish a bond or other collateral satisfactory to Owner to indemnify Owner against any Lien.

B. *Engineer's Review of Application and Acceptance:*

1. If, on the basis of Engineer's observation of the Work during construction and final inspection, and Engineer's review of the final Application for Payment and accompanying

documentation as required by the Contract Documents, Engineer is satisfied that the Work has been completed and Contractor's other obligations under the Contract Documents have been fulfilled, Engineer will, within ten days after receipt of the final Application for Payment, indicate in writing Engineer's recommendation of payment and present the Application for Payment to Owner for payment. At the same time Engineer will also give written notice to Owner and Contractor that the Work is acceptable subject to the provisions of Paragraph 14.09. Otherwise, Engineer will return the Application for Payment to Contractor, indicating in writing the reasons for refusing to recommend final payment, in which case Contractor shall make the necessary corrections and resubmit the Application for Payment.

C. *Payment Becomes Due:*

1. Thirty days after the presentation to Owner of the Application for Payment and accompanying documentation, the amount recommended by Engineer, less any sum Owner is entitled to set off against Engineer's recommendation, including but not limited to liquidated damages, will become due and will be paid by Owner to Contractor.

14.08 *Final Completion Delayed*

- A. If, through no fault of Contractor, final completion of the Work is significantly delayed, and if Engineer so confirms, Owner shall, upon receipt of Contractor's final Application for Payment (for Work fully completed and accepted) and recommendation of Engineer, and without terminating the Contract, make payment of the balance due for that portion of the Work fully completed and accepted. If the remaining balance to be held by Owner for Work not fully completed or corrected is less than the retainage stipulated in the Agreement, and if bonds have been furnished as required in Paragraph 5.01, the written consent of the surety to the payment of the balance due for that portion of the Work fully completed and accepted shall be submitted by Contractor to Engineer with the Application for such payment. Such payment shall be made under the terms and conditions governing final payment, except that it shall not constitute a waiver of Claims.

14.09 *Waiver of Claims*

- A. The making and acceptance of final payment will constitute:
 1. a waiver of all Claims by Owner against Contractor, except Claims arising from unsettled Liens, from defective Work appearing after final inspection pursuant to Paragraph 14.06, from failure to comply with the Contract Documents or the terms of any special guarantees specified therein, or from Contractor's continuing obligations under the Contract Documents; and
 2. a waiver of all Claims by Contractor against Owner other than those previously made in accordance with the requirements herein and expressly acknowledged by Owner in writing as still unsettled.

ARTICLE 15 – SUSPENSION OF WORK AND TERMINATION

15.01 *Owner May Suspend Work*

- A. At any time and without cause, Owner may suspend the Work or any portion thereof for a period of not more than 90 consecutive days by notice in writing to Contractor and Engineer which will fix the date on which Work will be resumed. Contractor shall resume the Work on the date so fixed. Contractor shall be granted an adjustment in the Contract Price or an extension of the Contract Times, or both, directly attributable to any such suspension if Contractor makes a Claim therefor as provided in Paragraph 10.05.

15.02 *Owner May Terminate for Cause*

- A. The occurrence of any one or more of the following events will justify termination for cause:
1. Contractor's persistent failure to perform the Work in accordance with the Contract Documents (including, but not limited to, failure to supply sufficient skilled workers or suitable materials or equipment or failure to adhere to the Progress Schedule established under Paragraph 2.07 as adjusted from time to time pursuant to Paragraph 6.04);
 2. Contractor's disregard of Laws or Regulations of any public body having jurisdiction;
 3. Contractor's repeated disregard of the authority of Engineer; or
 4. Contractor's violation in any substantial way of any provisions of the Contract Documents.
- B. If one or more of the events identified in Paragraph 15.02.A occur, Owner may, after giving Contractor (and surety) seven days written notice of its intent to terminate the services of Contractor:
1. exclude Contractor from the Site, and take possession of the Work and of all Contractor's tools, appliances, construction equipment, and machinery at the Site, and use the same to the full extent they could be used by Contractor (without liability to Contractor for trespass or conversion);
 2. incorporate in the Work all materials and equipment stored at the Site or for which Owner has paid Contractor but which are stored elsewhere; and
 3. complete the Work as Owner may deem expedient.
- C. If Owner proceeds as provided in Paragraph 15.02.B, Contractor shall not be entitled to receive any further payment until the Work is completed. If the unpaid balance of the Contract Price exceeds all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) sustained by Owner arising out of or relating to completing the Work, such excess will be paid to Contractor. If such claims, costs, losses, and damages exceed such unpaid balance, Contractor shall pay the difference to Owner. Such claims, costs, losses, and damages incurred by Owner will be reviewed by Engineer as to their reasonableness and, when

so approved by Engineer, incorporated in a Change Order. When exercising any rights or remedies under this Paragraph, Owner shall not be required to obtain the lowest price for the Work performed.

- D. Notwithstanding Paragraphs 15.02.B and 15.02.C, Contractor's services will not be terminated if Contractor begins within seven days of receipt of notice of intent to terminate to correct its failure to perform and proceeds diligently to cure such failure within no more than 30 days of receipt of said notice.
- E. Where Contractor's services have been so terminated by Owner, the termination will not affect any rights or remedies of Owner against Contractor then existing or which may thereafter accrue. Any retention or payment of moneys due Contractor by Owner will not release Contractor from liability.
- F. If and to the extent that Contractor has provided a performance bond under the provisions of Paragraph 5.01.A, the termination procedures of that bond shall supersede the provisions of Paragraphs 15.02.B and 15.02.C.

15.03 *Owner May Terminate For Convenience*

- A. Upon seven days written notice to Contractor and Engineer, Owner may, without cause and without prejudice to any other right or remedy of Owner, terminate the Contract. In such case, Contractor shall be paid for (without duplication of any items):
 - 1. completed and acceptable Work executed in accordance with the Contract Documents prior to the effective date of termination, including fair and reasonable sums for overhead and profit on such Work;
 - 2. expenses sustained prior to the effective date of termination in performing services and furnishing labor, materials, or equipment as required by the Contract Documents in connection with uncompleted Work, plus fair and reasonable sums for overhead and profit on such expenses;
 - 3. all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) incurred in settlement of terminated contracts with Subcontractors, Suppliers, and others; and
 - 4. reasonable expenses directly attributable to termination.
- B. Contractor shall not be paid on account of loss of anticipated profits or revenue or other economic loss arising out of or resulting from such termination.

15.04 *Contractor May Stop Work or Terminate*

- A. If, through no act or fault of Contractor, (i) the Work is suspended for more than 90 consecutive days by Owner or under an order of court or other public authority, or (ii) Engineer fails to act on any Application for Payment within 30 days after it is submitted, or (iii) Owner fails for 30 days

to pay Contractor any sum finally determined to be due, then Contractor may, upon seven days written notice to Owner and Engineer, and provided Owner or Engineer do not remedy such suspension or failure within that time, terminate the Contract and recover from Owner payment on the same terms as provided in Paragraph 15.03.

- B. In lieu of terminating the Contract and without prejudice to any other right or remedy, if Engineer has failed to act on an Application for Payment within 30 days after it is submitted, or Owner has failed for 30 days to pay Contractor any sum finally determined to be due, Contractor may, seven days after written notice to Owner and Engineer, stop the Work until payment is made of all such amounts due Contractor, including interest thereon. The provisions of this Paragraph 15.04 are not intended to preclude Contractor from making a Claim under Paragraph 10.05 for an adjustment in Contract Price or Contract Times or otherwise for expenses or damage directly attributable to Contractor's stopping the Work as permitted by this Paragraph.

ARTICLE 16 – DISPUTE RESOLUTION

16.01 Methods and Procedures

- A. Either Owner or Contractor may request mediation of any Claim submitted to Engineer for a decision under Paragraph 10.05 before such decision becomes final and binding. The mediation will be governed by the Construction Industry Mediation Rules of the American Arbitration Association in effect as of the Effective Date of the Agreement. The request for mediation shall be submitted in writing to the American Arbitration Association and the other party to the Contract. Timely submission of the request shall stay the effect of Paragraph 10.05.E.
- B. Owner and Contractor shall participate in the mediation process in good faith. The process shall be concluded within 60 days of filing of the request. The date of termination of the mediation shall be determined by application of the mediation rules referenced above.
- C. If the Claim is not resolved by mediation, Engineer's action under Paragraph 10.05.C or a denial pursuant to Paragraphs 10.05.C.3 or 10.05.D shall become final and binding 30 days after termination of the mediation unless, within that time period, Owner or Contractor:
1. elects in writing to invoke any dispute resolution process provided for in the Supplementary Conditions; or
 2. agrees with the other party to submit the Claim to another dispute resolution process; or
 3. gives written notice to the other party of the intent to submit the Claim to a court of competent jurisdiction.

ARTICLE 17 – MISCELLANEOUS

17.01 Giving Notice

- A. Whenever any provision of the Contract Documents requires the giving of written notice, it will be deemed to have been validly given if:

1. delivered in person to the individual or to a member of the firm or to an officer of the corporation for whom it is intended; or
2. delivered at or sent by registered or certified mail, postage prepaid, to the last business address known to the giver of the notice.

17.02 *Computation of Times*

- A. When any period of time is referred to in the Contract Documents by days, it will be computed to exclude the first and include the last day of such period. If the last day of any such period falls on a Saturday or Sunday or on a day made a legal holiday by the law of the applicable jurisdiction, such day will be omitted from the computation.

17.03 *Cumulative Remedies*

- A. The duties and obligations imposed by these General Conditions and the rights and remedies available hereunder to the parties hereto are in addition to, and are not to be construed in any way as a limitation of, any rights and remedies available to any or all of them which are otherwise imposed or available by Laws or Regulations, by special warranty or guarantee, or by other provisions of the Contract Documents. The provisions of this Paragraph will be as effective as if repeated specifically in the Contract Documents in connection with each particular duty, obligation, right, and remedy to which they apply.

17.04 *Survival of Obligations*

- A. All representations, indemnifications, warranties, and guarantees made in, required by, or given in accordance with the Contract Documents, as well as all continuing obligations indicated in the Contract Documents, will survive final payment, completion, and acceptance of the Work or termination or completion of the Contract or termination of the services of Contractor.

17.05 *Controlling Law*

- A. This Contract is to be governed by the law of the state in which the Project is located.

17.06 *Headings*

- A. Article and paragraph headings are inserted for convenience only and do not constitute parts of these General Conditions.

SUPPLEMENTAL CONDITIONS

01. GENERAL CONDITIONS:

The "Standard General Conditions of the Construction Contract", Engineers Joint Contract Documents Committee, 2007 Edition, Articles 1 through 17 inclusive, included herein preceding these supplements, is a part of this Contract.

ARTICLE 5 - BONDS & INSURANCE

5.04 B 1& 2 Contractor's protective liability insurance, with minimum limits as follows:

General Liability – \$1,000,000 per occurrence;

Damage to rented premises – \$100,000 per occurrence;

Personal injury including death – \$1,000,000 for each occurrence;

General aggregate – \$2,000,000 per project;

Property damage - \$100,000 for each and \$200,000. for the aggregate for operations.

Contractor's automobile liability insurance (including contractual liability insurance as applicable to the Contractor's obligations under paragraph 6.20) with minimum limits as follows:

Automobile liability – \$1,000,000 per occurrence;

Workers compensation – Statutory coverage and \$1,000,000 Employers liability limit.

- (a) Any exclusion of so-called underground damage to pipes, collapse of structures or damage resulting from explosion or blasting, shall be deleted.
- (b) The policy shall provide completed operations coverage, and such coverage shall be maintained by the Contractor for a period of one year from the date of payment of the final amounts owed the Contractor by the Owner, whichever occurs first.

ARTICLE 14 - PAYMENTS TO CONTRACTOR AND COMPLETION

14.02 *Progress Payments*

A. Applications for Payments

1. Add a sentence after the second sentence stating, "Each payment request shall be accompanied with record drawings showing as-built conditions of all work requested during the pay period."

ARTICLE 16 - DISPUTE RESOLUTION

- 16.01 Any dispute arising under this agreement shall first be resolved by utilizing non-binding mediation, however should the dispute not be resolved by this method it shall be heard in the Superior Court of the County in which the owner resides, and the parties consent to jurisdiction and venue in that Court. The parties waive any defense they may have to lack of jurisdiction or improper venue and agree to have all disputes resolved in the Superior Court of the County in which the owner resides.

Not for Bid

SECTION 01001
GENERAL REQUIREMENTS

PART 1 - GENERAL

1.01 COMMENCEMENTS AND PROSECUTION OF WORK

- A. Contract time shall begin at which time the Owner will issue a written Notice to Proceed. The Contractor must commence construction within ten (10) days of issuance of a written Notice to Proceed. The Contractor shall maintain sufficient labor and supervision on the job until all items have been completed and the Engineer's Final Certification has been issued.

1.02 COOPERATION

- A. The General Contractor and Sub-Contractors shall cooperate with one another and with other Contractors doing related work and shall coordinate their work with the work of other trades and other Contractors so as to facilitate the general progress of the work. Each trade shall afford all other trades and all other Contractors every reasonable opportunity for the installation of their work and for storage of their materials.

1.03 SANITARY FACILITIES, TEMPORARY

- A. Do not allow any sanitary nuisances to be committed in or about work; enforce sanitary regulations of Local and State Health authorities.

1.04 SITE EXAMINATION OF EXISTING CONDITIONS

- A. The Contractor, in undertaking the work under this Contract, is assumed to have visited the premises and to have taken into consideration all conditions which might affect his work. No consideration will be given any claim based on lack of knowledge of existing conditions, except where the Contract Documents make definite provisions for adjustment of cost or extension of time due to existing conditions which cannot be readily ascertained.

1.05 SPECIFICATIONS EXPLANATION

- A. Attention is directed to the fact that the detailed specifications and separate sections may be written in short or abridged form. In regard to every section of the specifications and all parts thereof, mentioned therein or indications on the drawings or articles, materials, operations or methods require that the Contractor:
 - 1. Provide each item mentioned and indicated (of quality or subject to qualifications notes).
 - 2. Perform (according to conditions stated) each operation prescribed.
 - 3. Provide therefore all necessary labor, equipment and incidentals.

- B. Wherever in these specifications or on the drawings the words "directed", "required", "ordered", or words of like import are used, it shall be understood that the directions, requirements, permission or order of the Engineer is intended; and similar words "approved", "accepted", "satisfactory", or words of like import shall mean approved, acceptable to, or satisfactory to the Engineer.
- C. For convenience of reference and to facilitate the letting of Contracts or Sub-Contracts, these specifications are separated into titled sections. Such separation shall not, however, operate to make the Engineer an arbiter to establish limits to the Contracts between the Contractor and Sub-Contractors, nor shall such operation be interpreted as superseding normal union functions.
- D. Notwithstanding the appearance of such language in the various divisions of the specifications as "The Electrical Contractor", "The Roofing Contractor", etc., the Contractor is responsible to the Owner for the entire Contract and the execution of all work referred to in the Contract Documents.

1.06 STANDARD

- A. Wherever reference is made to the standard specifications of nationally known organizations and specific articles, sections, divisions, or headings are not given, such specifications shall apply in full. Standard specifications where included herein by abbreviation or otherwise shall form a part of this specification the same as if quoted in full.
- B. The Engineer may require, and the Contractor shall furnish if required to do so , certificates from manufacturers to the effect that the products or materials furnished by them for use in the work comply with the applicable specified requirements for the materials or products being furnished.

1.07 TELEPHONE, TEMPORARY

- A. Contractor shall install and maintain at his expense a job telephone for duration of the Contract.

1.08 TEMPORARY UTILITIES

- A. Contractor shall furnish water, electricity, and heating fuel necessary for construction. Contractor shall provide necessary temporary piping, faucets, valves, wiring, switches, outlets, etc., to carry services to the work. The Contractor shall make all temporary utilities connection for his own use and remove temporary services on completion of Contract.

1.09 WORK OUTSIDE OF THE PROPERTY LINE

- A. All work outside of the property line called for by the Contract Documents shall be performed by the Contractor and all cost for same shall be included in the Contract.

1.10 AS-BUILT DRAWINGS

- A. The Contractor shall, upon completion of the work, furnish a marked set of drawings showing field changes affecting the various mechanical trades, utilities and electrical, as actually installed and as specified under those sections of the specifications, and deliver them to the Engineer. Engineer will furnish prints to Contractor for marking.

1.11 LIQUIDATED DAMAGES

- A. Substantial Completion - If the Contractor neglects, fails or refuses to achieve Substantial Completion of the work by not later than 12 P.M. (Midnight), the Contractor shall pay to the Owner, Liquidated Damages in the amount of three hundred dollars (\$300.00) per calendar day for each and every day that the Contractor is in default after the date indicated on the Notice to Proceed.
- B. Final Completion - If the Contractor neglects, fails, or refuses to complete the work by not later than 12 P.M. (Midnight), the Contractor shall pay to the Owner, Liquidated damages, in the amount of three hundred dollars (\$300.00) per calendar day for each and every day that the Contractor is in default after the date indicated on the Notice to Proceed. Liquidated Damages for Substantial Completion and Final Completion are cumulative.
 - 1. The said amount is fixed and agreed upon by and between the Contractor and the Owner because of the impracticability and extreme difficulty of fixing and ascertaining the actual damages the Owner would in such an event sustain, and said amount is agreed to be the amount of damages which the Owner would sustain and said amount shall be retained from time to time by the Owner from current Progress Payment should the construction progress fall behind schedule.
 - 2. Time is of the essence of each and every portion of this Contract and of the specification wherein a definite and certain length of time is fixed for the performance of any act whatsoever; and where under the Contract an additional time is allowed for the completion of any work, the new time limit fixed by such extension shall be of the essence of this Contract.
 - 3. Extensions of time applies to Liquidated Damages only and shall be allowed only for conditions over which the Contractor has no control, such as acts of God, transportation strikes affecting delivery of materials or equipment which are used in the project, manufacturing strikes affecting the production of materials or equipment which are used in the project, and weather above and beyond the normal expected loss of time based on historical climatological conditions over the last 10 years. For any time requested over what should be expected based on historical climatological conditions the amount of rain or temperature must meet the following conditions. To get credit for delays due to temperature the temperature must be at a level that would prevent construction in accordance with the other sections in these specifications. In order to get credit for rain delay the rain event must be persistent for more than four hours during that day and rainfall must be in excess of 0.5" for that 4 hour period or more than 1" during the day.

1.12 MATERIALS PRIOR APPROVAL AND SUBSTITUTIONS

- A. Where items of equipment and/or materials are specifically identified herein by a manufacturer's name, model or catalog number, only such specific item may be used in the base bid, except as hereinafter provided.
- B. If Contractors wish to use items of equipment and/or materials other than those specifically identified in the Specifications, Contractor shall apply in writing to the Engineer for approval of substitution at least seven (7) days prior to opening of bids, submitting with his request for approval complete descriptive and technical data on the item(s) he proposes to furnish.

- C. Approved substitutions will be listed in an addendum issued to all General Contractors prior to opening of bids.
- D. Unless requests for changes in the Specifications are approved prior to the opening of bids, as defined above, the successful Contractor will be held to furnish specified items. After contract is awarded, changes in specifications will be made only as defined under "Substitution of Equipment".

1.13 SUBSTITUTION OF EQUIPMENT AND MATERIALS

- A. After execution of contract, substitution of equipment and/or materials other than those specifically named in the Contract Documents will be approved by the Engineer for the following reasons only:
 - 1. That the equipment or material is no longer available.
 - 2. That the equipment or material does not perform the function for which it was intended.
 - 3. That the equipment or material cannot be delivered due to conditions beyond the Contractor's control.
- B. To receive consideration, requests for substitutions must be in writing accompanied by documentary proof of equality, and difference in price and delivery, if any.
- C. In case of a difference in price, the Owner shall receive all benefit of the difference in cost involved in any substitutions, and the contract altered by change order to credit the Owner with any savings so obtained.

1.14 INSPECTING AND TESTING OF MATERIALS

- A. Wherever in these Contract Documents inspecting and testing of material is called for, the selection of bureaus, laboratories and/or agencies for such inspecting and testing shall be made by the Engineer, and the character of the test shall be stipulated by the Engineer. Documentary evidence satisfactory to the Engineer that the materials have passed the required inspection and tests must be furnished in quadruplicate to the Engineer by the bureau, agency or laboratory selected. Materials satisfactorily meeting the requirements of the inspection or tests shall be approved by the Engineer and the Contractor notified of the results. The cost of such inspecting and testing shall be paid for by the Contractor.

1.15 ON SITE TESTING AND INSPECTING

- A. Wherever in these Contract Documents testing or inspecting is called for, the selection of bureaus, laboratories and/or agencies for such testing or inspecting shall be made by the Engineer. Documentary evidence satisfactory to the Engineer that the materials have passed the required tests or inspection shall be furnished in quadruplicate to the Engineer. **The cost of such tests and inspection shall be paid for by the Contractor.**

1.16 MEASUREMENTS AND DIMENSIONS

- A. Before ordering materials or doing work which is dependent for proper size of installation upon coordination with site conditions, the Contractor shall verify all dimensions by taking measurements at the site and shall be responsible for the correctness of same. No consideration will be given any claim based on differences between the actual dimensions and those indicated on the drawings. Any discrepancies between the drawings and/or specifications and the existing conditions shall be referred to the Engineer for adjustment before any work affected thereby is begun.

1.17 SHOP DRAWINGS

- A. Shop drawings shall be dated and contain: Name of project; description and names of equipment, materials, and items; and complete identification of locations at which material or equipment is to be installed, reference to the section of the specifications where it is specified and drawings number, where shown. In addition to the above, the Shop drawings shall: (1) show complete information for checking and for fabrication, installation and erection, without reference to other drawings or note; (2) shall be of drafting line work and lettering that is easily readable under field conditions; (3) have plane oriented the same as plans on the Contract Drawings; (4) list grade, class, or strength of materials; (5) be checked and initialed by the suppliers drafting room checker; (6) be checked and coordinated with other phases of the work, by a person in the Contractor's employ who is experienced and qualified in the checking and coordination of shop drawings.
- B. Shop drawings shall not, after having been submitted, be later issued with revised or additional materials, except for items corrected during the checking by the Contractor or reviewed by the Engineer.
- C. The following notation will be used by the Engineer in his review.
 - 1. No exceptions taken. (If checked here, fabrication may be undertaken. Approval does not authorize change to contract sums unless stated in a separate letter or by change order.)
 - 2. Note markings. (If checked here, fabrication may be under taken. Contractor is to coordinate markings noted.)
 - 3. Revise and resubmit.
 - 4. Rejected.
 - 5. Engineer review is for conformance with the design concept of the project and compliance with the information given within the Contract Documents only. The Contractor is responsible for dimensions being confirmed and correlated at the site; for information that pertains solely to the fabrication processes or to means, method, techniques, sequence, and procedures of construction; and for coordination of the work of all trades.
 - 6. Failure to note a noncompliance will not prevent later rejection when the noncompliance is disclosed.

- D. Submission of Shop drawings shall be accompanied by a transmittal letter in duplicate, containing project name, Owner's project number, Contractor's name, and number of drawings, title and other pertinent data.
- E. The Contractor shall promptly submit to the Engineer, five copies for Architectural items and six copies for Engineering items, required by the Contract Documents in accordance with the aforesaid schedule so as to cause no delay in his work or in work of any other Contractor.
- F. For standard items not requiring special shop drawings for manufacture, submit six copies of manufacturer's product data showing illustrated cuts of the items to be furnished, scaled details, size dimensions, performance characteristics, capabilities, wiring diagrams, control and all other pertinent information.
- G. The Contractor shall: (1) check, coordinate, correct, stamp, date, and sign all copies of each drawing, and deliver them to the Engineer for his review; (2) identify the set of drawings he has checked; this set shall be shown by checked marks or correction that every item has been verified and with the requirements of the Contract Documents.

1.18 MAINTENANCE MANUAL

- A. Contractor shall, prior to completion of contract, deliver to the Engineer, three copies of manual, assembled and bound with a hard cover, for the Owner's guidance, full details for care and maintenance of visible surfaces and of equipment included in contract.
- B. Contractor shall, for this manual, obtain from subcontractor, literature of manufacturers relating to equipment, including motors; also furnish cuts, wiring diagrams, control diagrams, instruction sheets and other information pertaining to same that will be useful to Owner in overall operation and maintenance.
- C. Where the above described manuals and data are called for under separate sections of the specifications, they are to be included in the manual description in this article.

SECTION 01150
MEASUREMENT AND PAYMENT

PART 1 - GENERAL

1.01 QUANTITIES

- A. Quantities: Quantities listed in the Proposal are approximate only and are intended to serve as a guide in comparing bids, and may be increased or decreased without invalidating the unit price bid.
- B. Payment: Contractor shall be paid for actual in place quantities as determined by the Engineer field measurements.
- C. Discrepancies: In case of discrepancies between the figures shown in the unit prices and totals, the unit prices shall apply and the totals shall be corrected to agree with the unit price.

PART 2 - MEASUREMENT AND PAYMENT

2.01 DEMOLITION

- A. Measurement: Measurement shall be made on the basis of the unit that is found in the bid that is removed in accordance with the plans, specifications and bid documents.
- B. Payment: Payment will be made at the unit price stated in the contract. The linear footage prices stated in the bid shall include furnishing all labor, materials and equipment necessary to complete this item of work. Work shall include, but is not limited to, removal of existing water main, existing sewer force main, or other material that exist, where noted on the plans as being removed, and will not be used as part of this project, excavation, removal and disposal of material at an approved site, backfill, compaction and surface restoration. All material not used will be crushed and/or abandoned in place.

2.02 CONNECTIONS TO EXISTING WATERMAINS

- A. Measurement: Measurement shall be made on the basis of each connection made to an existing watermain.
- B. Payment: Payment shall be made on the basis of the unit price bid. Unit price bid shall include furnishing all materials, labor and equipment required to complete the connection. Work shall include, but not be limited to, all trenching and excavation, pressure testing, backfill, disinfection, surface restoration and cleanup, furnishing and installing tapping sleeves & valves if noted on the plans, cutting and removing existing pipe where necessary, all fittings, and other accessories required to complete the connection, removal and disposal of any piping, accessories or fittings required to make the connection in accordance with the plans and specifications.

2.03 DISCONNECTION & RECONNECTION OF EX. WATER SERVICE

- A. Measurement: Measurement shall be made on the basis of each disconnection and reconnection of an existing service made in accordance with the construction plans and specifications.
- B. Payment: Payment will be made on the basis of the unit price bid. Unit price bid shall include furnishing all materials, labor and equipment necessary to complete the connection of the existing service to the proposed water main. Work shall include, but not be limited to, trenching, excavation, disconnecting existing water service, furnishing and installing saddle, two inch valve, connection of existing water service to water main, backfill, pressure testing, disinfection, complete surface restoration and cleanup.

2.04 WATERMAINS

- A. Measurement: Measurement will be made along the centerline of the pipe trench and through fittings and specials. No deduction in length will be made for fittings or specials.
- B. Payment: Payment will be made on the basis of unit price bid per linear foot for a specific line size. Unit price bid shall include all materials, labor and equipment necessary to complete the installation of the watermain. Work shall include, but not be limited to, trenching and excavation, necessary shoring and sheeting, furnishing and installing pipe, tracer wire, marker tape, backfilling and compaction, concrete blocking, dewatering, bedding, pressure testing, disinfection, complete surface restoration and cleanup.

2.05 STEEL CASING FOR WATERMAINS

- A. Measurement: Measurement will be made on the basis of the linear feet of steel casing installed around water mains at the locations designated on the plans.
- B. Payment: Payment will be made at the unit price stated in the bid. Unit price bid shall include all materials, labor and equipment necessary to complete the installation of the steel casing. Work shall include, but not be limited to, trenching and excavation, necessary shoring and sheeting, bedding, furnishing and installing steel casing, bulkheads, casing spacers, backfill, compaction, complete surface restoration and cleanup.

2.06 GATE VALVES (WATER)

- A. Measurement: Measurement shall be made on the basis of each unit installed in accordance with the construction plans and specifications.
- B. Payment: Payment will be made at the unit price bid for a specific valve size. Unit price bid shall include furnishing all materials, labor and equipment necessary to complete the installation of the gate valve. Work shall include, but not be limited to, excavation, necessary shoring, sheeting, backfilling, concrete valve box collar, furnishing and installing gate valves, valve boxes, pressure testing, disinfection and complete surface restoration and cleanup.

2.07 DUCTILE IRON FITTINGS (WATER SYSTEM)

- A. Measurement: Measurement will be made on the basis of each ton of fittings installed based on weight of the fitting and accessory kit.
- B. Payment: Payment will be made at the unit price bid per ton of fittings installed in accordance with the plans and specifications. Price shall include all necessary labor, equipment and materials to complete the task. Work shall include, but not be limited to, furnishing the fitting, all bolts, accessories, trench excavation, joint restraints, thrust blocking, pressure testing, complete surface restoration and cleanup.

2.08 CONNECTION TO EXISTING SYSTEM (SEWER SYSTEM)

- A. Measurement: Measurement will be made based on the connection made to an existing sewer system.
- B. Payment: Payment shall be made on the basis of the unit price bid. Unit price bid shall include furnishing all materials, labor and equipment required to complete the connection. Work shall include, but not be limited to, all trenching, excavating, pressure testing, backfill, surface restoration and cleanup, cutting and removing existing pipe where necessary, fittings, pipe and other accessories required to complete the connection.

2.09 SEWAGE FORCE MAINS

- A. Measurement: Measurement will be made based on each linear foot of force main installed as measured along the centerline of the pipe trench through fittings. No deduction in length will be made for fittings.
- B. Payment: Payment will be made on the basis of unit price bid per linear foot for each specific line size. Unit price bid shall include all materials, labor and equipment necessary to complete the installation of the force main. Work shall include, but not be limited to, trenching, excavating, necessary shoring and sheeting, furnishing and installing pipe, tracer wire, marker tape, backfilling and compaction, concrete blocking, bedding, pressure testing, complete surface restoration and cleanup.

2.10 MANHOLES AND RISER SECTIONS

- A. Measurement: Measurement shall be made on the basis of each manhole installed. Each complete manhole will be measured from the invert to the top of the cast iron frame and cover. A deduction of six feet (6') for the standard manhole and a deduction for the height of the frame and cover will be made. The remainder will be considered additional riser section.
- B. Payment: Payment will be made for each manhole installed and for each additional vertical foot of riser installed at the unit prices stated in the bid. The unit price bid shall include all labor, materials and equipment necessary, including, but not limited to, excavation, shoring and sheeting, dewatering, gravel bedding, manholes, installing doghouse manholes over existing sewer systems, riser sections, castings,

inverts, stub outs, plugs, pipe connections, concrete manhole markers (if applicable), ram-nek, backfill, compaction and complete surface restoration.

2.11 DUCTILE IRON FITTINGS (SEWER SYSTEM)

- A. Measurement: Measurement will be made on the basis of each ton of fittings installed based on weight of the fitting and accessory kit.
- B. Payment: Payment will be made at the unit price bid per ton of fittings installed in accordance with the plans and specifications. Price shall include all necessary labor, equipment and materials to complete the task. Work shall include, but not be limited to, furnishing the fitting, all bolts, accessories, trench excavation, joint restraints, thrust blocking, pressure testing, complete surface restoration and cleanup.

2.12 SILT FENCE

- A. Measurement: Measurement shall be made on the basis of each linear foot of silt fence installed in accordance with the Plans, Specifications and "The Manual for Erosion and Sediment Control in Georgia".
- B. Payment: Payment will be in accordance with the price stated in the bid. The unit price shall include all equipment, labor and materials necessary to prevent erosion from the site. Work shall include, but not be limited to, excavation, trenching, post and fabric installation, backfill, daily inspection, re-installation of failed sections, sediment removal once its one half original height of fence. Once final stabilization has occurred, removal and disposal of fence and surface restoration of remaining disturbed area. All silt fence locations shall be approved by the Engineer prior to installation. No payment will be made for silt fence installed without approval of Engineer.

2.13 GRASSING

- A. Measurement: Measurement shall be made on the basis of the completed item in accordance with the construction plans and bid items.
- B. Payment: Payment will be made in accordance with the price stated in the bid. The unit price shall include, but is not limited to, furnishing all labor, materials and equipment necessary for the satisfactory growth of grass on all disturbed areas in accordance with plans and specifications. Work shall include, but not be limited to, furnishing all materials, fertilizer, soil samples, grass seed, raking, leveling, watering, maintenance and final surface restoration. Final payment will not occur until permanent grass is established.

2.14 MOBILIZATION

- A. Measurement: Measurement shall be made on the basis of establishing construction yard and significant progress in beginning the project. Mobilization will be limited to 5.0% of the bid price.
- B. Payment: Payment will be made at the price bid. The lump sum price shall include establishing the construction yard, beginning work and providing the owner with copies of all insurance certificates, bonds and meeting all general condition requirements.

SECTION 02210
SITE GRADING

PART 1 - GENERAL

1.01 QUALITY ASSURANCE

A. Reference Standards:

1. Standards of American Society for Testing and Materials:

ASTM-D-698 Moisture-Density Relations of Soils Using 5.5 lb. (2.5 KG) Hammer and 12 inch (304.8 mm) Drop

2. Methods of Sampling and Testing of American Association of State Highway and Transportation Officials (AASHTO), latest edition.

1.02 TESTING

A. All soil testing shall be performed by an Independent Testing Laboratory selected by the Engineer and paid for by the Contractor.

1.03 EXCESS EXCAVATED MATERIALS

A. Excess excavated materials shall be wasted off site by the Contractor at no expense to Owner, or as directed by the Engineer.

1.04 BORROW MATERIAL

A. Any borrow material required to accomplish all levels, lines and grades indicated shall be furnished by the Contractor at no expense to the Owner.

B. Borrow material shall be obtained from borrow pits off site.

C. The Contractor shall pay for all soil analysis for borrow material.

1.05 EXCAVATED MATERIAL

A. All material to be excavated shall be classified as earth.

1.06 UNSUITABLE BEARING MATERIALS

A. Should unsuitable bearing materials be encountered at levels indicated and found to have insufficient bearing values the Engineer may order the excavation carried to lower depths.

B. Compensation for the removal and/or replacement of unsuitable materials shall be in accordance with the General Conditions, Article 10.01.

C. Excavation of unsuitable bearing materials shall not proceed until the conditions have been observed by the Engineer and written approval has been given by the Owner.

PART 2 - EXECUTION

2.01 TOP SOIL

- A. Areas to be stripped shall first be scraped clean of all brush, weeds, grass, roots and other material.
- B. Remove topsoil from areas to be graded and stockpile in locations where it will not interfere with structures, roads or utility operations.
- C. Topsoil shall be free from subsoil, debris and stones larger than 2 inches in diameter. The stored topsoil shall be left in piles to be used for finished grading.
- D. Stockpiles shall be protected from contamination by undesirable foreign matter and shall be graded to shed water.

2.02 EXCAVATION

- A. Excavations shall be accomplished to bring surface to the levels, lines and grades as indicated.
- B. Excavated material to be used for fill or backfill material shall be stockpiled on the site as directed by the Engineer. Stockpiles shall be graded to shed water.

2.03 FILLING

- A. All fill material required to bring areas to the levels, lines and grades indicated shall be selected and approved materials from approved borrow areas.
- B. Sub-grades on which fill material is to be placed shall be scarified to a depth of not less than 4 inches by plowing or discing. A layer of suitable fill material, approximately 3 inches in depth, shall be spread over the scarified surface and compacted.
- C. Fill material shall be spread and compacted in successive uniform layers not exceeding 8 inches in depth (loose measure) until the total thickness of fill is completed.

2.04 COMPACTION

- A. Compaction required for material fill shall be 95% of Standard Proctor, maximum dry density as determined by the procedures of ASTM D-698. Fill areas shall be crowned and sloped to drainage ditches or as required to prevent ponding of surface water.
- B. Compaction by flooding of any material is not acceptable. In the event that any flooding takes place, the material and all adjacent softened material shall be removed and replaced with compacted fill at no cost to the Owner.

2.05 FINISH GRADE

- A. Distribute topsoil evenly to levels, lines and grades shown.
- B. Finish grade to be trimmed and raked true to line and grade to avoid surface ponding.
- C. Remove stone two inches or greater in diameter and debris from soil.
- D. Finish grade tolerance to +/- 0.05 foot for roadways and +/- 0.10 foot for other areas.

Not for Bid

SECTION 02221
TRENCH EXCAVATION, BACKFILL AND COMPACTION

PART 1 - GENERAL

1.01 SCOPE, STANDARDS & DEFINITIONS

- A. Work under this section shall consist of furnishing all materials, equipment and labor for excavation, trenching and backfilling for utility systems. "Utility systems" shall include underground piping and appurtenances for water distribution systems, storm water drains, sewage collection systems, force mains, spray irrigation system and all other pipes and appurtenances shown on the drawings.
- B. Applicable Standards and Reference
 - I. ASTM D2321 Soil Classification and Restrictions
 - a. Class IA = Manufactured crushed stone, shell, crushed slag or rock, open graded, clean, large voids, contains no fines, can allow sand migration to create excessive settling. Suitable as drainage blanket.
 - b. Class IB = Manufactured aggregate dense graded, clean, crushed stone with sand and gradation present. Closer void so little migration of sand, little fines. Minimal migration of sand. Suitable as drainage blanket.
 - c. Class II = Coarse grained soils and sand, graded gravel and sandy mix, minimal migration of silt or sand, use as drainage blanket and drains limited.
 - d. Class III = Coarse grain sand with fines, silty gravel, gravel-sand-silt mixture, clayey gravels, silty sand mixture. Not to be used in the presence of water.
 - e. Class IVA = Fine grain soils, inorganic, Inorganic silts and very fine sand, silty clayey fine sands, inorganic clay with minor plasticity. Lean clay. Use only where no water exists and shallow fills.
 - f. Class IVB = Fine Grained soils inorganic, micaceous fine sand, silty soil, fat clay, clay with high plasticity. Use requires geotechnical evaluation.
 - g. Class V = Organic soils, clay and silt with organics. No permitted use other than top 6" outside roadways for soil amendment for grassing.

1.02 EXISTING UTILITIES

- A. Before opening trenches, the Contractor shall examine all available records and explore for the location of all sub-surface pipes, valves or other structures and reference such locations on the surface.
- B. In opening trenches, every effort shall be made not to interfere with these utilities structures. Expose existing piping by hand before excavating by machine. Excavate existing utilities sufficiently in advance of pipe laying to determine crossing arrangement. Slight deviations may be permitted in order to clear such structures. The Contractor shall be entirely responsible for the preservation of all underground or overhead utility lines and structures, such as gas, water, sewer lines, telephone conduit, power lines, etc., and shall replace, adjust or repair, without additional compensation, any such lines damaged or interfered with as a result of this construction.

- C. Schedule work to keep roads and utilities in usable condition; coordinating all operation with the Owner to avoid inconvenience insofar as practicable.

1.03 EXCAVATED MATERIAL

- A. All material to be excavated shall be classified as earth.

1.04 BORROW MATERIAL

- A. Any borrow material required to accomplish all levels, lines and grades indicated shall be furnished by the Contractor at no expense to the Owner.
- B. Borrow material shall be obtained from borrow pits off site.
- C. The Contractor shall pay for all soils analysis for borrow material.

1.05 TESTING

- A. All soil testing shall be performed by an Independent Testing Laboratory selected by the Engineer and paid for by the Contractor.

1.06 QUALITY ASSURANCE

- A. All excavation within the rights of way of city streets and county, State or Federal roadways, shall be backfilled in accordance with the then prevailing requirements of the Georgia Department of Transportation, Highway Division.
- B. Reference Standards: Methods of Sampling and Testing of American Association of State Highway and Transportation Officials (AASHTO).

PART 2 - EXECUTION

2.01 GENERAL EXCAVATION

- A. The Contractor shall do all excavation of whatever substances encountered to depth shown on plans. Excavated materials not required for fill or backfill shall be removed from site as directed by the Engineer.
- B. Contractor is to excavate to provide 3 foot minimum cover over utility.
- C. Excavation for manholes and other accessories to have 12 inches minimum and 24 inch maximum clearance on all sides.
- D. Excavation shall not be carried below the required level.
- E. Where excavation is carried below grades indicated, the Contractor shall refill same to the proper grade with compacted earth or stone, or as directed by the Engineer.
- F. Banks of trenches shall be vertical.


- G. Width of trench shall be as shown on the plans. The bottom of trench for sewers and culverts shall be rounded so that an arc of the circumference equal to 0.6 of the outside diameter of the pipe rests on undisturbed soil.
- H. Bell holes shall be excavated accurately to size by hand.

2.02 UNSUITABLE BEARING MATERIALS

- A. Should unsuitable bearing materials be encountered at levels indicated and found to have insufficient bearing values the Engineer may order the excavation carried to lower depth.
- B. Compensation for the removal and/or replacement of unsuitable bearing materials shall be in accordance ASTM D2321 requirements.
- C. Excavation of unsuitable bearing materials shall not proceed until the conditions have been observed by the Engineer and written approval is given by the Owner.

2.03 PIPE BEDDING

- A. The following detail provides trench & pipe zone terminology.



PIPE BEDDING DETAIL
N.T.S.

- B. The trench floor should be constructed to provide firm, stable, and uniform support for the full length of the pipe. This can be accomplished by bringing the entire trench floor level grade and then creating bell holes at each joint to permit proper joint assembly, alignment and support. Portions of the trench that are excavated below grade should be returned to grade and compacted as required to provide proper support. If native trench soil is not suitable for pipe bedding, the trench should be over excavated and refilled with suitable foundation material either local sandy material compacted to 90% Std. Proctor or #57 stone depending on the presence of water and, as approved by the engineer. Bedding material shall be Class IB or II as defined in ASTM D2321. Large rocks or hard material should not be contained in the bedding area (minimum of 4") below the pipe.
- C. The most important factor in assuring proper pipe-soil interaction is the haunching material and its density. This material provides the majority of the support that the pipe requires to function properly in regards to deflection and performance. The haunching material shall be placed and compacted under the pipe haunches as shown in the detail above. Proper control should be exercised to avoid deflecting the pipe from proper alignment. The same material that is used for bedding should be used for haunching and compacted to the same standards. Haunching material shall be Class IB or II as defined in ASTM D2321.
- D. Initial backfill, as shown in the detail above, shall be accomplished with suitable, compactable material and compacted in 6" layers. Material shall meet the requirements of Class IB II or III as restricted in ASTM D2321.
- E. Final Backfill will be accomplished by placing material in 12" lifts and compacting to a level determined by the final use of the area above the pipe. Final backfill in roadways shall require placement of suitable Class IA, IB, II and III backfill material, placed in 12" lifts and compacted to 100% standard proctor (ASTM Test D-698). Final Backfill outside of roadways shall be Class II, III or IVA and lightly compacted to avoid settling in the future. The top 6" of the final backfill, outside of roadways, shall be suitable for establishing a final grassed surface.
- F. Material used in the "trench & pipe zone" shall be restricted as per the limitations and restrictions as outlined in ASTM D2321

2.04 BRACING AND SHORING

- A. The Contractor shall do all bracing, sheeting and shoring necessary to perform and protect all excavations as required for safety.
- B. Sheeting driven alongside the pipe should be cut off and left in place to an elevation 1.5 feet above the top of the pipe.
- C. All other sheeting shall be removed as directed by the Engineer.

2.05 DEWATERING FOR EXCAVATION

- A. The Contractor shall pump or remove any water accumulated in any excavated area and shall perform all work necessary to keep excavations clear of water while foundations, structures or any masonry are being constructed or while pipe is being laid.
- B. No structure or pipe shall be laid in water, and water shall not be allowed to flow over or rise upon any concrete or masonry or piping until same has been inspected and the mortar or joint material has cured.
- C. No extra compensation will be allowed for removal of water.
- D. All water pumped or bailed from the trenches or other excavation shall be conveyed to a point of discharge where it will neither cause a hazard to the public health, nor damage to the public or private property, or to work completed or in progress.

2.06 BACKFILL

- A. The soil at the sides of a pipe and above it is the backfill.
- B. Prior to backfilling any excavation, all piping and structures shall be observed by the Engineer.
- C. After pipes have been tested and approved, backfilling shall be done with approved material free from large clods or stones.
- D. Backfill shall be placed in uniform layers, four inches thick, on both sides of the pipe and thoroughly compacted with pneumatic or hand tampers. The backfill shall be brought up uniformly on both sides of the pipe and compacted to an elevation of one foot above the top of the pipe, after which the fill shall be placed in eight inch lifts. No rock will be allowed in the backfill within a distance of one foot from the pipe, and rock larger than six inches in the greatest dimension will not be permitted in any part of the trench or backfill.
 - 1. Backfill shall be compacted to not less than 95% of the maximum dry weight per cubic foot as determined by AASHTO Method T-99 (Standard Proctor Test).
 - 2. The top 18 inches of backfill under any paved area shall be compacted to 100% Standard Proctor.
 - 3. Water settling will not be permitted in clay soils. It may be required at the option of the Engineer in sandy soils.

2.07 REPLACING PAVEMENTS

- A. Subgrades shall be compacted with a mechanical tamper.
- B. The minimum width of replaced concrete pavements shall be 4 feet at interiors and 6 feet at joints and constructed as shown on Standard Details. Avoid cutting pavements at joints; if unavoidable, reconstruct same as original joint. Depth shall be equal to the original thickness. Existing pavements edges shall be cut vertical.

- C. Use high-early-strength cement if road is to be opened in less than 3 days.
- D. The minimum width of replaced bituminous pavements shall be 3 feet with 8 inch concrete patch. The existing pavement shall be cut vertically and horizontally to a straight line. The 8 inch concrete patch shall be minimum 3,000 psi concrete containing black dye and shall be flush with the existing pavement.

Not for Bid

SECTION 02415
SITE DEMOLITION

PART 1 - GENERAL

1.1 DESCRIPTION:

This section specifies demolition and removal of buildings, portions of buildings, utilities, other structures and debris from trash dumps shown.

1.2 RELATED WORK:

- A. Demolition and removal of roads, walks, curbs, and on-grade slabs outside buildings to be demolished:
- B. Safety Requirements: GENERAL CONDITIONS Article, ACCIDENT PREVENTION.
- C. Disconnecting utility services prior to demolition: Section 01 00 00, GENERAL REQUIREMENTS.
- D. Reserved items that are to remain the property of the Owner.
- E. Asbestos Removal: See Hazardous Material Sections of General Conditions
- F. Lead Paint: See Hazardous Material Sections of General Conditions
- G. Environmental Protection: See Erosion and Sedimentation Control Specification
- H. Construction Waste Management: See General Requirements Specification

1.3 PROTECTION:

- A. Perform demolition in such manner as to eliminate hazards to persons and property; to minimize interference with use of adjacent areas, utilities and structures or interruption of use of such utilities; and to provide free passage to and from such adjacent areas of structures. Comply with requirements of GENERAL CONDITIONS Article, ACCIDENT PREVENTION.
- B. Provide safeguards, including warning signs, barricades, temporary fences, warning lights, and other similar items that are required for protection of all personnel during demolition and removal operations.
- C. Maintain fences, barricades, lights, and other similar items around exposed excavations until such excavations have been completely filled.
- D. Provide enclosed dust chutes with control gates from each floor to carry debris to truck beds and govern flow of material into truck. Provide overhead bridges of tight board or

prefabricated metal construction at dust chutes to protect persons and property from falling debris.

- E. Prevent spread of flying particles and dust. Sprinkle rubbish and debris with water to keep dust to a minimum. Do not use water if it results in hazardous or objectionable condition such as, but not limited to; ice, flooding, or pollution. Vacuum and dust the work area daily.
- F. In addition to previously listed fire and safety rules to be observed in performance of work, include following:
 - 1. No wall or part of wall shall be permitted to fall outwardly from structures.
 - 2. Maintain at least one stairway in each structure in usable condition to highest remaining floor. Keep stairway free of obstructions and debris until that level of structure has been removed.
 - 3. Wherever a cutting torch or other equipment that might cause a fire is used, provide and maintain fire extinguishers nearby ready for immediate use. Instruct all possible users in use of fire extinguishers.
 - 4. Keep hydrants clear and accessible at all times. Prohibit debris from accumulating within a radius of 4500 mm (15 feet) of fire hydrants.
- G. Before beginning any demolition work, the Contractor shall survey the site and examine the drawings and specifications to determine the extent of the work. The contractor shall take necessary precautions to avoid damages to existing items to remain in place, to be reused, or to remain the property of the Owner; any damaged items shall be repaired or replaced as approved by the Resident Engineer. The Contractor shall coordinate the work of this section with all other work and shall construct and maintain shoring, bracing, and supports as required. The Contractor shall ensure that structural elements are not overloaded and shall be responsible for increasing structural supports or adding new supports as may be required as a result of any cutting, removal, or demolition work performed under this contract. Do not overload structural elements. Provide new supports and reinforcement for existing construction weakened by demolition or removal works. Repairs, reinforcement, or structural replacement must have Resident Engineer's approval.

H. The work shall comply with the requirements of the Erosion and Sediment Control Specification and other sections of this specification

I. The work shall comply with the requirements of GENERAL REQUIREMENTS

1.4 UTILITY SERVICES:

A. Demolish and remove outside utility service lines shown to be removed.

B. Remove abandoned outside utility lines that would interfere with installation of new utility lines and new construction.

PART 2 - PRODUCTS (NOT USED)

PART 3 – EXECUTION

3.1 DEMOLITION:

A. Completely demolish and remove buildings and structures, including all appurtenances related or connected thereto, as noted below:

1. In accordance with Building Demolition Specification

2. As required for installation of new utility service lines.

3. To full depth within an area defined by hypothetical lines located 1500 mm (5 feet) outside building lines of new structures.

B. Debris, including brick, concrete, stone, metals and similar materials shall become property of Contractor and shall be disposed of by him daily, off the project site to avoid accumulation at the demolition site. Materials that cannot be removed daily shall be stored in areas specified by the Resident Engineer. Break up concrete slabs below grade that do not require removal from present location into pieces not exceeding 600 mm (24 inches) square to permit drainage. Contractor shall dispose debris in compliance with applicable federal, state or local permits, rules and/or regulations.

C. Remove and legally dispose of all materials, other than earth to remain as part of project work, from any trash dumps shown. Materials removed shall become property of contractor and shall be disposed of in compliance with applicable federal, state or local permits, rules and/or regulations to a permitted site. All materials in the indicated trash dump areas, including above surrounding grade and extending to a depth of 1500mm (5feet) below surrounding grade, shall be included as part of the lump sum compensation for the work of this section. Materials that are located beneath the surface of the surrounding ground more than 1500 mm (5 feet), or materials that are discovered to be

hazardous, shall be handled as unforeseen. The removal of hazardous material shall be referred to Hazardous Materials specifications.

- E. Remove existing utilities as indicated or uncovered by work and terminate in a manner conforming to the nationally recognized code covering the specific utility and approved by the Resident Engineer. When Utility lines are encountered that are not indicated on the drawings, the Resident Engineer shall be notified prior to further work in that area.

3.2 CLEAN-UP:

On completion of work of this section and after removal of all debris, leave site in clean condition satisfactory to Resident Engineer. Clean-up shall include off the off site disposal of all items and materials not required to remain property of the Owner as well as all debris and rubbish resulting from demolition operations.

Not for Bid

SECTION 02540
EROSION CONTROL

PART 1 - GENERAL

1.01 The work specified in this Section consists of furnishing, installing and maintaining temporary erosion controls and temporary sedimentation controls.

1.02 DEFINITIONS

- A. Temporary erosion controls shall include grassing, mulching, watering and reseeding on-site sloped surfaces, providing berms at the top of the slopes and providing interceptor ditches at the ends of berms and at those locations which will ensure that erosion during construction will be either eliminated or minimized.
- B. Temporary sedimentation controls shall include silt dams, traps, barriers and appurtenances at the toe slopes.

PART 2 - MATERIALS

2.01 Hay bales shall be clean, seed free cereal hay type, securely bound.

2.02 Netting shall be 1/2 inch, galvanized steel chicken wire mesh.

2.03 Filter stone shall be crushed stone conforming to the Department of Transportation - State of Georgia-Standard Specifications – Construction of Transportation Systems - 2013 - Table 800.01, Size Number 3.

2.04 Rolled Erosion Control Products:

- A. Mulch Control Netting. A planar woven natural fiber or extruded geosynthetic mesh used as a temporary degradable rolled erosion product anchor loose fiber mulches
Max. Gradient = 5:1 (H:V) in slope application
C Factor = ≤ 0.10 @ 5:1 in slope application
Max Shear stress 0.25 lb/sf in channel application
Min. Tensile Strength ultra short (3 mo) and short (12 mo) term = 5 lbs/ft
Min Tensile Strength extended term ((24 mo) = 25 lbs/ft
- B. Open Weave textile. A temporary degradable rolled erosion control product composed of processed natural or polymer yarns woven into a matrix, used to provide erosion control and facilitate vegetation establishment.
Max. Gradient = 3:1 (H:V) in slope application
C Factor = ≤ 0.15 @ 3:1 in slope application
Max Shear stress = 1.5 lb/sf in channel application
Min. Tensile Strength ultra short (3 mo) and short (12 mo) term = 50 lbs/ft
Min Tensile Strength extended term ((24 mo) = 100lbs/ft

- C. Erosion Control Blanket. A temporary degradable rolled erosion control product composed of processed natural or polymer fibers mechanically, structurally or chemically bound together to form a continuous matrix to provide erosion control and facilitate vegetation establishment.

Netless Rolled Erosion Control Blankets:

Max. Gradient = 4:1 (H:V) in slope application

C Factor = ≤ 0.10 @ 4:1 in slope application

Max Shear stress = 0.5 lb/sf in channel application

Min. Tensile Strength ultra short (3 mo) and short (12 mo) term = 5 lbs/ft

Single-net Erosion Control Blankets:

Max. Gradient = 3:1 (H:V) in slope application

C Factor = ≤ 0.15 @ 3:1 in slope application

Max Shear stress = 1.5 lb/sf in channel application

Min. Tensile Strength ultra short (3 mo) and short (12 mo) term = 50 lbs/ft

Min Tensile Strength extended term ((24 mo) = 100lbs/ft

Double-net Erosion Control Blankets:

Max. Gradient = 2:1 (H:V) in slope application

C Factor = ≤ 0.2 @ 2:1 in slope application

Max Shear stress = 1.75 lb/sf in channel application

Min. Tensile Strength ultra short (3 mo) and short (12 mo) term = 75 lbs/ft

- D. Turf Reinforcement Mat. A rolled erosion control product composed of non-degradable synthetic fibers, filaments, nets, wire mesh, and/or other elements, processed into a permanent, three dimensional matrix of sufficient thickness. TRMs, which may be supplemented with degradable components, are designed to impart immediate erosion protection, enhance vegetation establishment and provide long term functionality by permanently reinforcing vegetation during and after maturation. These products are typically used in hydraulic applications such as high flow ditches, channels, steep slopes, stream banks, and shorelines, where erosive forces may exceed the limits of natural, unreinforced vegetation.

Slope Application max gradient = 0.5:1 (H:V)

Channel Application Max Shear Stress: 5A, B, C as defined in FHWA guidelines

5A = 6.0 lb/sf, 5B = 8.0 lb/sf, 5C = 10.0 lbs/sf

Min. Tensile Strength: 5A, B, C as defined in FHWA guidelines

5A = 125.0 lb/ft, 5B = 150.0 lb/ft, 5C = 175.0 lbs/ft 5A, B, C as defined in FHWA guidelines

PART 3 - EXECUTION

3.01 SEDIMENTATION CONTROL

- A. Silt dams, traps, barriers, and appurtenances shall be installed and shall be maintained in-place for duration of construction.
- B. Hay bales shall be staked with two (2) 1 x 4 wood stakes per bale driven eighteen (18) inches into the ground and finishing flush with the top of the bale.
1. Install two (2) stakes per bale with the long dimension of the stakes parallel to the long dimension of the bale.

2. Where bales are installed in multiple layers the bales shall be installed with vertical joints staggered and two (2) 1 x 4 wood stakes per bale driven through all layers, full from top of bale to eighteen inches into the ground.
- C. Hay bales which have deteriorated shall be replaced with new materials.
 - D. Erosion and sedimentation controls shall be maintained in a condition which will retain unfiltered water.
 - E. The Contractor shall construct the sedimentation ponds and control devices prior to clearing and grubbing the site to insure complete silt control. When the silt or the debris level is greater than 1 foot above the bottom of the pond, the Contractor shall remove the silt or debris to restore the proper elevation for the bottom of the pond.
 - F. The Contractor shall have all erosion and sedimentation control devices in service and operating properly prior to completion and final acceptance of the contract.
 - G. Two widths of silt fence are available, Type A or C (36" height) and Type B (22" height). In order to determine which to use, the project duration, slope gradient, and slope length must be known (See Table 6-13.1 below). Approved silt fence fabrics are listed in the Georgia Department of Transportation list #36. The manufacturer shall have either an approved color mark yarn in the fabric or label the fabricated silt fence with both the manufacturer and fabric name every 100 feet.

TABLE 6-13.1

Land Slope	Maximum Slope Length Behind Fence
<u>Percent</u>	<u>feet</u>
<2	100
2 to 5	75
5 to 10	50
10 to 20	25
>20	15

All silt fence must meet the minimum standards set forth in Section 171- temporary Silt Fence, of the Department of Transportation, State of Georgia, Standard specification, current edition. See Table 6-13.5 for current Georgia DOT silt fence specifications.

3.02 EROSION CONTROL BLANKET INSTALLATION

- A. Prepare a stable and firm soil surface free of rocks and debris. Apply soil amendments as necessary to prepare seedbed. Place fertilizer, water, seed in accordance with manufacture and specification recommendations. Unroll parallel to the primary direction of flow. Ensure that the product maintains intimate contact with the soil over the entire installation. Do not stretch or allow material to bridge over the surface. Staple/stake blanket to soil such that each staple/stake is flush with the underlying soil. Install anchor trenches, seams, and terminal ends as specified.
- B. The Upslope Trench, Seams, and Terminal Ends may be secure by anchor trench, checks, slots, or staples as outlined in Erosion Control technology Council (ECTC) standards for upslope security.

- C. Staple installation shall be at a rate of 1.7 staples per square yard minimum. Sandy or silty soils may require more. Wet installations may require a more density securing.
- D. If seaming method is used seams shall overlap at least 4" and staples must be placed at sufficient spacing to avoid separation.
- E. Staples must be placed at 4"x 4" spacing on check slots and check seams.
- F. Consecutive rolls shall have overlaps of at least 6" and secured with staples every 1foot.

3.03 RESPONSIBILITY

- A. The Contractor shall be solely responsible for insuring that no silt or debris leaves the immediate construction site. Any silt or debris that does leave the immediate site shall be cleaned up and the area disturbed shall be returned to its natural state as directed by the Engineer at the Contractor's expense.
- B. The Contractor has the option to submit additional control measures in the form of shop drawings.

Not for Bid

SECTION 02556
WATER DISTRIBUTION SYSTEM

PART 1 GENERAL

1.01 REFERENCE STANDARDS

A. American Water Works Association (AWWA):

C500 Gate Valves 3" - 48" for Water and Other Liquids

C502 Dry-Barrel Fire Hydrants

C600 Installation of Cast Iron Water Mains

C601 Disinfecting Water Mains

C800 Threads for Underground Service Line Fittings

C900 Polyvinyl Chloride Pipe

B. American National Standards Institute (ANSI):

A-21.10 Gray-Iron and Ductile Iron Fittings, 2"-48" for Water and Other liquids

A-21.11 Rubber Gasket Joints for Cast Iron and Ductile Iron Pressure Pipe Fittings

A-21.4 Cement Mortar Lining for Cast Iron and Ductile Iron Pipe and Fittings for Water

A-21.51 Ductile Iron Pipe, Centrifugally Cast in Metal or Sand-Lined Molds, for Water or Other Liquids

B-18.2 Square and Hex-Head Bolts and Screws

C. American Society of Testing and Materials (ASTM):

A-47 Malleable Iron Castings

A-48 Gray Iron Casting

A-88 Seamless Copper Water Tube

A-240 Chromium and Chromium-Nickel Stainless Steel Plate Sheet and Strip for Fusion-Welded Uni-fired Pressure Vessels

A-307 Low Carbon Steel Externally and Internally Threaded Standard Fasteners

D-1784 Rigid Poly (Vinyl chloride) Compounds, and Chlorinated Poly (Vinyl Chloride) Compounds

D-2239 Polyethylene (PE) Plastic Pipe (SDR-PR)

D-2241 Poly Vinyl Chloride (PVC) Plastic Pipe (SDR-PR and Class T)

D-3139 Joints for Plastic Pressure Pipe Using Flexible Elastomeric Seals

D. Rule for Safe Drinking Water, Georgia State EPD: Chapter 391-3-5

1.02 DESCRIPTION

- A. All valves of the same type shall be from a single manufacturer. Parts for valves of the same type and size shall be interchangeable. Spare parts shall be furnished where required in the payment items. Special tools required for repacking or disassembling valves shall be provided.
- B. All valves shall open left (counter-clockwise).

1.03 SUBMITTALS

- A. Six copies of manufacturer's drawings and catalog cuts of the following items shall be submitted for approval of the Design Engineer:
 - 1. Pipe
 - 2. Fittings
 - 3. Joints
 - 4. Hydrants
 - 5. Valves

1.04 PRODUCT DELIVERY, STORAGE AND HANDLING

- A. Materials delivered to site shall be inspected for damage, unloaded and stored with the minimum of handling. Store materials on site in enclosures or under protective coverings. Store plastic piping and rubber gaskets under cover and protect from exposure to direct sunlight. Store materials above ground. Interior of pipe and fittings shall be kept free of dirt and debris.
- B. Pipe, fittings, valves, hydrants and other accessories shall be handled to insure delivery to the point of installation in sound undamaged condition. If coatings or linings of pipe or fittings are damaged, such pipe or fittings shall be removed from the site and new materials furnished. Pipe shall not be dragged. Rubber gaskets that are not installed immediately shall not be left in the sunlight, but shall be stored under cover and protected from exposure to direct sunlight.

PART 2 - PRODUCTS

2.01 POLYVINYL CHLORIDE PIPE (PVC)

- A. Polyvinyl chloride water main pipe shall conform to Designation ASTM D2241 and shall consist of Type I, Grade 1 PVC compound conforming to ASTM D1784. All pipe larger than 2" shall meet the requirements of AWWA C900, "Poly Vinyl Chloride (PVC) pressure pipe." All pipe shall be class 200 pipe and shall meet the requirements of DR14. The standard laying length shall be 20 ft.

±1 inch. Two inch PVC pipe shall be SDR 21, 200 PSI pressure class, iron pipe standard O.D., with slip joint.

- B. Pipe shall have integral bell and spigot joints. Provisions shall be made for contraction and expansion at each joint with an elastomeric ring. Threaded or solvent welded type joints shall not be used. Bell end pipe and couplings with elastomeric gaskets shall meet the requirements of ASTM 3139.
- C. The Contractor shall install a continuous run of 14 gauge copper tracer wire with underground coating above the top of the PVC pipe 12 inches above the pipe but no deeper than 48 inches below finished grade. The tracer wire shall be suitable for detection with metal pipe location equipment.
- D. Pipe shall carry National Sanitation Foundation (NSF) seal and be factory marked with manufacturer's identification, pipe size, material and pressure rating.

2.02 DUCTILE IRON PIPE

- A. Ductile iron pipe shall conform with the requirements of ANSI Standard A21.51 and shall be of the thickness classes shown below:

NORMAL PIPE DIAMETER	THICKNESS CLASS
4"	51
6"	50
8"	50
10"	50
12"	50
16"	50
8"	50
24"	50

Class designations for the various classes of pipe shall be painted on the outside of each joint of pipe. Weights shall be conspicuously painted in white on each joint of pipe after the bituminous coating has hardened.

- B. All joints shall have the same pressure rating as the pipe with which it is used. Joints shall be rubber gasketed push on or mechanical joint. Joints shall meet the requirements of ANSI A21.11.
- C. Pipe shall be coated inside and out with one mil. thick bituminous coating conforming to ANSI A21.4. The interior shall be lined with a cement mortar lining conforming to ANSI/AWWA C104/A21.4.

2.03 GALVANIZED STEEL PIPE

- A. This pipe and fittings shall conform to the requirements of ASTM A120. The pipe shall be "standard weight", unless otherwise specified.

2.04 PLASTIC TUBING

- A. Plastic pipe shall conform to all the requirements of the "Specifications for Polyethylene (PE) Plastic Pipe (ADR-PR)", as they apply to PE 3306 of ASTM D2239.
- B. The hydrostatic design stress shall be 630 psi for water at 23° centigrade (73.4° F) and 500 psi for water at 37.8° C (100° F).
- C. The polyethylene extrusion compound from which the pipe is extruded shall meet the requirements of Type III, Grade 3, Class C material as described in "Specification for Polyethylene Molding and Extrusion Materials", ASTM D1248, except that melt index shall be determined under a higher temperature than any of the conditions as listed in Section 6(b) of "Method of Test for Measuring Flow Rates of Thermoplastics by Extrusion Plastometer", ASTM D1238. The test condition shall be the same as for condition J, except that the temperature shall be 310° C (590° F), with a load of 12-5 kilograms. Under these conditions the resin shall extrude at a maximum rate of 0.25 grams per ten (10) minutes. The pipe shall be homogeneous throughout and free of visible cracks, holes, foreign inclusions or other defects. The pipe shall be uniform in color, capacity, density, and other physical properties.
- D. The size, the type of plastic pipe material, dimension ratio, commercial standards with which the pipe complies, the manufacturer's name and the National Sanitation Foundation (NSF) seal of approval, shall be conspicuously marked on the outside of the pipe at intervals of not more than five (5) feet.

2.05 FITTINGS

- A. Ductile iron mechanical joint fittings shall conform to the requirements of ANSI A21.10 or ANSI A21.53. The fittings shall be of the lightest class conforming to the pressure rating of the pipe lines in which they are installed, in no case shall the fittings be lighter than class 200.
- B. Fittings for galvanized steel pipe shall be malleable iron conforming to ANSI B16.3 except the nipples and couplings shall be the same material as the pipe. All fittings shall be hot-dip galvanized in accordance with ASTM A120.
- C. The mechanical joint shall meet requirements of ANSI A21.11 and shall have the same pressure rating as the fitting of which it is a part.
- D. Fittings shall be coated inside and out with one mil. thick bituminous coating conforming to ANSI A21.4.

2.06 HYDRANTS

- A. All fire hydrants shall conform to AWWA C502.
- B. All fire hydrants shall have a 6" mechanical joint in-let connection and be equipped with a 5-1/4 inch valve, two 2-1/2 inch hose nozzles and one 4-1/2 inch pumper connection, all with ANSI (National) standard threads. Operating nuts shall be 1-1/2 inch, pentagon type.

- C. All fire hydrants shall be equipped with "O" ring type stem seals.
- D. All fire hydrants shall be designed for 150 psi working pressure and 300 psi test pressure.
- E. All fire hydrants shall be equipped with a 6" gate valve, complying with other sections of the specifications, installed on the fire hydrant lead between the hydrant and the main.
- F. The Contractor shall paint the hydrant with XO-14 Tractor Red (Federal Safety Color) paint.
- G. All fire hydrants shall be designed such that clockwise rotation of the stem closes the valve and counterclockwise rotation opens the valve. Hydrant covers shall have the word "Open" and an arrow showing the proper rotation of the operating nut cast in or permanently attached.
- H. An independent drain shall be provided, completely draining the hydrant after use. The drain shall be activated to the open position by the closing of the hydrant valve. The drain rod shall be easily cleaned. The drain shall have a protective shield integral with the hydrant base to minimize clogging and prevent undermining.
- I. All working parts of the hydrant shall be easily removed for inspection or servicing without digging or the use of hoists or derricks or special tools. The hydrant cover and stand pipe shall be removable without requiring the water to be shut off.
- J. Each fire hydrant shall be equipped with a ground line mounted breakaway flange and cast iron safety stem coupling specially designed so that upon sustaining severe impact the hydrant will shear off at the ground line without loss of water in the main.
- K. All fire hydrants shall be Mueller standard or equal as approved by the City Inspector.

2.07 METERS

- A. All meters shall be approved first line product of recognized manufacturer and shall be compatible with the meter reading system currently being used by the Owner.
- B. Meters, meter materials and meter test shall conform to applicable AWWA Specifications and shall meet or exceed current AWWA Specifications.
- C. Each meter shall have manufacturers serial number on the lid.
- D. All body parts as cases, boxes and lids shall be of bronze composition.
- E. Meters shall be split case, positive displacement type.
- F. The register shall read in U.S. Gallons and shall be hermetically sealed and driven by permanent magnets.

2.08 METER BOXES

- A. The meter box shall be the approved standard product used by the City of Hinesville, Georgia.
- B. They shall be rectangular and of adequate dimension to accommodate the specified meters.
- C. Boxes shall have cast iron or heavy plastic covers labeled "WATER METER".
- D. Boxes for 5/8" by 3/4" meters shall have inside width not less than 10 inches, inside length not less than 15 inches and overall height not less than 12 inches.
- E. Boxes shall be designed and built to withstand traffic loads typical of yard installations.

2.09 VALVES

- A. All valves smaller than 12" shall be gate valves. All valves 12" and larger shall be butterfly valves.
- B. All valves 2" in diameter and smaller shall be constructed of brass or bronze except that the hand wheel which shall be of malleable iron construction with screwed ends. All valves 2-1/2" in diameter and larger shall have flanged ends for interior service and mechanical joints for buried service unless otherwise approved. They shall be iron body, bronze mounted, except that in the smaller sizes the valves may be all bronze.
- C. Gate Valves:
 - 1. Gate valves smaller than three inches shall meet the requirements of Fed. Spec. WW-V-54, Class A, 125 pounds.
 - 2. Gate valves three inches and larger shall have nonrising stems and shall meet the requirements of AWWA Standard C-500. Valves for lighter pressures than the AWWA Standard shall meet the requirements of the above specifications except that the requirements for metal thickness and strengths and structural designs shall be adjusted as required to meet hydrostatic test pressures not less than 150 psi.
 - 3. All gate valves shall have standard stuffing box seals. Bonnet bolts, studs and nuts shall be cadmium plated. Seating devices shall be bronze to iron or bronze to bronze. The glands shall be bronze or bronze bushed. Gland bolts and nuts shall be bronze.
 - 4. All gate valves 2½ inches in diameter and larger shall be of the resilient wedge type. Resilient wedge should be nitrite rubber coated ductile iron. All gate valves two inches in diameter and smaller shall be of the double disc or the solid wedge type.
 - 5. Valves to have two inches square operating nut, with the exception that gate valves in altitude valves pits shall have hand wheels.

6. Valves buried in ground or located in vaults or structures shall have suitable extensions for socket operation with top of operating nut located two feet below finished grade maximum.
7. All valves shall include a concrete valve marker with stamped metal tab marking the distance to the valve.

D. Butterfly Valves

1. Butterfly valves shall meet the requirements of AWWA C504-80, except as modified herein. Valves furnished shall be of the short body laying length with operators sized based on the operating conditions.
2. Butterfly valves shall have bodies of cast iron, alloy cast iron or ductile iron with integrally cast hubs for shaft bearing housing, Class 150B.
3. Butterfly valves shall have Type 304 stainless steel valve shaft, keyed for operator connection and connected to disc with Type 304 stainless steel pins secured in place.
4. Butterfly valves will include two way thrust bearings with permanent grease lubrication.
5. Valves shall have resilient valve seat of natural rubber per ASTM D735-R or Buna N Type as per ASTM D735-SB, provide uninterrupted 360 degree seating, mating seat shall be Type 304 or 316 stainless steel. Resilient seat shall be recessed in a groove as per AWWA C504.
6. Valve disc seating shall be 90 degrees to the pipe axis, shall be ductile iron ASTM A536, grade 65-45-12, class 40 cast iron or steel as per ASTM A36.
7. Butterfly valves shall be Henry Pratt, BIF, a Unit of General Signal Corp., Allis Chalmers or approved equal.
8. Resilient seat gate valve conforming to AWWA C509 may be substituted for 12" butterfly valves.

E. Check Valves:

1. Check valves 2" through 24" shall be iron body, bronze mounted swing check valves meeting the requirements of AWWA Standard C508-76.
2. The check valve shall be metal to metal or composite to metal seat construction with flange ends or screw and coupled ends.

F. Altitude Valves:

1. All altitude valves furnished for use on this project shall be equipped for showing at all times the position of the valve. Said altitude valves shall be of the size specified on the drawings and suitable for the use intended.

2. The Contractor shall supply the services of a qualified manufacturer's representative to check and calibrate each altitude valve installation for proper working pressure and sequence.

G. Air Release Valves:

1. Air release valve shall have all bronze body and bonnet. They shall be the direct acting type.
2. Valves shall be hydrostatically tested to at least 150 psi.
3. The valve shall have stainless steel floats and an internal coating with rust inhibitors.

H. Tapping Valve & Sleeve:

The Contractor shall furnish and install tapping sleeves and valves suitable for connection to the existing watermains at locations indicated on the drawings, or required by city engineer or his representative and shall furnish the tapping machine and competent supervision for making of taps. When directed by city engineer or his representative, work shall include cutting and plugging of existing main. Contractor shall verify type, size, O.D. and class of existing pipe before ordering valve and sleeve.

Prior to making tap, Contractor shall hydrostatically pressure test complete tapping sleeve and valve installation at same pressures required under Section 3.03. Tapping sleeve and valve shall be properly supported before mounting tapping machine.

Tapping sleeves shall be cast or ductile iron with mechanical joint ends equal to those manufactured by American Darling, or Mueller Company. Split steel tapping sleeves as manufactured by Rockwell or JCM may be used with approval of city engineer or his representative. Outlets shall be sized to permit a tap to be made using a full size shell cutter. The existing pipe shall be thoroughly cleaned prior to installation of sleeve. Use of strap saddles for taps larger than 2" is not permitted.

Tapping valves shall conform to requirements for gate valves hereinbefore stipulated, except for modifications necessary to permit use of full size cutter.

Backtaps shall not be made unless specifically authorized by city engineer or his representative. All backtaps are to utilize MJ fittings and "Megalug" retainer glands.

2.10 BACKFLOW PREVENTERS

- A. The backflow preventers used shall be those specifically designed for use in connections when the danger from backflow presents a health hazard.
- B. All backflow preventers shall be of the reduced pressure type.

- C. Backflow preventers 3/4" to 2" shall be Hersey, Model FRPII or equal meeting or exceeding the following specifications:
- Mainline Case - Bronze
 - Working Parts - Bronze & Stainless Steel
 - Springs - Stainless Steel
 - Diaphragms - Buna N and Mylar
 - Valve disc - Silicone Rubber
 - O Ring - Buna N
 - Check Valve Enclosure - Glass Reinforced Plastic
 - Maximum Rated Working Pressure - 150 psi
 - Temp. Range - 33° - 210°F
- D. Backflow Preventers 2½" to 10" shall be Model 6CM or equal meeting or exceeding the following specifications:
- Body 8"-10"- Hot Dipped Galvanized or Epoxy Coating
 - Body 2½"-6" - Bronze
 - Working Parts - Bronze & Stainless Steel
 - Springs 2½"-6"- Stainless Steel
 - Springs 8"-10"- Vinyl Coated Carbon Steel
 - Diaphragms - Reinforced Elastomer
 - Valve Disc - Silicone Rubber
 - Maximum Rated Working Pressure - 175 psi
 - Temp. Range - 33° - 140°F
- E. Backflow preventers larger than 10" shall be designed for conditions that do present a health hazard. It shall be the reduced pressure type and depending on the application, may require detection of leaks or unauthorized use. Detectors above 10" shall be submitted for approval. The submittal shall include complete shop drawings. The submittal will be reviewed based on the product's ability to meet the needs of the project and the Owner.

PART 3 - EXECUTION

- A. All valves shall be carefully mounted in their respective positions free from distortion and strain. All valves shall be properly packed and left in satisfactory operating condition at the completion of the project.
- B. Valve box and cover shall be installed with each valve as shown in miscellaneous details.

3.01 PIPE INSTALLATION

- A. PVC pipe shall be installed in accordance with the Uni-Bell Plastic Pipe Association guide for installation of polyvinyl chloride plastic pressure pipe for municipal water main distribution system and the printed recommendations of the manufacturer.
- B. Ductile iron pipe shall be installed in accordance with AWWA C600.
- C. Pipe line alignment and gradient shall be straight, or shall follow true curves as near as practicable. Curvature in pipe lines, where required, shall be well within the allowable laying radius, horizontal and vertical.

- D. Excavation, cleaning, laying, jointing and backfilling shall follow as closely as is possible so as to progress the work. In no case shall pipe be left in the trench overnight without completing the jointing. The completed pipe line shall not be left exposed in the trench unnecessarily, and the Contractor shall backfill and compact the trench as soon as is possible after laying and jointing is completed. Each day at the close of work, and at all times when laying is not in progress, the exposed end of the pipe line in the trench shall be closed with a head or barrier of wood or metal. If at any time it becomes necessary to cover the end of any uncompleted pipe line with backfill, the end of that pipe shall be closed with a mechanical joint plug.
- E. The Contractor shall keep exposed ends of pipe properly plugged during laying to prevent dirt and other materials from entering the line, and shall also, before the system is accepted, thoroughly clean all lines.
- F. Thrust Blocks (Reaction Blocking) shall be provided as specified AWWA C600. All exposed pipes, valves, hydrants, etc., shall be securely strapped and all ends and bends braced.
- G. Other means of pipe restraining shall include "mega lug" utilization and all threads bolted through fittings in accordance with AWWA C600.
- H. Mechanical joints shall be made only by experienced mechanics. Sockets and spigots shall be washed with soapy water before slipping gland and gasket over spigot. The spigot shall be inserted in the socket full depth. The gasket shall be brushed with soapy water, and pushed into position making sure the gasket is evenly seated in the socket. The gland shall then be properly positioned for compressing the gasket. All bolts and nuts shall be tightened with a torque wrench to a uniform, permanent tightness. Bolts shall be tightened alternately 180 degrees apart. Sockets, spigots, glands and bolts shall be kept clean and wet with soapy water until each joint is completed.
- I. All water distribution mains shall have a minimum 36" of cover.

3.02 FIRE HYDRANT INSTALLATION

- A. All fire hydrants shall have 36" minimum pipe cover provided for the branch supply line.
- B. Each fire hydrant shall be set on a stable foundation at least 18 inches square and 6 inches thick and shall be blocked against the end of the trench with concrete and anchored.
- C. Hydrant drainage shall be provided by installing around the hydrant at least 7 cubic feet of gravel or crushed stone below the top of the hydrant supply pipe.
- D. The barrel of the fire hydrant shall be set plumb (perpendicular to the ground) with the lowest discharge outlet at least fifteen (15) inches high but no higher than 24 inches above finished grade. No fire hydrant shall be installed within 10 feet of any private driveway. Hydrants shall be located no closer than 5 feet of a curbing and no further than 12 feet of the curbing.

- E. The hydrant shall be connected to the watermain by using all threads to connect to the valve and to the tee.
- F. Immediately before installation of a hydrant, the following operations shall be performed:
 - 1. The hydrant shall be thoroughly inspected.
 - 2. The hydrant interior shall be thoroughly cleaned.
 - 3. The hydrant shall be opened and closed to determine that all parts are in proper working order, with valves seating properly and the drain valve operating freely.

3.03 HYDROSTATIC TEST

- A. Upon completion of backfilling operations and not less than seven (7) days after the last concrete blocking anchor has been poured, the pipe system shall be subject to hydrostatic test.
- B. The system shall be filled with water and all air expelled.
- C. The Contractor shall pressurize the system to 150 pounds per square inch at the highest point in the system.
- D. The test pressure shall be maintained for two hours.
- E. If the pressure cannot be maintained, the cause shall be determined, corrected and test repeated until successful.

3.04 LEAKAGE TEST

- A. Following the pressure test, the system shall be subject to a leakage test.
- B. Leakage shall be defined as the quantity of water that must be supplied into the pipe to maintain the design working pressure after all air in the pipe line has been expelled and the pipe has been filled with water.
- C. Leakage shall not exceed the quantity determined by the formula given below:

$$L = \frac{ND(\text{Square Root of } P)}{7400}$$

WHERE L= allowable leakage in gallon/hr.
 N= number of joints in pipe line
 D= nominal diameter of the pipe inches
 P= average test pressure during leakage test in psig

- D. If leakage exceeds the allowable rate, leaks shall be found and repaired and the test repeated until successful.

3.05 DISINFECTION

- A. Water mains and accessories shall be disinfected in accordance with "Rules for Safe Drinking Water" as published by the Georgia Environmental Protection Division.
- B. The mains shall be flushed before disinfecting by maintaining a velocity of at least 2.5 feet per second for a period of ten minutes.
- C. The continuous feed method may be used for any size main or system where satisfactory quantity and quality water is available. The tablet method shall not be acceptable.
- D. Following disinfection, the system shall be flushed until chlorine concentration is less than 1 milligram per liter.
- E. Bacteriologic Tests:
 - 1. Tests shall be performed to detect the presence of coliform organisms on samples taken from the end farthest from the point at which chlorine was introduced into the system and at 1000 ft. intervals.
 - 2. If unsatisfactory samples are produced, disinfection shall be repeated until samples are satisfactory.

Not for Bid

SECTION 02650
SANITARY SEWERS

PART 1 - GENERAL

1.01 APPLICABLE STANDARDS

A. American National Standards Institute (ANSI):

- A21.4 Cement-Mortar Lining for Cast-Iron and Ductile-Iron Pipe and Fittings for Water
- A21.6 Cast-Iron Pipe Centrifugally Cast in Metal Molds, for Water or Other Liquids
- A21.11 Rubber Gasket Joints for Cast-Iron and Ductile-Iron Pressure Pipe and Fittings
- A21.51 Ductile Iron Pipe, Centrifugally Cast in Metal Molds or Sand-Lined Molds, for Water or Other Liquids

B. American Society of Testing and Materials (ASTM):

- A48 Gray Iron Castings
- C12 Installing Vitrified Clay Sewer Pipe
- C425 Compression Joints for Vitrified Clay Bell and Spigot Pipe
- C478 Precast Reinforced Concrete Manhole Sections
- C594 Compression Couplings for Vitrified Clay Plain-End Pipe
- C700 Extra Strength and Standard Strength Clay and Perforated Clay Pipe
- D1784 Rigid Poly (Vinyl Chloride) Compounds and Chlorinated Poly (Vinyl Chloride) Compounds
- D2241 Poly (Vinyl Chloride) (PVC) Plastic Pipe (SDR-PR and Class T)
- D2321 Underground Installation of Flexible Thermoplastic Sewer Pipe
- D2774 Underground Installation of Thermo-plastic Pressure Piping
- D3034 Type PSM Poly (Vinyl Chloride) (PVC) Sewer Pipe and Fittings
- D3139 Joints for Plastic Pressure Pipes using Flexible Elastomeric Seals
- D3212 Sewer Pipe Joints using Elastomeric Seals

C. American Water Works Association (AWWA):

- C-600 Installation of Cast-Iron Mains

1.02 SUBMITTALS

- A. Materials used in the sanitary sewer system shall be submitted for approval to the Design Engineer. The Design Engineer shall review the drawings, provide a list of materials and certify compliance to the Owner.
- B. Six copies of shop drawings or manufacturer's standard drawings or catalog cuts shall be submitted for the following:
 - 1. Precast concrete manholes
 - 2. Manholes and Frames
 - 3. Gaskets - One of each type
 - 4. Pipe - One of each type
 - 5. Valves - One of each type

1.03 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. The Contractor shall be responsible for handling and storage of all materials and damaged materials shall not be used in the work. Materials delivered to the site shall be promptly inspected for damage upon arrival. Damaged or defective materials to be immediately removed from the site.
- B. All materials to be stored at least 12 inches above grade. Inside of pipes and fittings shall be kept free of dirt and debris. Rubber gaskets and plastic pipe not used immediately shall be protected from direct sunlight. Manhole units shall be handled with care to avoid chippage or breakage.

PART 2 - PRODUCTS

2.01 POLYVINYL CHLORIDE PIPE AND FITTINGS

- A. Polyvinyl chloride pipe and fittings for gravity sewers shall be SDR-35 for less than 12' bury and SDR – 26 for 12' bury and over, meeting ASTM D3034 for type PSM Polyvinyl Chloride (PVC) sewer pipe. The joints shall be Push-On "O" ring gasket type with integral bell and spigot meeting ASTM 3212. Threaded or solvent welded type joints shall not be used.
- B. Polyvinyl chloride pressure pipe shall meet one of the following specifications:
 - 1. IPS Size PVC Pipe: Class 200 SDR 21 - Polyvinyl chloride water main pipe shall conform to Designation ASTM D2241 and shall consist of Type I, Grade 1 PVC compound conforming to ASTM D1784. All pipe shall be Class 200, SDR 21. The standard laying length shall be 20 ft. ±1 inch.

2. DIP Size PVC Pipe: AWWA C-900-07

- a. C-900 polyvinyl chloride water main pipe 4" TO 12" shall conform to Designation ASTM D2241 and shall consist of Type I, Grade 1 PVC compound conforming to ASTM D1784. All pipe larger than 4" to 12" shall meet the requirements of AWWA C900, "Poly Vinyl Chloride (PVC) pressure pipe." All pipe shall be class 200 pipe and shall meet the requirements of DR14. The standard laying length shall be 20 ft. \pm 1 inch. The FM approved pressure class will be used to determine pressure class.
- b. C-905 polyvinyl chloride water main pipe 14" to 30" shall be manufactured from compounds conforming to PVC cell classification of 12454B as defined in ASTM D-1784. The integral bell joint system meets the requirements of ASTM D-3139 and utilizes an elastomeric seal conforming to ASTM F-477. All pipe shall be class 200 pipe and shall meet the requirements of DR18. The standard laying length shall be 20 ft. \pm 1 inch.
- c. When DIP size PVC pipe is used two 2" PVC pipe shall be SDR 21, 200 PSI pressure class, iron pipe

C. Marking: Pipe shall be clearly marked with:

1. Manufacturer's Identification
2. Nominal Pipe Size
3. Material, Type and Grade
4. SDR or Pressure Rating
5. All gravity sewer pipe shall be green. Force main pipe shall be white or brown.
6. All pipe regardless of color shall be clearly marked **"SEWAGE FORCE MAIN"** or **"GRAVITY SEWER"** as appropriate, marked every three feet.

2.02 DUCTILE IRON PIPE AND FITTING

- A. Type: Coated Ductile
- B. Joints:
 1. Push on type in accordance with ANSI A21.11.
 2. Mechanical joint in accordance with ANSI A21.11 and fittings may be in accordance with A21.53..
- C. Ductile iron pipe shall conform to ANSI A21.51.
- D. Pipe shall have a Protecto 401 lining or equal. The lining should have a high resistance to fatty oils, detergents and sewage generated hydrogen sulfide.

- E. Pipe shall be coated outside with one mil. thick bituminous coating conforming to ANSI A21.4 and AWWA C110, C115OR C151.

2.03 REINFORCED CONCRETE PIPE AND MANHOLES (WET WELLS OR VALVE PITS)

- A. Precast concrete sections to be manufactured in accordance with provisions of ASTM C478. As a minimum, the interior of all sections shall be coated with two coats of bituminous coating. The first coat shall be spray applied and the second coat should be roller applied. In addition, in extremely corrosive environments, to include force main receiving manholes, wetwells, and the first two manhole from the force main connection shall be lined with sealed HDPE sheet liner. The HDPE liner shall have a watertight seal at all joints and penetrations. The liner shall be Agru Sure Grip Liner or equivalent.
- B. Precast concrete riser sections to be 48 inches in diameter with minimum wall thickness of 4 inches.
- C. Precast concrete base units to have minimum wall thickness of 5 inches.
- D. Jointing material shall be rubber gasket type conforming to ASTM C443 or vulcanized butyl rubber base flexible joint sealer in rope form conforming to Federal Specification SS-S-00210, Kent-Seal No. 2 or approved equal. The inside and outside of the joint shall be finished with mortar. Mortar shall be one part Portland cement and two parts sand.
- E. Manhole base sections shall provide for a flexible watertight union between pipe and manhole base. Manhole sleeves shall be of high quality synthetic rubber with tensile strength of 1,500 psi, resistant to raw sewage, ozone, acids, and weathering, flexible at temperatures below 0°F and resistant to heat as high as 250°F. A substantial, serrated flange of the sleeve material shall be integrally cast into the wall of the manhole base forming a tight water seal. The sleeve shall protrude through the wall of the base. A watertight union shall be secured with the end of the pipe with stainless steel strap clamps. Manhole sleeves shall be Interpace Corp. Lock Joint Manhole Sleeves or approved equal.
- F. Pick up holes shall not penetrate the interior walls or the riser.

2.04 MANHOLE FRAMES AND COVERS

- A. Frames and covers to have machined bearing surfaces.
- B. Covers to have checkered top design and marked "Sanitary Sewer" and include the name of the utility owner.
- C. Combined weight of frame and cover shall be approximately 450 pounds.
- D. Frame shall have a depth of approximately 9 inches and an access opening of not less than 20 inches.
- E. Covers shall have two pick holes located at edges.
- F. Materials shall conform to ASTM A48 for Class 30 gray iron castings.

2.05 MANHOLE STEPS

- A. Manhole steps shall be constructed of a number 3 reinforcing bar encapsulated in polypropylene plastic with a non-skid tread.
- B. Finished dimensions of the steps shall be identical to that of malleable iron manhole steps.
- C. Steps to have a minimum tread width of 12 inches.

2.06 NUTS AND BOLTS

- A. Stainless Steel Flanged: Square head MB/SF, hexagon nuts; ASTM 307B; ANSI B18.2, zinc plated.

2.07 GASKETS

- A. Flanged pipe gaskets shall conform to requirements of ASA A21.10 and shall be suitable for the indicated services.

2.08 VALVES

- A. All valves two inches in diameter and smaller shall be constructed of brass or bronze except the hand wheel, which shall be of malleable iron construction. Valves two inches in diameter and smaller shall have screwed ends unless approved otherwise. All valves 2½ inches in diameter and larger shall have flanged ends unless otherwise approved. They shall be iron body, bronze mounted, except that in the smaller sizes the valves may be all bronze at the contractors option and expense.
- B. The contractor shall prepare and submit for approval complete detailed drawings of all valves in accordance with the requirements of the appropriate section of these specifications. All valves of the same type shall be from a single manufacturer. Parts of valves of the same type and size shall be interchangeable. Spare parts shall be furnished as specified under the proposal items. Special tools required for repacking or disassembling valves shall be provided.
- C. All valves shall be carefully mounted in their respective positions free from all distortion and strain. All valves shall be properly packed and left in satisfactory operating condition at the completion of the project. All valves shall open left.
- D. Gate Valves
 - 1. Gate valves should not be used in raw sewage applications. Gate valves should only be used where primary and partial secondary treatment has already occurred.
 - 2. Unless otherwise specified or directed, gate valves three inches and larger shall have non- rising stems and shall meet the requirements of AWWA Standard C-500. Valves for lighter pressures than the AWWA Standard shall meet the requirements of the above specifications except that the requirements for metal thicknesses and strengths and structural designs shall be adjusted as required to meet hydrostatic test pressures not less than 125 psi.

3. Unless otherwise specified or directed, gate valves smaller than three inches shall meet the requirements of Federal Specification WW-V-54, Class A, 125 pounds.
4. All gate valves shall have standard stuffing box seals. Bonnet bolts, studs and nuts shall be cadmium plated. Seating devices shall be bronze to iron or bronze to bronze as specified or required. The glands shall be bronze or bronze bushed. Gland bolts and nuts shall be bronze.
5. All gate valves 2½ inches in diameter and larger shall be of the double disk type. All gate valves two inches in diameter and smaller may be of the double disk or the solid wedge type.

E. Plug Valves

1. All plug valves shall be the two-way type.
2. Nonlubricated, eccentric with resilient faced plugs.
3. Port area of 4 to 20 inch valves shall be at least 70 percent of full pipe area.
4. Valves to be designed for 125 psi working pressure.
5. Bodies to be semisteel with raised seats.
6. Seats to have either a welded-in overlay of approximately 90 percent pure nickel on surfaces contacting the plug face or shall be bronze conforming to ASTM B-62 and attached to the body by stainless steel set screws.
7. Upper and lower plug stem bushings to be stainless steel and shall be permanently lubricated.
8. Exposed nuts, bolts and washers to be zinc plated.
9. Flanges to be faced and drilled to ASA 125 pound standard.

F. Check Valves

1. Type: Ball Check
 - a. Static head must exceed 10 feet to use ball check valves.
 - b. No ball check valve will be mounted vertically to compensate for low static head.
 - c. Ball check ends must be flanged.
 - d. The body shall be cast iron, ASTM A159-72, Class 35.
 - e. The ball shall be hollow steel with vulcanized nitrile rubber covering.
 - f. Pressure rating shall be 150 psi.
 - g. Valve to be Flygt HDL or equal.

2. Lever Actuate Spring Check Valve

- a. Where static head is less than 10 feet lever action swing check valves shall be used.
- b. Lever action swing checks may be spring and lever type or weight on lever type as approved by the design engineer and the Owner.
- c. Valves shall be installed in the horizontal position.
- d. The valve body, disc, cover and lever shall be cast iron, ASTM A159-72, Class 35.
- e. The disc arm shall be cast steel
- f. The seat ring shall be bronze or stainless steel.
- g. All studs, bolts or nuts shall be commercial grade steel.
- h. The gate shall be rubber faced.
- i. The hinge shaft shall be stainless steel.
- j. The chamber shall be bronze.
- k. The valve shall be Clow F5340 (outside spring and lever) or Clow F5345 (outside weight and lever) or an approved equal.

G. Automatic Sewage Air Release Valve

- 1. The automatic sewage air release valve shall be designed to allow entrapped air to escape from the sewage force main line. After the air escapes out of the air release valve, the valve shall shut-off until more air accumulates in it and the opening cycle will repeat automatically.
- 2. The sewage release valve must have a compound internal linkage of precision molded delfin or stainless steel. All other internals must be stainless steel to positively prevent galvanic action. The float rod shall be 20" long to provide an air gap between the linkage and waste level inside the valve to retard the waste solids from clogging the linkage. The stainless steel float must withstand a minimum 1000 psi pressure. Each valve shall be complete with hose and blow off valves to permit back flushing without dismantling valve.

Body and cover cast iron	ASTM A48 Class 30
Internal Delfin linkage	ASTMD2133 (or Stainless Steel)
Stainless Float	ASTM A240
Buna-N	ASTM SB800

- 3. Typical installation will utilize standard body valve. Valve height 28"-with back flushing attachments-33-1/2". If depth of trench is not deep enough, furnish short valve. Valve height 17-1/2" -with back flushing attachments-23-1/2".

4. Automatic sewage air release valve to be as manufactured by Crispin, Val-matic, or APCO equal to APCO Series 400 with accessories.

2.09 ACCESSORIES, PLUG, AND GATE VALVES

- A. Valves to have two inch square operating nut unless otherwise indicated.
- B. Valves buried in ground or located in vaults or structures to have suitable extensions for socket operation with top of operating nut located two feet below finished grades maximum.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Plastic piping installation shall be in accordance with ASTM D2321 Recommended Practice for non-pressure pipe and ASTM D2774 Recommended Practice for pressure pipe.
- B. Ductile iron pressure piping shall be installed in accordance with AWWA Standard C600.
- C. Material selection for piping material shall be as indicated. If piping materials are not indicated the Contractor has the option of selecting materials in accordance with this section.
- D. Service sewer lines shall be constructed of same material as the mains.
- E. Sewer lines shall not be laid closer than 10 feet horizontally to a water main. Pressure sewer lines shall pass beneath water lines, with the top of the sewer being at least 18 inches below the bottom of the water line. Where sanitary sewer lines pass beneath water lines, no joints in the sewer line shall be closer than 10 feet, horizontal the water line. When the vertical or horizontal separation cannot be accomplished, then concrete encasement shall extend a minimum of 10 feet on both sides of crossing.
- F. Pipe laying to proceed up-grade with pipe bells or groove on the upper end. Pipe to be laid with joints close and even, butting all around. Sagging joints will not be tolerated.
- G. Pipe shall be straight and of uniform grade between manholes, laid to line and grade.
- H. All sewer shall be designed and constructed to give velocities of not less than 2.0 FPS. Since the Owner has adopted a low flow plumbing device ordinance, the following slopes will be used.

Minimum Slope in Feet
Sewer Size Per 100 Feet

8"	0.44
10"	0.30
12"	0.24
15"	0.15
18"	0.12
21"	0.10
24"	0.08
30"	0.058
36"	0.046

- I. An allowable deviation from the design grades will be allowed up to 5% of the grade shown on the plan. If the grade is steeper than allowed 5% deviation the engineer must verify that the project was installed to all minimum requirements and determine the impact of the additional grade. If the grade is flatter than the 5% deviation, then it exceeds the allowable tolerance and the installation of that line is not acceptable and must be replaced. All sewer mains installed will be field checked for grades during preparation of "Record drawings".
- I. Bell holes shall be dug so the pipe barrel will carry the load of the pipe. Pipe shall be bedded in undisturbed earth or, where rock occurs, on a thoroughly compacted layer of #57 stone or sand fill of a minimum thickness of 6 inches under the barrel or bell of the pipe.
- J. Where sewers or force mains are to be connected to existing manholes or other structures, and where no stub or opening has been provided for the connection, the Contractor shall make an opening of minimum diameter through the side wall of the structure utilizing a professional coring machine and installing a boot for inserting the sewer pipe. The boot and stainless steel strap shall be sized and installed to create a water tight seal.
- K. Lateral connection made to the sewer prior to back-filling shall be laid on a slope not exceeding 2 feet vertical to 1 foot horizontal, and not less than 1/8 inch per foot, so that the lateral shall have a solid bearing on undisturbed earth as stipulated for pipe sewers. The lateral shall make such a horizontal angle with the sewer line that a proper connection with the wye or tee branch or slant is obtained without trimming the pipe and with no danger of jointing material being forced into the sewer. All laterals shall be closed by means of suitable stoppers or end caps.
- L. Wye or tee branches shall be field located for service to all subdivided lots or inhabitable structures unless otherwise directed by the Architect/Engineer. Wye branches shall be installed so that the lower lip of the branch is not more than 2 inches below the outside top of the pipe. Tees shall be installed with the branch 45° to vertical. After installation, wye or tee branches shall not be covered with backfill until determination and record has been made of the locations of each with reference to the nearest manhole downstream and the direction in which the wye faces.

- M. All laterals shall be properly marked on ground surface at the point where laterals terminate with treated timber markers. Timber markers shall consist of a 2 inch by 4 inch timber extending from the end of the lateral vertically to within 2 inches of the ground surface. All such markers shall be securely anchored and maintained in a proper vertical position until backfilling has been completed. The top end of such markers shall be marked or left exposed until an "as-built" survey has been made.
- N. The top rim of manhole frames and covers shall be set to conform to grades and transverse slopes. Generally along outfall lines, the manhole frames and covers shall extend approximately 6 inches above finished grade or to a designated elevation for flood protection. Generally where lines are located along streets, the manhole frames and covers shall be set flush with the surface.
- O. The Contractor shall install a continuous run of plasticized metallic tape above the top of the sewer main at 12 inches to 18 inches below finished grade. Tape shall be suitable for detection with metal pipe location equipment labeled "sewer buried below," and brightly colored to contrast with the soil.
- P. A 14 gauge copper tracer wire with underground coating shall be installed along the route of pressure sewers. The wire shall be located 12 inches above the pipe but no deeper than 48 inches.
- Q. All PVC pressure pipe shall have a minimum of 36" cover. Areas where the cover is not maintained may require the use of extra strength (D.I.) pipe as directed by the engineer.
- R. All sewer mains will be installed at a constant grade and line as shown on the plans. If after video inspection "sags" are found in the line, then the depth of the sag will be determined by the utility owner. If the sag is determined to be deeper than the following chart then the line will be removed and replaced to meet the minimum requirements of these specifications.

Pipe Size	Max. Sag Depth
8"	0.50"
10"	0.50"
12"	0.75"
15"	0.75"
18"	0.75"

3.02 PRESSURE TESTS

- A. FORCE MAINS: The Contractor shall test by hydrostatic pressure to 150 pounds per square inch. Each section tested shall be slowly filled with water, care being taken to expel all air from the pipes. The required pressure shall be applied for not less than two hours. No pipe installation will be accepted until the leakage during the pressure test is less than the number of gallons listed below for each 1000 feet of pipe.

6" - 1.5 gallons	12" - 2.75 gallons
8" - 1.75 gallons	14" - 3.00 gallons
10" - 2.75 gallons	16" - 3.5 gallons

- B. GRAVITY MAINS: On All sewer mains less than 8' deep, the Contractor shall pressure test the gravity mains with air. Each section including manholes shall be pressurized to 3.5 psi. The allowable pressure drop of 0.5 psi on any portion of the system shall not be less than the times shown on the following chart.

<u>PIPE SIZE</u>	<u>MINIMUM TIME</u>
4"	3 MIN.
6"	4 MIN.
8"	6 MIN.
10"	7 MIN.
12"	8 MIN.

If the main will not maintain the specified pressure, the Contractor will isolate the weak joint and repair. The test will be repeated until successful. The service lines must be installed at least to the back of the curb prior to testing. These pressure drops represent a maximum infiltration/exfiltration rate of 25 gallons per inch of pipe diameter per mile per 24 hour period.

3.03 ALLOWABLE INFILTRATION/EXFILTRATION

- A. If any visible flow is observed in the pipe during installation or final inspection a weir test will be conducted.
- B. The leakage inward or outward (infiltration or exfiltration) of the entire system including the sewer mains, service sewers, manholes and wet wells shall not exceed 25 gallons per inch of pipe diameter per mile per day for any section of the system.
- C. The weir shall be installed in each manhole. The manhole will then be filled with water to a depth of 3' from the top of the pipe, which should be at the bottom of the weir. The water level will stand for one (1) hour to stabilize then filled (if necessary) to the initial level. During the next hour the water level will be observed and the amount flowing through the weir or the amount of water required to maintain the level will be measured. This measured amount should not exceed the allowable.

3.04 INSPECTION

- A. Upon complete installation of the gravity sewer, the Contractor must enter a waiting period of not less than 10 days prior to inspection. In order to initiate the waiting period, the Contractor must notify the Design Engineer and the LCPC inspector in writing of the status of the sewer.
- B. After completion of the waiting period all sewer mains must pass a 5% deflection mandrel pulled by hand. If a 5% deflection mandrel will not pass through any section, that section will be replaced or rerounded at the expense of the Contractor. Mandrel to be supplied by the City of Hinesville inspector.
- C. Once the mandrel and physical inspection is complete the contractor will schedule a time when the owner may internally inspect the sewer main utilizing a sewer camera and generating a video inspection of the system. If any defects are found in the system as a result of the internal inspection then, that section of the sewer main and any mains feeding into that system will not be accepted.

- C. No sewer main will be accepted if there is any evidence of sagging or bowing in the line which will adversely effect the performance of the pipe. Nor will any sewer mains be accepted if they are laid on a grade substantially less that specified on the Construction Plans. No line will be accepted if laid on less grade than the minimum stated in this specification.
- D. All manholes will be inspected for general appearance, cracks, leaks, proper installation of frame and cover, steps and inverts. Any manholes, which do not conform to the specifications, will not be accepted until the deficiency is corrected by the Contractor.
- E. All 4" sewer services will be tested for continuity and minimum bends by passing a standard tennis ball. Each sewer service shall be temporarily capped during construction. During the inspection, a tennis ball will be dropped down the open end of the sewer service. If the ball does not appear in the lower manhole the contractor will excavate the service, correct the blockage and repeat the test until successful.
- F. All manhole and wetwell liner systems shall be tested using the "Spark Test" to locate incomplete welds or penetrations in the liner not adequately sealed for gas containment.

3.05 CLEANING

- A. Contractor to clean the completed system of any debris or obstructions prior to Final Inspection.

Not for Bid

SECTION 02821
GRASSING

PART 1 - GENERAL

1.01 APPLICABLE STANDARDS

- A. Conform to Section 700 and other applicable articles of the "Standard Specifications Construction of Transportation Systems", of the Department of Transportation, State of Georgia, dated April 18, 2013. Omit all references to measurement and payment.

1.02 SOIL SAMPLES

- A. The Contractor shall take soil samples from several areas of the site to be grassed and have them analyzed by the Georgia Extension Service. The results of the analysis shall determine the best fertilizer mixture to use on the site.

PART 2 - MATERIALS

2.01 FERTILIZER

- A. Commercial Fertilizer: Fertilizer for lawns shall be a complete fertilizer, the nitrogen content of which shall be derived from either organic or inorganic sources and meeting the following minimum requirements of plant food by weight, unless the soil analysis and report indicates a need for a different fertilizer mixture in which case the recommended mixture shall be furnished and applied. All State and Federal laws relative to fertilizer must be complied with.

10% Nitrogen - 12% Phosphoric Acid - 12% Potash

- B. Ground Limestone: Lime shall be ground dolomitic limestone containing not less than 85% of total carbonates and shall be ground to such fineness that 50% will pass through a 20-mesh sieve. Coarser material will be acceptable, provided the specified rates of application are increased proportionately on the basis of quantities passing the 100-mesh sieve.
- C. Sodium Nitrate shall be a commercial product in dry powder form and shall be delivered in the original, unopened containers each bearing the manufacturer's guaranteed statement of analysis. It shall contain not less than 16% Nitrogen.

2.02 LAWN MATERIALS

- A. Kentucky 31 Fescue (Fescue elatior: var. arundinacea): Seed shall be 98% minimum purity and 85% germination.
- B. Bermuda Grass (Cyanodon Dactylon): Seed shall be 98% minimum purity and 85% germination.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Prepare the seed bed by thoroughly cultivating, discing and hand raking as necessary to produce a smooth even grade free from hollows or other inequalities. Before any seeding is attempted the soil must be in a well pulverized, smooth, friable condition of uniformly fine texture.

3.02 FERTILIZING AND LIMING

- A. Approximately two (2) days prior to the start of seeding operations, apply ground limestone at the rate of 20 pounds per 1000 sq. ft. of lawn area. Either in conjunction with the above operation or immediately afterwards apply the specified Commercial Fertilizer over all lawn areas at the rate of 30 pounds per 1000 sq. ft. of lawn area. Work limestone into the top 6 inches of ground and the fertilizer into the top 2 inches of ground.
- B. When the grass has started to cover well (approximately 4 weeks after sowing seed) apply 1-1/2 pounds of Ammonium Nitrate to all lawn areas and immediately water using a fine spray. At the end of the maintenance period and prior to the final inspection apply 10 pounds of the specified Commercial Fertilizer per 1000 sq. ft. of lawn area and immediately water.

3.03 SEEDING

- A. Before any seeding is attempted the soil must be in a well pulverized, smooth, friable condition of uniformly fine texture. Lawn areas shall be seeded evenly with a mechanical spreader at the rate of 2 lbs. of seed per 1000 sq. ft., 50% in one direction and the remainder sown at right angles to first sowing. The seeded areas shall be lightly raked, rolled with a suitable weight roller and watered with a fine spray.
- B. Fescue planting season shall be as approved by Engineer.
- C. Bermuda Grass seeding shall be planted only between May 1 to September 1.
- D. When grassing is required between curbs and sidewalks, behind sidewalks in areas adjacent to private property, the Engineer may change the type of seeding to that required to match any type of grass which may be planted and growing on the adjacent lawn. No increase in the Contract Sum will be made for this substitution.

3.04 WATERING

- A. Soak soil to a minimum depth of 6 inches immediately after seeding. Do not wash away soil or seed. Keep all surfaces continuously moist thereafter until 30 days after the lawn has been seeded. Use fine spray nozzles only.

3.05 RESPONSIBILITY

- A. Maintenance of grass areas shall consist of watering, weeding, cutting, repair of any erosion and reseeding or resodding as necessary to establish a uniform stand of the specified grasses, and shall continue until final acceptance.
- B. All grassed areas that do not show satisfactory growth within 15 days after sowing shall be re-sown and re-fertilized as directed until a satisfactory blanket is established. Approximately 3 weeks after sowing the last seed, but not before the seed has taken hold and the grass is growing well, apply sulfate of ammonia or sodium nitrate at the rate of 300 pounds to the acre and water immediately. The lawns shall be considered established when they are reasonably free from weed, green in appearance and the specified grass is vigorous and growing well on each square foot of lawn area. Full coverage is required in 60 days.
- C. All grassed areas shall be protected until accepted. All eroded and damaged areas, regardless of cause, shall be immediately repaired and reseeded. Protect lawn areas against traffic.
- D. Grassed areas shall be covered evenly with a loose layer of clean wheat, rye, oats, Serecia Lespedeza or Coastal Bermuda Hay. Two tons of dry mulch shall be applied to each acre seeded. Hay shall be placed during calm weather with no wind.
- E. As soon as the grass becomes established, a final inspection of the work will be made, provided a written request for such inspection is given to the Engineer. Satisfactory coverage is defined as coverage of the areas seeded with grass that is alive and growing, leaving no bare spots larger than one (1) square foot with 98% coverage.
- F. All temporary valves, cutoffs and piping shall be removed by the Contractor at final acceptance of the grassing.

Not for Bid